

LANDLORD/HOME OWNER GAS SAFETY RECORD

This inspection is for gas safety purposes only in accordance with the current edition of the Gas Safety (Installation and Use) Regulations. Flues were inspected visually and checked for satisfactory evacuation of products of combustion. A detailed internal inspection of the flue integrity, construction and lining has not been carried out.

TENANT/HOME OWNER DETAILS

Tenant/Home Owner* Name:	
Property Address:	37. CROSSWAYS BADDER HILL, YORK
Post Code	
Tenant/Home Owner* present during inspection	YES() NO()

LANDLORD/AGENT DETAILS (if applicable)

Landlord/Agent* Name:	ARMAN BARNWELL LIMITED
Address:	58. GUYGATE, YORK
Post Code	
Landlord/Agent* present during inspection	YES() NO()

GAS INSTALLER: (Trading Title)	C. ROBERTSON
Name:	C. ROBERTSON
Address:	19. LELANDON CROFT RAWCROFT, YORK
Post code:	YO30 5ZG
Tel:	0770448500
Gas Safe Register No:	157664
Gas Installer Ref. No :	H.B.
Date of Issue:	25/7/23
Time of Issue:	
Engineers Name: (print)	C. ROBERTSON

APPLIANCE DETAILS					INSPECTION DETAILS					FLUE TEST					RESULTS			
LOCATION	MAKE	MODEL	TYPE	Flue Type e.g. CF or RS	Operating Pressure Mbar	Heat Input Kw	Safety Device Correct Operation Yes/No	Ventilation Adequate Yes/No	CO Alarm fitted Yes/No	CO Alarm tested Pass/Fail	Flue Flow Test Pass/Fail	Spillage Test Pass/Fail	Termination Test Satisfactory Yes/No	Visual Condition Pass/Fail	Combustion Performance Reading CO: CO2 CO	Appliance Safe To Use Yes/No	Landlord's Appliance Yes/No	Inspected Yes/No
1	UTILITY	4440	HE	R-S	20	1	YES	YES	YES	PASS	PASS	PASS	CO 0.00	PASS	8.6/25.88	YES	YES	YES
2	WATER	BEULIE	FL	F-L	20	1	YES	YES	YES	PASS	PASS	PASS	N/A	PASS	N/A	YES	YES	YES
3																		
4																		
5																		

DETAILS OF WORK CARRIED OUT

LABEL & WARNING NOTICE ISSUED

DETAILS OF ANY FAULTS		REMEDIAL ACTION TAKEN		DETAILS OF WORK CARRIED OUT		LABEL & WARNING NOTICE ISSUED	
1	BRASS CAP MISSING FROM COOKER			PART REGR		Yes	NO
2	GAS PIPE NOT SECURED IN WALL						
3							
4							
5							

Outcome of gas installation pipework visual inspection?	Pass / Fail / NA
Outcome of gas supply pipework visual inspection?	Pass / Fail / NA
Is the Emergency Control Valve access satisfactory?	Pass / Fail / NA
Outcome of gas tightness test?	Pass / Fail / NA
Is the Protective Equipotential bonding satisfactory?	Pass / Fail / NA

This Safety Record is issued by Gas Installer: (SIGNED)	
Received on behalf of Landlord / Home Owner: (SIGNED)	
Tenant/Landlord/Agent/Home Owner*	
Number of appliances tested:	220
Date:	25/7/23