



ELECTRICAL INSTALLATION CERTIFICATE

Requirements for Electrical Installations - BS 7671: 2018+A2:2022
(IET Wiring Regulations 18th Edition)

Guidance for recipients:

This safety Certificate has been issued to confirm that the electrical installation work to which it relates has been designed, constructed, inspected and tested in accordance with BS 7671 (the IET Wiring Regulations).

You should have received an 'original' Certificate and the person that issued the Certificate should have retained a duplicate.

If you were the person ordering this work, but not the owner of the installation, you should pass this Certificate, or a full copy of it, immediately to the owner. The original Certificate is to be retained in a safe place and be shown to any person inspecting or undertaking work on the electrical installation in the future.

If you later vacate the property, this Certificate will demonstrate to the new owner that the electrical installation complied with the requirements of BS 7671 at the time the Certificate was issued.

The Construction (Design and Management) Regulations require that, for a project covered by those Regulations, a copy of this certificate, together with schedules, is included in the project health and safety document.

For safety reasons, the electrical installation will need to be re-inspected at appropriate intervals by a skilled person or persons, competent in such work. The maximum time interval recommended before the next inspection is stated in Section 3 under "NEXT INSPECTION".

This Certificate is intended to be issued only for a new electrical installation or for new work associated with an addition or alteration to an existing installation. It should not have been issued for the inspection and testing of an existing electrical installation. An "Electrical Installation Condition Report" should be issued for such an inspection.

This Certificate is only valid if the Schedule of Inspections has been completed to confirm that all relevant inspections have been carried out and where accompanied by Schedule(s) of Circuit Details and Test Results.

Where the installation includes a residual current device (RCD) it should be tested six-monthly by pressing the button marked 'T' or 'Test'. The device should switch off the supply and should then be switched on to restore the supply. If the device does not switch off the supply when the button is pressed, seek expert advice. For safety reasons it is important that this instruction is followed.

Where the installation includes an arc fault detection device (AFDD) having a manual test facility it should be tested six-monthly by pressing the test button. Where an AFDD has both a test button and automatic test function, manufacturer's instructions shall be followed with respect to test button operation.

Where the installation includes a surge protective device (SPD) the status indicator should be checked to confirm it is in operational condition in accordance with manufacturer's information. If the indication shows that the device is not operational, seek expert advice. For safety reasons it is important that this instruction is followed.

Where the installation includes alternative or additional sources of supply, warning notices should be found at the origin or meter position or, if remote from the origin, at the consumer unit or distribution board and at all points of isolation of all sources of supply.

ELECTRICAL INSTALLATION CERTIFICATE
[BS 7671: 2018+A2:2022 as amended]

FT/EIC 673500001443

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



Client Details

Client	Mike Gray	Installation	Mike Gray
Address	48 Constantine Avenue YORK	Address	48 Constantine Avenue YORK
Postcode	YO10 3TA	Postcode	YO10 3TA

Details of the Installation

Description of premises Domestic Commercial Industrial Date of original installation

Installation is New Addition Alteration Records Available Yes No RCD Risk assessment attached

Description of the installation
New consumer unit fitted following EICR

Extent of the installation covered by this certificate
All circuits tested due to consumer unit upgrade

Details of departures from BS 7671 (regulations 120.3, 133.1.3 and 133.5)
NA

Details of permitted exception. (regulation 411.3.3) where applicable a suitable risk assessment(s) must be attached to this certificate
NA

Declaration for Design, Construction, Inspection and Testing (for sole person responsibility)

I being the person responsible for design, construction, inspection and the test of the electrical installation (as indicated by my signature below), particulars of which are described in Section 2, having exercised reasonable skill and care when carrying out the design, construction, inspection and test hereby CERTIFY that the design, construction, inspection and test for which i have been responsible is to the best of my knowledge and belief in accordance with BS 7671:2018, amended to except for the departures, if any, listed below. The extent of liability of the signatory or the signatories is limited to work described in Section 2 as subject of this certificate.

For the DESIGN / CONSTRUCTION / INSPECTION & TEST of the installation:

Company	<input type="text" value="JB Electrical Services"/>	Position	<input type="text" value="Owner"/>		
Inspector Name	<input type="text" value="Terence John Berry"/>	Date	<input type="text" value="21/11/2023"/>		
Address	<input type="text" value="31 Main Street"/> <input type="text" value="Stamford Bridge, North Yorkshire"/> <input type="text" value="YO41 1AD"/>	Scheme No.	<input type="text" value="25729"/>	Branch No.	<input type="text"/>
Reviewed By	<input type="text" value="Terence John Berry"/>	Signature	<input type="text" value="JB"/>		
Reviewed By Date	<input type="text" value="21/11/2023"/>	Reviewed By Signature	<input type="text" value="JB"/>		

Next inspection I the designer recommend that this installation is further inspected after an interval of not more than years

ELECTRICAL INSTALLATION CERTIFICATE
[BS 7671: 2018+A2:2022 as amended]

FT/EIC 673500001443

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
 BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



Supply Characteristics and Earthing Arrangements

Earthing Arrangements TN-S TN-C-S TT Other If Other please specify

Number & Type of live conductors AC DC No. of phases No. of wires

Nature of Supply Parameters (Note: ⁽¹⁾ by enquiry, ⁽²⁾ by enquiry or by measurement)

Nominal voltage, U/U₀ ⁽¹⁾ v Nominal frequency, f⁽¹⁾ Hz Confirmation of polarity

Prospective fault current, I_{pf} ⁽²⁾ kA External loop impedance, Z_e ⁽²⁾ Ω

Supply Protective Device BS (EN) Type Rated Current A

No. of Additional Supplies

Particulars of Installation at the Origin

Details of installation Earth Electrode (where applicable) Type (e.g. rod(s), tape etc) Distributors facility Installation Earth Electrode

Location Electrode resistance to earth Ω Maximum Demand (load) Amps KVA

Main Protective Conductors	Material	csa	(✓) or Value	(✓) or Value
Earthing Conductor	Copper	16	mm ² Continuity Verified <input checked="" type="checkbox"/>	Ω Connection Verified <input checked="" type="checkbox"/>
Protective Bonding Conductor	Copper	10	mm ² Continuity Verified <input checked="" type="checkbox"/>	Ω Connection Verified <input checked="" type="checkbox"/>

Main Supply Conductor	Material	csa	(connection / continuity) (✓) or Value	(✓) or Value
	Copper	25	mm ²	

Main Switch Location

Fuse/device rating or setting A Voltage rating V BS(EN) No. of Poles Current Rating A

If RCD main switch: Rated residual operating current I_{Δn} mA Rated time delay ms Measured operating trip time ms

Comments on existing installation (in case of addition or alteration see section 644.1.2) use continuation sheet if needed

Existing installation appears to be in a satisfactory condition

(For additions or alterations) cables concealed within trunking and conduits, or cables or conduits concealed under floors, in roof spaces and generally within the fabric of the building or underground may not have been inspected.

Schedule of Inspection - Outcomes

Indicates an inspection has been carried out and the result is satisfactory		Indicates the inspection is not applicable to a particular item	
1.0	Condition of consumer's intake equipment (visual inspection only)	8.0	Circuits (Distribution and Final)
2.0	Parallel or switched alternative sources of supply	9.0	Isolation and switching
3.0	Protective measure: Automatic Disconnection of Supply (ADS)	10.0	Current-using equipment (permanently connected)
4.0	Basic Protection	11.0	Identification and notices
5.0	Protective measure other than ADS	12.0	Location(s) containing a bath or shower
6.0	Additional protection	13.0	Other special installations or locations
7.0	Distribution equipment	14.0	Prosumer's low voltage electrical installation(s)

SCHEDULES: This certificate is only valid when (enter quantities of schedules attached) schedules of circuit details and test results are attached

Inspector's Name: Signature:

Date:

ELECTRICAL INSTALLATION CERTIFICATE - Circuit Details

FT/EIC 673500001443

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



Client Name	Mike Gray	Installation Address	Mike Gray, 48 Constantine Avenue, YORK
Client Address	48 Constantine Avenue YORK	Postcode	YO10 3TA
Client Postcode	YO10 3TA		

Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation	
SPD Details: Type(s)*	T1 <input checked="" type="checkbox"/> T2 <input type="checkbox"/> T3† <input type="checkbox"/> N/A <input type="checkbox"/>	Overcurrent protective device for the distribution circuit:	Supply to distribution board is from _____
Location	Hallway Cupboard	No. of phases	1 BS(EN) _____ Type _____ Rating _____ A
Designation	DB 1	Nominal voltage	_____ V RCD BS(EN) _____ Type _____ Rating _____ IΔn mA
No. of ways	12		

SCHEDULE OF CIRCUIT DETAILS

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method †:	No. of points served	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (S)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other Other § 80% (Ω)	RCD			
					L / N	GPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/S	Cooker	A	B	1	6	2.5	0.4	61009 RCD/RCBO	B	40	6	0.87	61009	A	30	40
2/S	Kitchen Sockets	A	B	7	2.5	1.5	0.4	61009 RCD/RCBO	B	32	6	1.09	61009	A	30	32
3/S	Sockets	A	B	11	2.5	1.5	0.4	61009 RCD/RCBO	B	32	6	1.09	61009	A	30	32
4/S	Cooker Hood	A	B	1	4	1.5	0.4	61009 RCD/RCBO	B	32	6	1.09	61009	A	30	32
5/S	Heating	A	B	1	2.5	1.5	0.4	61009 RCD/RCBO	B	16	6	2.18	61009	A	30	16
6/S	Lighting	A	B	11	1	1	0.4	61009 RCD/RCBO	B	6	6	5.82	61009	A	30	6
7/S	Smoke Alarm	A	B	2	1	1	0.4	61009 RCD/RCBO	B	6	6	5.82	61009	A	30	6
8/S	Front Yard Light	A	B	1	1	1	0.4	61009 RCD/RCBO	B	6	6	5.82	61009	A	30	6
9/S	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/S	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
11/S	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12/S	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)
 ‡: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

ELECTRICAL INSTALLATION CERTIFICATE - Test Results

FT/EIC 6735000001443

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



Client Name	Mike Gray	Installation Address	Mike Gray, 48 Constantine Avenue, YORK
Client Address	48 Constantine Avenue YORK	Client Postcode	YO10 3TA
Distribution board details - Complete in every case		Complete only if the distribution board is not connected directly to the origin of the installation	
Location	Hallway Cupboard	Associated RCD (if any):	BS (EN)
Designation	DB 1	Z _{db}	Ω Operating at IΔn
No. of ways	12 <input checked="" type="checkbox"/> Supply polarity confirmed <input checked="" type="checkbox"/> Phase sequence confirmed	I _{pf}	kA No. of poles
No. of phases	1 SPD: <input checked="" type="checkbox"/> Operational status confirmed <input type="checkbox"/> Not applicable	Time delay (if applicable)	

TEST RESULTS

Circuit No. and Line	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity	Max. Measured Z _s (Ω)	RCD testing All RCDs IΔn ms	Manual test button operation	
	Ring final circuits only			Fig 6 check (✓)	R1R2 or R2		Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)				RCD (✓)	AFDD (✓)
	r1	r _n	r2		R1 + R2	R2								
1/S	N/A	N/A	N/A	N/A	0.16	N/A	500	>200	23.9	✓	0.38	38.7	✓	N/A
2/S	0.10	0.14	0.16	✓	0.03	N/A	500	>200	147.4	✓	0.12	38.7	✓	N/A
3/S	0.45	0.50	1.49	✓	0.37	N/A	500	>200	52.9	✓	0.30	38.1	✓	N/A
4/S	N/A	N/A	N/A	N/A	0.10	N/A	500	>200	111.4	✓	0.19	38.1	✓	N/A
5/S	N/A	N/A	N/A	N/A	0.32	N/A	500	>200	>200	✓	0.71	38.1	✓	N/A
6/S	N/A	N/A	N/A	N/A	0.50	N/A	500	>200	107.8	✓	0.69	38.1	✓	N/A
7/S	N/A	N/A	N/A	N/A	0.47	N/A	500	>200	>200	✓	0.68	38.1	✓	N/A
8/S	N/A	N/A	N/A	N/A	0.27	N/A	500	>200	>200	✓	0.41	38.1	✓	N/A
9/S	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/S	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
11/S	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12/S	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing

NA

Date(s) dead testing 21/11/2023 To 21/11/2023

Date(s) live testing 21/11/2023 To 21/11/2023

Test instrument serial number(s)

Loop impedance 20991571 Insulation resistance 20991571 Continuity 20991571 RCD 20991571 E/Electrode

Tested by: Name (capital letters) TERENCE JOHN BERRY Signature

Position Owner Date 21/11/2023