



# ELECTRICAL INSTALLATION CERTIFICATE

Requirements for Electrical Installations - BS 7671: 2018+A2:2022  
(IET Wiring Regulations 18th Edition)

## Guidance for recipients:

This safety Certificate has been issued to confirm that the electrical installation work to which it relates has been designed, constructed, inspected and tested in accordance with BS 7671 (the IET Wiring Regulations).

You should have received an 'original' Certificate and the person that issued the Certificate should have retained a duplicate.

If you were the person ordering this work, but not the owner of the installation, you should pass this Certificate, or a full copy of it, immediately to the owner. The original Certificate is to be retained in a safe place and be shown to any person inspecting or undertaking work on the electrical installation in the future.

If you later vacate the property, this Certificate will demonstrate to the new owner that the electrical installation complied with the requirements of BS 7671 at the time the Certificate was issued.

The Construction (Design and Management) Regulations require that, for a project covered by those Regulations, a copy of this certificate, together with schedules, is included in the project health and safety document.

For safety reasons, the electrical installation will need to be re-inspected at appropriate intervals by a skilled person or persons, competent in such work. The maximum time interval recommended before the next inspection is stated in Section 3 under "NEXT INSPECTION".

This Certificate is intended to be issued only for a new electrical installation or for new work associated with an addition or alteration to an existing installation. It should not have been issued for the inspection and testing of an existing electrical installation. An "Electrical Installation Condition Report" should be issued for such an inspection.

This Certificate is only valid if the Schedule of Inspections has been completed to confirm that all relevant inspections have been carried out and where accompanied by Schedule(s) of Circuit Details and Test Results.

Where the installation includes a residual current device (RCD) it should be tested six-monthly by pressing the button marked 'T' or 'Test'. The device should switch off the supply and should then be switched on to restore the supply. If the device does not switch off the supply when the button is pressed, seek expert advice. For safety reasons it is important that this instruction is followed.

Where the installation includes an arc fault detection device (AFDD) having a manual test facility it should be tested six-monthly by pressing the test button. Where an AFDD has both a test button and automatic test function, manufacturer's instructions shall be followed with respect to test button operation.

Where the installation includes a surge protective device (SPD) the status indicator should be checked to confirm it is in operational condition in accordance with manufacturer's information. If the indication shows that the device is not operational, seek expert advice. For safety reasons it is important that this instruction is followed.

Where the installation includes alternative or additional sources of supply, warning notices should be found at the origin or meter position or, if remote from the origin, at the consumer unit or distribution board and at all points of isolation of all sources of supply.

**ELECTRICAL INSTALLATION CERTIFICATE**  
**[BS 7671: 2018+A2:2022 as amended]**

FT/EIC 673500001712

for Residential or Similar Premises up to 100 A

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



**Client Details**

Client	Samantha Haydon	Installation	Samantha Haydon
Address	18 Thief Lane YORK	Address	18 Thief Lane YORK
Postcode	YO10 3HS	Postcode	YO10 3HS

**Details of the Installation**

Description of premises Residential or Similar  Commercial  Industrial  Date of original installation

Installation is New  Addition  Alteration  Records Available Yes  No  RCD Risk assessment attached

Description of the installation  
Wiring of new loft conversion, modifications to heating and kitchen circuits and new consumer unit fitted

Extent of the installation covered by this certificate  
All circuits tested due to consumer unit upgrade

Details of departures from BS 7671 (regulations 120.3, 133.1.3 and 133.5)  
NA

Details of permitted exception. (regulation 411.3.3) where applicable a suitable risk assessment(s) must be attached to this certificate  
NA

**Declaration for Design, Construction, Inspection and Testing (for sole person responsibility)**

I being the person responsible for design, construction, inspection and the test of the electrical installation (as indicated by my signature below), particulars of which are described in Section 2, having exercised reasonable skill and care when carrying out the design, construction, inspection and test hereby CERTIFY that the design, construction, inspection and test for which i have been responsible is to the best of my knowledge and belief in accordance with BS 7671:2018, amended to  except for the departures, if any, listed below. The extent of liability of the signatory or the signatories is limited to work described in Section 2 as subject of this certificate.

For the DESIGN / CONSTRUCTION / INSPECTION & TEST of the installation:

Company	<input type="text" value="JB Electrical Services"/>	Position	<input type="text" value="Owner"/>		
Inspector Name	<input type="text" value="John Berry"/>	Date	<input type="text" value="20/09/2024"/>		
Address	<input type="text" value="31 Main Street"/> <input type="text" value="Stamford Bridge"/> <input type="text" value="YO41 1AD"/>	Scheme No.	<input type="text"/>	Branch No.	<input type="text"/>
Reviewed By	<input type="text" value="John Berry"/>	Signature	<input type="text"/>		
Reviewed By Date	<input type="text" value="20/09/2024"/>	Reviewed By Signature	<input type="text"/>		

Next inspection I the designer recommend that this installation is further inspected after an interval of not more than  years

for Residential or Similar Premises up to 100 A

Requirements for Electrical Installations  
 BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



**Supply Characteristics and Earthing Arrangements**

Earthing Arrangements TN-S  TN-C-S  TT  Other  If Other please specify

Number & Type of live conductors AC  DC  No. of phases  No. of wires

**Nature of Supply Parameters (Note: <sup>(1)</sup> by enquiry, <sup>(2)</sup> by enquiry or by measurement)**

Nominal voltage, U/U<sub>0</sub> <sup>(1)</sup>  v Nominal frequency, f<sup>(1)</sup>  Hz Confirmation of polarity

Prospective fault current, I<sub>pf</sub> <sup>(2)</sup>  kA External loop impedance, Z<sub>e</sub> <sup>(2)</sup>  Ω

Supply Protective Device BS (EN)  Type  Rated Current  A

No. of Additional Supplies

**Particulars of Installation at the Origin**

**Details of installation Earth Electrode** (where applicable) Type (e.g. rod(s), tape etc)  Distributors facility  Installation Earth Electrode

Location  Electrode resistance to earth  Ω Maximum Demand (load)  Amps  KVA

Main Protective Conductors	Material	csa	(✓) or Value	(✓) or Value
Earthing Conductor	Copper	16	mm <sup>2</sup> Continuity Verified <input checked="" type="checkbox"/>	Ω Connection Verified <input checked="" type="checkbox"/>
Protective Bonding Conductor	Copper	10	mm <sup>2</sup> Continuity Verified <input checked="" type="checkbox"/>	Ω Connection Verified <input checked="" type="checkbox"/>

Main Supply Conductor	Material	csa	(connection / continuity) (✓) or Value	(✓) or Value
	Copper	25	mm <sup>2</sup>	

**Main Switch** Location

Water installation  Ω To structural steel  Ω  
 Gas installation pipes  Ω To lightning protection  Ω  
 Oil installation pipes  Ω Other  Ω

**Fuse/device rating or setting**  A Voltage rating  V BS(EN)  No. of Poles  Current Rating  A

**If RCD main switch:** Rated residual operating current I<sub>Δn</sub>  mA Rated time delay  ms Measured operating trip time  ms

**Comments on existing installation** (in case of addition or alteration see section 644.1.2) use continuation sheet if needed

Existing installation appears to be in a satisfactory condition

(For additions or alterations) cables concealed within trunking and conduits, or cables or conduits concealed under floors, in roof spaces and generally within the fabric of the building or underground may not have been inspected.

**Schedule of Inspection - Outcomes**

Indicates an inspection has been carried out and the result is satisfactory		Indicates the inspection is not applicable to a particular item	
1.0	Condition of consumer's intake equipment (visual inspection only)	8.0	Circuits (Distribution and Final)
2.0	Parallel or switched alternative sources of supply	9.0	Isolation and switching
3.0	Protective measure: Automatic Disconnection of Supply (ADS)	10.0	Current-using equipment (permanently connected)
4.0	Basic Protection	11.0	Identification and notices
5.0	Protective measure other than ADS	12.0	Location(s) containing a bath or shower
6.0	Additional protection	13.0	Other special installations or locations
7.0	Distribution equipment	14.0	Prosumer's low voltage electrical installation(s)

**SCHEDULES:** This certificate is only valid when (enter quantities of schedules attached)  schedules of circuit details and test results are attached

Inspector's Name:  Signature:

Date:

**ELECTRICAL INSTALLATION CERTIFICATE - Circuit Details**

FT/EIC 673500001712

for Residential or Similar Premises up to 100 A

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b>	Samantha Haydon	<b>Installation Address</b>	Samantha Haydon, 18 Thief Lane, YORK
<b>Client Address</b>	18 Thief Lane YORK	<b>Postcode</b>	YO10 3HS
<b>Client Postcode</b>	YO10 3HS		

<b>Distribution board details - Complete in every case</b> SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3† <input type="checkbox"/> N/A <input type="checkbox"/> Location <input type="text"/> Designation DB 1 <input type="text"/> No. of ways 11 <input type="text"/>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Overcurrent protective device for the distribution circuit: Supply to distribution board is from <input type="text"/> No. of phases 1 <input type="text"/> BS(EN) <input type="text"/> Type <input type="text"/> Rating <input type="text"/> A Nominal voltage <input type="text"/> V RCD BS(EN) <input type="text"/> Type <input type="text"/> Rating <input type="text"/> IΔn mA	
--	--	--	--

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method †	No. of points served	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (S)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other §	RCD			
					L / N	GPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/S	Hob	A	B	1	6	2.5	5	61009 RCD/RCBO	B	40	6	0.87	61009	A	30	40
2/S	Sockets	A	B	19	2.5	1.5	0.4	61009 RCD/RCBO	B	32	6	1.09	61009	A	30	32
3/S	Kitchen Sockets	A	B	7	2.5	1.5	0.4	61009 RCD/RCBO	B	32	6	1.09	61009	A	30	32
4/S	Garage/Socket Below	A	B	6	2.5	1.5	0.4	61009 RCD/RCBO	B	20	6	1.75	61009	A	30	20
5/S	Oven	A	B	1	2.5	1.5	0.4	61009 RCD/RCBO	B	16	6	2.18	61009	A	30	16
6/S	Smokes/Ground Lights	A	B	9	1	1	0.4	61009 RCD/RCBO	B	6	6	5.82	61009	A	30	6
7/S	First/Second Floor Lighting	A	B	13	1	1	0.4	61009 RCD/RCBO	B	6	6	5.82	61009	A	30	6
8/S	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
9/S	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/S	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
11/S	SPARE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 ‡: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CERTIFICATE - Test Results**

FT/EIC 6735000001712

for Residential or Similar Premises up to 100 A

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b>	Samantha Haydon	<b>Installation Address</b>	Samantha Haydon, 18 Thief Lane, YORK
<b>Client Address</b>	18 Thief Lane YORK	<b>Client Postcode</b>	YO10 3HS
<b>Distribution board details - Complete in every case</b>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b>	
Location		Associated RCD (if any):	BS (EN) <input type="checkbox"/>
Designation	DB 1	Z <sub>db</sub>	<input type="text"/> Ω Operating at IΔn <input type="text"/> ms
No. of ways	11 <input checked="" type="checkbox"/> Supply polarity confirmed <input type="checkbox"/> Phase sequence confirmed	I <sub>pf</sub>	<input type="text"/> kA No. of poles <input type="text"/> Time delay (if applicable) <input type="text"/>
No. of phases	1 SPD: <input checked="" type="checkbox"/> Operational status confirmed <input type="checkbox"/> Not applicable		

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω						Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing All RCDs IΔn ms	Manual test button operation	
	Ring final circuits only			Fig 8 check (✓)	R1R2 or R2		Test voltage V	L/L, L/N M(Ω)	L/E, N/E M(Ω)				RCD (✓)	AFDD (✓)
	r1	r <sub>m</sub>	r2		R1 + R2	R2								
1/S	N/A	N/A	N/A	N/A	0.17	N/A	500	>200	151.6	✓	0.29	38.1	✓	N/A
2/S	0.39	0.43	0.72	✓	0.27	N/A	500	>200	122.7	✓	0.58	38.1	✓	N/A
3/S	0.25	0.29	0.51	✓	0.18	N/A	500	>200	174.6	✓	0.42	38.1	✓	N/A
4/S	N/A	N/A	N/A	N/A	0.71	N/A	500	>200	104.7	✓	0.96	38.1	✓	N/A
5/S	N/A	N/A	N/A	N/A	0.24	N/A	500	>200	>200	✓	0.49	38.1	✓	N/A
6/S	N/A	N/A	N/A	N/A	0.82	N/A	500	>200	121.7	✓	1.21	38.1	✓	N/A
7/S	N/A	N/A	N/A	N/A	1.06	N/A	500	>200	113.3	✓	1.38	38.1	✓	N/A
8/S	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
9/S	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10/S	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
11/S	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing		Date(s) dead testing	20/09/2024	To	20/09/2024					
NA		Date(s) live testing	20/09/2024	To	20/09/2024					
Test instrument serial number(s)	Loop impedance	20991571	Insulation resistance	20991571	Continuity	20991571	RCD	20991571	E/Electrode	
Tested by: Name (capital letters)		JOHN BERRY		Signature						
Position	Owner	Date	20/09/2024							