



NAPIT Electrical Certificate Installation/Modification

Requirements for Electrical Installations – BS 7671: 2008
incorporating Amendment No.3, 2015 [IET Wiring Regulations 17th Edition]
All items inspected to confirm as appropriate, compliance with the relevant clauses in BS7671

NA/EIC **525544**
Page **1** of **3**

1 Details of the Installation

Client	MRS S VASICLI
Address	14 HALL PARK YORK
Postcode	YO10 5DT

Installation (If different from client)	
Address	23 TURNERS CROFT YORK
Postcode	YO10 5EL

2 Description, extent and limitations of the Installation (note 5)

Installation is New Addition Alteration Records available Yes No Date of original installation **1980's?**

Description of installation
6 Bedroom House

Extent of installation covered by this Certificate
ALL ELECTRICAL INSTALLATION

Details of departure from BS7671 (Regulations 120.3 and 133.5)
Details of permitted exceptions. [Regulation 411.3.3] Where applicable a suitable risk assessment[s] must be attached to this certificate
NONE Risk assessment attached

3 For design, construction, inspection and testing (for sole person responsibility.) (for multiple persons responsibility complete sec. 4,5,15)

I being the person responsible for design, construction, inspection and test of the electrical installation (as indicated by my signature below), particulars of which are described in Section 2, having exercised reasonable skill and care when carrying out the design, construction, inspection and test hereby CERTIFY that the design, construction, inspection and test for which I have been responsible is to the best of my knowledge and belief in accordance with BS 7671:2008, amended to **2015** (date)
The extent of liability of the signatory or the signatories is limited to the work described in Section 2 as subject of this certificate.
For the DESIGN / CONSTRUCTION / INSPECTION AND TEST of the installation:

Company name	P. D. CLARK ELECTRICAL LTD
Installer	P. CLARK
Company address	7 MEADOW LANE YORK
Postcode	YO32 2YU

Signature	
Position	TBSTER
Date	10/10/25
NAPIT membership No.	14236

4 For construction (if different from sec. 3)

I being the person responsible for construction of the electrical installation (as indicated by my signature below), particulars of which are described in Section 2, having exercised reasonable skill and care when carrying out the construction hereby CERTIFY that the construction work for which I have been responsible is to the best of my knowledge and belief in accordance with BS7671:2008, amended to (date)
The extent of liability of the signatory or the signatories is limited to the work described in Section 2 as subject of this certificate.
For the CONSTRUCTION of the Installation:

Company name	
Installer	
Company address	
Postcode	

Signature	
Position	
Date	
NAPIT membership No.	

5 For inspection and testing (if different from sec. 3)

I being the person responsible for the inspection and testing of the electrical installation (as indicated by my signature below), particulars of which are described in Section 2, having exercised reasonable skill and care when carrying out the inspection and testing hereby CERTIFY that the work for which I have been responsible is to the best of my knowledge and belief in accordance with BS7671 :2008, amended to (date)
The extent of liability of the signatory or the signatories is limited to the work described in Section 2 as subject of this certificate.
For the INSPECTION AND TESTING of the Installation:

Company name	
Inspector	
Company address	
Postcode	

Signature	
Position	
Date	
NAPIT membership No.	

Next inspection I/we the designer(s) recommend that this Installation is further inspected after an interval of not more than years/months



NAPIT Electrical Certificate Installation/Modification

Requirements for Electrical Installations – BS 7671: 2008
incorporating Amendment No.3,2015 [IET Wiring Regulations 17th Edition]
All items inspected to confirm as appropriate, compliance with the relevant clauses in BS7671

NA/EIC

525544

Page 2 of 3

6 For Designer 1 (if different from sec.3)

Company name	
Designer	
Address	
Postcode	
Date	NAPIT Membership No.

I/We being the person(s) responsible for design of the electrical installation (as indicated by my/our signature below), particulars of which are described in Section 2, having exercised reasonable skill and care when carrying out the design hereby CERTIFY that the design work for which I/We have been responsible is to the best of my/our knowledge and belief in accordance with BS7671:2008, amended to (date)

Signature

For Designer 2** (if applicable & different from sec.3)

Company name	
Designer	
Address	
Postcode	
Date	NAPIT Membership No.

I/We being the person(s) responsible for design of the electrical installation (as indicated by my/our signature below), particulars of which are described in Section 2, having exercised reasonable skill and care when carrying out the design hereby CERTIFY that the design work for which I/We have been responsible is to the best of my/our knowledge and belief in accordance with BS7671:2008, amended to (date)

Signature

7 Supply characteristics and earthing arrangements

Earthing Arrangements TN-S TN-C-S TT Other Please specify:

Number a type of live conductors a.c. d.c. No. of phases 1 No. of wires 2

Nature of Supply Parameters (Note: (!) by enquiry, (?) by enquiry or by measurement)

Nominal voltage, U_o (!) 244 V Nominal frequency, f(!) 50 Hz Confirmation of supply polarity

Prospective fault current, I_{pf} (?) 1.13 kA External loop Impedance, Z_s (?) -27 Ω

Supply Protective Device BS 1361 Type II Nominal Current Rating 60 A

Other Sources of Supply

8 Particulars of installation referred to in this certificate

Means of Earthing Distributor's facility Installation earth electrode

Details of installation Earth Electrode (where applicable) Type (e.g. rod(s), tape etc) —

Location — Electrode resistance to earth — Ω

Maximum demand (Load) 48 A

Main Protective Conductors	Material	Csa (mm ²)	Verified (connection / continuity)		
Earthing Conductor	Cu	16	<input checked="" type="checkbox"/>	Water installation pipes	<input checked="" type="checkbox"/> Structural steel
Protective Bonding Conductor	Cu	10	<input checked="" type="checkbox"/>	Gas installation pipes	<input checked="" type="checkbox"/> Lightning protection
Main Supply Conductor				Oil installation pipes	<input type="checkbox"/> Other

Main Switch / Switch-Fuse / Circuit Breaker / RCD

Location CONSUMER BS(EN) 60947 No. of Poles 2 Current Rating 100 A

Fuse/device rating or setting 100 A Voltage rating 230 V

If RCD main switch: Rated residual operating current I_{Δn} = 30 mA Rated time delay 21 ms

Measured operating trip time 27 ms (at I_{Δn})

Comments on existing installation (In the case of addition or alteration see Section 633)

NONE.

(For additions or alterations) cables concealed within trunking and conduits, or cables or conduits concealed under floors, in roof spaces and generally within the fabric of the building or underground may not have been inspected. Schedule of Test Results attached Schedule of Inspections attached

