



ELECTRICAL INSTALLATION CERTIFICATE
CERTIFICATE No: EICS-20230821142002

This is to certify that the electrical installation at the following address complies with the requirements of BS7671:2018+A2:2022 (18th Edition)

46 Crombie Avenue
York
YO30 6DN

The following work was carried out at the address above

Alterations to ground floor for new layout. New CCU installed in kitchen for new extension. New SWA feed installed for garage power. New CCU installed in garage

This Certificate deems the installation to be in the following condition:

SATISFACTORY

Company issuing this Certificate

Rollinson Electrical
75 North Moor Road, Huntington
York
North Yorkshire
YO32 9QN
07843752230
dean@rollinsonelectrical.co.uk
CPS Enrolment No: Napit 32715

Issued on
18/08/2023

Inspected by
Dean Rollinson

Reviewed by
Dean Rollinson

Recommended re-test

**5 Years from
date of issue**

Certificate generated by electraform® certification software 2023 | www.electraform.co.uk

SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

Earthing arrangements		Number and type of live conductors			Nature of supply parameters				Supply Protective Device		
TN-S	<input checked="" type="checkbox"/>	AC	<input checked="" type="checkbox"/>	DC	<input type="checkbox"/>	Nominal voltage - U	NA V	U _o	230 V	BS(EN)	1361-II
TN-C-S	<input type="checkbox"/>	1-phase (2 wire)	<input checked="" type="checkbox"/>	1-phase (3 wire)	<input type="checkbox"/>	2 pole	<input type="checkbox"/>	Nominal frequency - f	50 Hz	No of supplies	1
TN-C	<input type="checkbox"/>	2-phase (3 wire)	<input type="checkbox"/>	3 pole	<input type="checkbox"/>	PFC - Ipf	1.65 kA	Supply polarity confirmed	<input checked="" type="checkbox"/>	Short circuit capacity (kA)	33
TT	<input type="checkbox"/>	3-phase (3 wire)	<input type="checkbox"/>	3-phase (4 wire)	<input type="checkbox"/>	Other	<input type="checkbox"/>	Earth loop impedance - Z _e	0.14 Ω	Maximum demand	80 A
IT	<input type="checkbox"/>									Rated current (A)	LIM

PARTICULARS OF INSTALLATION REFERRED TO IN THIS REPORT

Means of earthing	Details of installation earth electrode (where applicable)				
Distributor's facility	<input checked="" type="checkbox"/>	Type: eg rod, tape	N/A	Resistance to earth	N/A Ω
Earth electrode		Location	N/A	Method of measurement	N/A

Main switch / switch fuse /circuit breaker / RCD				Earthing conductor		Main protective bonding conductors		Bonding of extraneous conductive parts			
Type BS(EN)	60947-3	Voltage rating	230 V	Conductor material	Copper	Conductor material	Copper	Water	<input checked="" type="checkbox"/>	Gas	<input checked="" type="checkbox"/>
No of poles	2	Rated current - I _n	100 A	Conductor csa (mm ²)	16	Conductor csa (mm ²)	10	Oil	-	Structural steel	-
Conductor material	Copper	Fuse/device rating or setting	NA A	Continuity check	<input checked="" type="checkbox"/>			Lightning protection	-	Other services	-
Conductor csa (mm ²)	25	RCD operating current, I _n	N/A mA								
RCD time delay (ms)	NA ms	RCD operating time at IΔn	NA ms								
						BONDING OUTCOMES		Pass <input checked="" type="checkbox"/>		Not applicable N/A	
										No access <input type="checkbox"/>	

Location of main switch

Right of CCU

SCHEDULE OF INSPECTIONS

Item No.	Description	Outcome	Item No.	Description	Outcome
1.0	Condition of consumer's intake equipment (Visual inspection only)	<input checked="" type="checkbox"/>	8.0	Circuits (Distribution and final)	<input checked="" type="checkbox"/>
2.0	Parallel or switched alternative sources of supply	N/A	9.0	Isolation and switching	<input checked="" type="checkbox"/>
3.0	Protective measure: Automatic disconnection of supply	<input checked="" type="checkbox"/>	10.0	Current using equipment (permanently connected)	<input checked="" type="checkbox"/>
4.0	Basic protection	<input checked="" type="checkbox"/>	11.0	Identification and notices	<input checked="" type="checkbox"/>
5.0	Protective measures other than ADS	<input checked="" type="checkbox"/>	12.0	Location(s) containing a bath or shower	<input checked="" type="checkbox"/>
6.0	Additional protection	<input checked="" type="checkbox"/>	13.0	Other special installations or locations	<input checked="" type="checkbox"/>
7.0	Distribution equipment	<input checked="" type="checkbox"/>	14.0	Prosumer's low voltage electrical installation(s)	N/A

DB-1 - Front entrance - (Lewden) (12 ways)

Applies in every case				Characteristics at this board							
DB name	DB-1	Supplied from	Origin	Supply polarity confirmed		<input checked="" type="checkbox"/>					
Location	Front entrance	No of circuits	12	No of phases	1	Phase sequence confirmed <input checked="" type="checkbox"/>					
SPD Details		Type T1	Type T2 <input checked="" type="checkbox"/>	Type T3	SPD Operation status confirmed <input checked="" type="checkbox"/>						
Overcurrent protective device for the supply circuit				Measurements at this board							
BS(EN)	1361-II	Rating (A)	LIM	Voltage Rating (V)	-	Zs (Ω)	0.14	Ipf (kA)	1.65	IΔn (ms)	N/A

CIRCUIT DETAILS

Cct No	Designation	No of points	Wiring type	Ref method	Conductors			Overcurrent devices					RCD	
					Live (mm ²)	cpc (mm ²)	Dis time (s)	BS(EN)	Rating (A)	Short circuit (kA)	Voltage Rating (V)	Max Zs (Ω)	RCD type	IΔn (mA)
1	CCU 2 Kitchen	1	F	C	16	16	0.4	60898-B	63	6	230	0.69	-	-
2	Sockets ground floor	12	A	100	2.5	1	0.4	62606-AFDD	20	6	230	2.19	A	30
3	Sockets first floor	12	A	100	2.5	1	0.4	62606-AFDD	32	6	230	1.37	A	30
4	Spur here	1	A	100	2.5	1	0.4	61009-B	16	6	230	2.73	A	30
5	Lights ground floor and smokes	18	A	100	1	1	0.4	61009-B	6	6	230	7.28	A	30
6	Lights upstairs	20	A	100	1	1	0.4	61009-B	6	6	230	7.28	A	30
7	Spare	-	-	-	-	-	-	-	-	-	-	-	-	-
8	Spare	-	-	-	-	-	-	-	-	-	-	-	-	-
9	Spare	-	-	-	-	-	-	-	-	-	1	-	-	AC
10	Spare	-	-	-	-	-	-	-	-	-	-	-	-	-
11	Surge mcb	1	A	C	6	6	0.4	60898-B	32	6	230	1.37	-	-
12	Surge	1	A	C	6	6	0.4	62305-SPD	32	6	230	0.34	-	-

TEST RESULTS DB-1 - Front entrance - (Lewden 12 ways)

Cct No	Designation	Ring final circuits (measured end to end)			At least one column to be completed		Insulation resistance			Polarity	Meas Zs (Ω)	Meas kA	RCD		AFDD	Circuit vulnerable to test
		(r1) (Ω)	(rn) (Ω)	(r2) (Ω)	R1+R2 (Ω)	R2 (Ω)	IR Test voltage (V)	L-L (M Ω)	L-E (M Ω)				RCD at I Δ n (ms)	RCD Test button	AFDD Test button	
1	CCU 2 Kitchen	-	-	-	-	-	500	999	999	✓	0.16	-	NA	N/A	N/A	Yes
2	Sockets ground floor	-	-	-	0.42	-	500	999	999	✓	1.05	-	24.5	✓	✓	Yes
3	Sockets first floor	0.76	0.76	1.71	0.62	-	500	999	999	✓	0.76	-	27.8	✓	✓	Yes
4	Spur here	-	-	-	0.10	-	500	999	999	✓	0.24	-	29.0	✓	N/A	Yes
5	Lights ground floor and smokes	-	-	-	1.92	-	500	999	999	✓	2.06	-	30.8	✓	N/A	Yes
6	Lights upstairs	-	-	-	0.92	-	500	999	999	✓	1.06	-	29.3	✓	N/A	Yes
7	Spare	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
8	Spare	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
9	Spare	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
10	Spare	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
11	Surge mcb	-	-	-	0.01	-	500	999	999	✓	0.15	-	NA	N/A	N/A	Yes
12	Surge	-	-	-	0.01	-	500	999	999	✓	0.15	-	NA	N/A	N/A	Yes

ENGINEER AND TEST INSTRUMENTS

Multifunction

102111692

Continuity

-

Insulation resistance

-

EFLI Tester

-

RCD tester

-

Tested by (Capitals)

Dean Rollinson

Signature



Date

18/08/2023

Certificate produced by electroform based on the MODEL FORM from BS7671:2018+A2:2022 (18th Edition)

DB-2 - Kitchen cupboard - (Fusebox) (11 ways)

Applies in every case			Applies when the board is not connected to the origin			Characteristics at this board					
DB name	<input type="text" value="DB-2"/>		Supplied from	<input type="text" value="CCU 1 Circuit 1"/>		Supply polarity confirmed	<input checked="" type="checkbox"/>				
Location	<input type="text" value="Kitchen cupboard"/>		No of circuits	<input type="text" value="11"/>	No of phases	<input type="text" value="1"/>	Phase sequence confirmed	<input checked="" type="checkbox"/>			
SPD Details	Type T1	Type T2 <input checked="" type="checkbox"/>	Type T3	SPD Operation status confirmed <input checked="" type="checkbox"/>							
Overcurrent protective device for the supply circuit					Measurements at this board						
BS(EN)	<input type="text" value="60898-B"/>	Rating (A)	<input type="text" value="63"/>	Voltage Rating (V)	<input type="text" value="230"/>	Zs (Ω)	<input type="text" value="0.16"/>	Ipf (kA)	<input type="text" value="1.44"/>	I Δ n (ms)	<input type="text" value="N/A"/>

CIRCUIT DETAILS

Cct No	Designation	No of points	Wiring type	Ref method	Conductors			Overcurrent devices					RCD	
					Live (mm ²)	cpc (mm ²)	Dis time (s)	BS(EN)	Rating (A)	Short circuit (kA)	Voltage Rating (V)	Max Zs (Ω)	RCD type	I Δ n (mA)
1	Surge	1	A	C	6	6	0.4	62305-SPD	32	6	230	1.37	-	-
2	Spare	-	-	-	-	-	-	-	-	-	-	-	-	-
3	Spare	-	-	-	-	-	-	-	-	-	-	-	-	-
4	Spare	-	-	-	-	-	-	-	-	-	-	-	-	-
5	Garage	1	F	D	6	6	0.4	60898-B	32	6	230	1.37	-	-
6	Sockets kitchen	7	A	100	2.5	1.5	0.4	62606-AFDD	32	6	230	1.37	A	30
7	Hob left	1	A	100	6	2.5	0.4	61009-B	32	6	230	1.37	A	30
8	Hob right	1	A	100	6	2.5	0.4	61009-B	32	6	230	1.37	A	30
9	Cooker right	1	A	100	2.5	1.5	0.4	61009-B	16	6	230	2.73	A	30
10	Cooker light	1	A	100	2.5	1.5	0.4	61009-B	16	6	230	2.73	A	30
11	Lights and smoke	7	A	100	1	1	0.4	61009-B	6	6	230	7.28	A	30

TEST RESULTS DB-2 - Kitchen cupboard - (Fusebox 11 ways)

Cct No	Designation	Ring final circuits (measured end to end)			At least one column to be completed		Insulation resistance			Polarity	Meas Zs (Ω)	Meas kA	RCD		AFDD	Circuit vulnerable to test
		(r1) (Ω)	(rn) (Ω)	(r2) (Ω)	R1+R2 (Ω)	R2 (Ω)	IR Test voltage (V)	L-L (M Ω)	L-E (M Ω)				RCD at I Δ n (ms)	RCD Test button	AFDD Test button	
1	Surge	-	-	-	0.01	-	500	999	999	✓	0.17	-	NA	N/A	N/A	Yes
2	Spare	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
3	Spare	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
4	Spare	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
5	Garage	-	-	-	0.09	-	500	999	999	✓	0.28	-	NA	N/A	N/A	Yes
6	Sockets kitchen	0.27	0.27	0.33	0.15	-	500	999	999	✓	0.31	-	28.5	✓	✓	Yes
7	Hob left	-	-	-	0.05	-	500	999	999	✓	0.21	-	29.1	✓	N/A	Yes
8	Hob right	-	-	-	0.04	-	500	999	999	✓	0.20	-	28.9	✓	N/A	Yes
9	Cooker right	-	-	-	0.05	-	500	999	999	✓	0.21	-	30.3	✓	N/A	Yes
10	Cooker light	-	-	-	0.09	-	500	999	999	✓	0.25	-	30.3	✓	N/A	Yes
11	Lights and smoke	-	-	-	0.86	-	500	999	999	✓	1.02	-	28.8	✓	N/A	Yes

ENGINEER AND TEST INSTRUMENTS

Multifunction

102111692

Continuity

-

Insulation resistance

-

EFLI Tester

-

RCD tester

-

Tested by (Capitals)

Dean Rollinson

Signature



Date

18/08/2023

Certificate produced by electroform based on the MODEL FORM from BS7671:2018+A2:2022 (18th Edition)

DB-3 - Garage entrance - (Fusebox) (8 ways)

Applies in every case			Applies when the board is not connected to the origin			Characteristics at this board					
DB name	<input type="text" value="DB-3"/>		Supplied from	<input type="text" value="Kitchen CCU circuit 5"/>		Supply polarity confirmed	<input checked="" type="checkbox"/>				
Location	<input type="text" value="Garage entrance"/>		No of circuits	<input type="text" value="8"/>	No of phases	<input type="text" value="1"/>	Phase sequence confirmed	<input checked="" type="checkbox"/>			
SPD Details		Type T1	Type T2	<input checked="" type="checkbox"/>	Type T3	SPD Operation status confirmed		<input checked="" type="checkbox"/>			
Overcurrent protective device for the supply circuit					Measurements at this board						
BS(EN)	<input type="text" value="60898-B"/>	Rating (A)	<input type="text" value="32"/>	Voltage Rating (V)	<input type="text" value="230"/>	Zs (Ω)	<input type="text" value="0.28"/>	Ipf (kA)	<input type="text" value="-"/>	IΔn (ms)	<input type="text" value="-"/>


CIRCUIT DETAILS

Cct No	Designation	No of points	Wiring type	Ref method	Conductors			Overcurrent devices					RCD	
					Live (mm ²)	cpc (mm ²)	Dis time (s)	BS(EN)	Rating (A)	Short circuit (kA)	Voltage Rating (V)	Max Zs (Ω)	RCD type	IΔn (mA)
1	Sockets	9	C	B	2.5	1.5	0.4	61009-B	32	6	230	1.37	A	30
2	20A socket left	1	C	B	2.5	1.5	0.4	61009-B	20	6	230	2.19	A	30
3	20A socket back	1	C	B	2.5	1.5	0.4	61009-B	20	6	230	2.19	A	30
4	Alarm/Data	2	A	B	2.5	1.5	0.4	61009-B	16	6	230	2.73	A	30
5	Lights	8	A	100	1	1	0.4	61009-B	6	6	230	7.28	A	30
6	Spare	-	-	-	-	-	-	-	-	-	-	-	-	-
7	Spare	-	-	-	-	-	-	-	-	-	-	-	-	-
8	Spare	-	-	-	-	-	-	-	-	-	-	-	-	-

TEST RESULTS DB-3 - Garage entrance - (Fusebox 8 ways)

Cct No	Designation	Ring final circuits (measured end to end)			At least one column to be completed		Insulation resistance			Polarity	Meas Zs (Ω)	Meas kA	RCD		AFDD	Circuit vulnerable to test
		(r1) (Ω)	(rn) (Ω)	(r2) (Ω)	R1+R2 (Ω)	R2 (Ω)	IR Test voltage (V)	L-L (MΩ)	L-E (MΩ)				RCD at IΔn (ms)	RCD Test button	AFDD Test button	
1	Sockets	0.48	0.48	0.80	0.32	-	500	999	999	✓	0.60	-	29.1	✓	N/A	Yes
2	20A socket left	-	-	-	0.12	-	500	999	999	✓	0.40	-	28.7	✓	N/A	Yes
3	20A socket back	-	-	-	0.16	-	500	999	999	✓	0.44	-	28.7	✓	N/A	Yes
4	Alarm/Data	-	-	-	0.03	-	500	999	999	✓	0.31	-	29.1	✓	N/A	Yes
5	Lights	-	-	-	0.69	-	500	999	999	✓	0.97	-	29.1	✓	N/A	Yes
6	Spare	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
7	Spare	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
8	Spare	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-

ENGINEER AND TEST INSTRUMENTS

Multifunction 102111692	Continuity -	Insulation resistance -	EFLI Tester -	RCD tester -
Tested by (Capitals) Dean Rollinson	Signature 		Date 18/08/2023	

Certificate produced by electroform based on the MODEL FORM from BS7671:2018+A2:2022 (18th Edition)

ELECTRICAL INSTALLATION CERTIFICATE GUIDANCE FOR RECIPIENTS

This CERTIFICATE is an important and valuable document which should be retained for future reference.

- This safety Certificate has been issued to confirm that the electrical installation work to which it relates has been designed, constructed, inspected and tested in accordance with BS 7671.
- You should have received a Certificate without watermarks and the company should have retained a duplicate. If you were the person ordering the work, but not the owner of the installation, you should pass this Certificate, or a full copy of it including the schedules, immediately to the owner.
- This Certificate should be retained in a safe place and be shown to any person inspecting or undertaking further work on the electrical installation in the future. If you later vacate the property, this Certificate will demonstrate to the new owner that the electrical installation complied with the requirements of BS 7671 at the time the Certificate was issued. The Construction (Design and Management) Regulations require that, for a project covered by those Regulations, a copy of this Certificate, together with schedules, is included in the project health and safety documentation.
- For safety reasons, the electrical installation will need to be inspected at appropriate intervals by a skilled person or persons, competent in such work. The maximum time interval recommended before the next inspection is stated on Page 1 under "NEXT INSPECTION".
- This Certificate is intended to be issued only for a new electrical installation or for new work associated with an alteration or an addition to an existing installation. It should not have been issued for the inspection and testing of an existing electrical installation. An "Electrical Installation Condition Report (EICR)" should have been issued for such an inspection.
- This Certificate is only valid if the Schedule of Inspections has been completed to confirm that all relevant inspections have been carried out and where accompanied by Schedule(s) of Circuit Details and Test Results.
- Where the installation includes a residual current device (RCD) it should be tested six-monthly by pressing the button marked 'T' or 'Test'. The device should switch off the supply and should then be switched on to restore the supply. If the device does not switch off the supply when the button is pressed, seek expert advice. **For safety reasons it is important this instruction is followed.**
- Where the installation includes an arc fault detection device (AFDD) having a manual test facility it should be tested six-monthly by pressing the test button. Where an AFDD has both a test button and automatic test function, manufacturers instructions should be followed with respect to test button operation.
- Where the installation includes a surge protection device (SPD) the status indicator should be checked to confirm it is in operational condition in accordance with manufacturers information. If the indication shows the device is not operational, seek expert advice. **For safety reasons it is important this instruction is followed.**
- Where the installation includes alternative or additional sources of supply, warning notices should be found at the origin or meter position or, if remote from the origin, at the consumer unit or distribution board and at all points of isolation of all sources of supply.

CODES FOR TYPE OF WIRING								
A	B	C	D	E	F	G	H	O (Other)
Thermoplastic insulated/sheathed cables	Thermoplastic cables in metallic conduit	Thermoplastic cables in non-metallic conduit	Thermoplastic cables in metallic trunking	Thermoplastic cables in non-metallic trunking	Thermoplastic / SWA cables	Thermosetting / SWA cables	MICC cables	Other cable types not listed here
FP	TR	HT	SY	YY	CY	VIR		
FP 200 - standard fire resistant cable	Tri-rated - BS 6231 high temperature - flame retardant cable	Hi Tuff - waterproof with a tough PVC sheathing for outdoor use	SY cable - flexible instrumentation cable with a galvanised steel wire braid	YY cable - flexible instrumentation cable	CY cable - flexible instrumentation cable with a tinned copper wire braid and a PETP separator	VIR - Vulcanised Indian Rubber cable - no longer manufactured		

Certificate produced by electroform based on the MODEL FORM from BS7671:2018+A2:2022 (18th Edition)