



## ELECTRICAL INSTALLATION CERTIFICATE

CERTIFICATE No: EICS-20220901135701

This is to certify that the electrical installation at the following address complies with the requirements of BS7671:2018+A2:2022 (18th Edition)

146 Lawrence street  
York  
YO10 3EB

The following work was carried out at the address above

*Replace consumer unit.*

This Certificate deems the installation to be in the following condition:

**SATISFACTORY**

Company issuing this Certificate

Mad About Electrics  
Unit 2 Pyramid Court, Rosetta Way  
York  
YO26 5NB  
01904787983  
info@madaboutelectrics.com  
CPS Enrolment No: 50 1089 000

Issued on

14/09/2022

Inspected by  
Luke Livingstone

Reviewed by  
Zac Loveley

Recommended re-test

**5 Years from  
date of issue**

Certificate generated by electraform® 2022 | www.electraform.co.uk

DETAILS OF THE CLIENT

DETAILS OF THE INSTALLATION

David Blackwell  
254 Tadcaster Road  
York  
North Yorkshire  
YO24 1ES

☎: -  
✉: -  
👤: David Blackwell

-  
146 Lawrence street  
York  
-  
YO10 3EB

☎: -  
✉: -  
👤: -

EXTENT OF INSTALLATION COVERED BY THIS CERTIFICATE

Extent of the electrical installation covered by this certificate

Replace consumer unit.

Description of premises

- ☒ Residential  
☐ Commercial  
☐ Industrial  
☐ Other

-

Installation is

- ☐ New  
☐ An addition  
☒ An alteration

DETAILS OF DEPARTURES AND PERMITTED EXCEPTIONS

Details of departures and permitted exceptions BS 7671 (Regs 120.3, 133.5, 411.3.3). ☐ Risk assessment included.

N/A

COMMENTS ON EXISTING INSTALLATION (in the case of an addition or alteration see Regulation 644.1.2)

Installation is in poor condition, showing lots of signs of deterioration and in need of modernization. All circuits are electrically sound however further investigation is needed to determine underlying issues with the wiring.

FOR DESIGN, CONSTRUCTION AND INSPECTION AND TESTING

**Mad About Electrics**  
Unit 2 Pyramid Court, Rosetta Way  
York  
-  
YO26 5NB

☎: 01904787983  
✉: info@madaboutelectrics.com  
🌐: www.madaboutelectrics.com  
Registration no: 50 1089 000

I/We, being the person(s) responsible for the design, construction and inspection and testing of the electrical installation (as indicated by my/our signatures below), particulars of which are described above, having exercised reasonable skill and care when carrying out the design, construction and inspection and testing, hereby **CERTIFY** that the work for which I have been responsible is to the best of my knowledge and belief in accordance with BS7671:2018+A2:2022 (18th Edition) as amended except for the departures, if any, detailed as follows.

Inspected and tested by

Name

Luke Livingstone

Signature

*[Signature]*

Position

Electrician

Date

01/09/2022

Certificate authorised by

Name

Zac Loveley

Signature

*[Signature]*

Position

Electrician

Date

14/09/2022

NEXT INSPECTION

I, recommend that this installation is further inspected and tested in

5 Years

SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

Earthing arrangements		Number and type of live conductors				Nature of supply parameters				Supply Protective Device	
TN-S	<input checked="" type="checkbox"/>	AC	<input checked="" type="checkbox"/>	DC	<input type="checkbox"/>	Nominal voltage - U	440 V	Uo	230 V	BS(EN)	1361-II
TN-C-S	<input type="checkbox"/>	1-phase (2 wire)	<input checked="" type="checkbox"/>	1-phase (3 wire)	<input type="checkbox"/>	Nominal frequency - f	50 Hz	No of supplies	1	Type	II
TN-C	<input type="checkbox"/>	2-phase (3 wire)	<input type="checkbox"/>		<input type="checkbox"/>	PFC - Ip <sub>f</sub>	1.92 kA	Supply polarity confirmed	<input checked="" type="checkbox"/>	Short circuit capacity (kA)	33
TT	<input type="checkbox"/>	3-phase (3 wire)	<input type="checkbox"/>	3-phase (4 wire)	<input type="checkbox"/>	Earth loop impedance - Z <sub>e</sub>	0.12 Ω	Maximum demand	55 A	Rated current (A)	100
IT	<input type="checkbox"/>										

PARTICULARS OF INSTALLATION REFERRED TO IN THIS REPORT

Means of earthing		Details of installation earth electrode (where applicable)			
Distributor's facility	<input checked="" type="checkbox"/>	Type: eg rod, tape	N/A	Resistance to earth	N/A Ω
Earth electrode		Location	N/A	Method of measurement	N/A

  

Main switch / switch fuse /circuit breaker / RCD				Earthing conductor		Main protective bonding conductors		Bonding of extraneous conductive parts	
Type BS(EN)	60947-3	Voltage rating	230 V	Conductor material	Copper	Conductor material	Copper	Water	<input checked="" type="checkbox"/>
No of poles	2	Rated current - I <sub>n</sub>	100 A	Conductor csa (mm <sup>2</sup> )	16	Conductor csa (mm <sup>2</sup> )	16	Oil	N/A
Conductor material	Copper	Fuse/device rating or setting	N/A A	Continuity check	<input checked="" type="checkbox"/>			Structural steel	N/A
Conductor csa (mm <sup>2</sup> )	25	RCD operating current, I <sub>Δn</sub>	N/A mA					Lightning protection	N/A
RCD time delay (ms)	N/A ms	RCD operating time at I <sub>Δn</sub>	N/A ms					Other services	-

Bonding locations and measurements can be found on page ADDITIONAL BONDING INFORMATION at the end of this certificate.

BONDING OUTCOMES	Pass	Not applicable	No access
	<input checked="" type="checkbox"/>	N/A	<input type="checkbox"/>

  

**Location of main switch**

Hall

SCHEDULE OF INSPECTIONS

Item No.	Description	Outcome	Item No.	Description	Outcome
1.0	Condition of consumer's intake equipment (Visual inspection only)	<input checked="" type="checkbox"/>	8.0	Circuits (Distribution and final)	<input checked="" type="checkbox"/>
2.0	Parallel or switched alternative sources of supply	N/A	9.0	Isolation and switching	<input checked="" type="checkbox"/>
3.0	Protective measure: Automatic disconnection of supply	<input checked="" type="checkbox"/>	10.0	Current using equipment (permanently connected)	<input checked="" type="checkbox"/>
4.0	Basic protection	<input checked="" type="checkbox"/>	11.0	Identification and notices	<input checked="" type="checkbox"/>
5.0	Protective measures other than ADS	<input checked="" type="checkbox"/>	12.0	Location(s) containing a bath or shower	<input checked="" type="checkbox"/>
6.0	Additional protection	<input checked="" type="checkbox"/>	13.0	Other special installations or locations	N/A
7.0	Distribution equipment	<input checked="" type="checkbox"/>	14.0	Prosumer's low voltage electrical installation(s)	<input checked="" type="checkbox"/>

## DB-1 - Hall - (Lewden) (13 ways)

Applies in every case				Characteristics at this board			
DB name	DB-1			Supplied from	Origin		Supply polarity confirmed <input checked="" type="checkbox"/>
Location	Hall			No of circuits	13	No of phases	1
						Phase sequence confirmed	N/A

  

SPD Details		Type T1	Type T2	Type T3	SPD Operation status confirmed	
<b>Overcurrent protective device for the supply circuit</b>						
BS(EN)	1361-II	Rating (A)	100	Voltage Rating (V)	230	

  

Measurements at this board					
Zs (Ω)	0.11	Ipf (kA)	0.21	IΔn (ms)	N/A

## CIRCUIT DETAILS

Cct No	Designation	No of points	Wiring type	Ref method	Conductors			Overcurrent devices						RCD
					Live (mm <sup>2</sup> )	cpc (mm <sup>2</sup> )	Dis time (s)	BS(EN)	Rating (A)	Short circuit (kA)	Voltage Rating (V)	Max Zs (Ω)	IΔn (mA)	
1	Shower	1	A	C	10	6	0.4	61009-B	40	6	230	1.09	30	
2	Cooker	1	A	C	6	2.5	0.4	61009-B	32	6	230	1.37	30	
3	Spare	-	-	-	-	-	-	-	-	-	-	-	-	
4	Downstairs Sockets	10	A	C	2.5	1.5	0.4	61009-B	32	6	230	1.37	30	
5	Upstairs Sockets	13	A	C	2.5	1.5	0.4	61009-B	16	6	230	2.73	30	
6	Unknown	-	A	C	2.5	1.5	0.4	61009-B	16	6	230	2.73	30	
7	Downstairs Lights	12	A	C	1	1	0.4	61009-B	6	6	230	7.28	30	
8	Upstairs Lights	9	A	C	1	1	0.4	61009-B	6	6	230	7.28	30	
9	Downstairs Sockets	5	A	C	2.5	1.5	0.4	61009-B	32	6	230	1.37	30	
10	Kitchen Sockets	14	A	C	2.5	1.5	0.4	61009-B	32	6	230	1.37	30	
11	Spare	-	-	-	-	-	-	-	-	-	-	-	-	
12	Spare	-	-	-	-	-	-	-	-	-	-	-	-	
13	Spare	-	-	-	-	-	-	-	-	-	-	-	-	

## TEST RESULTS DB-1 - Hall - (Lewden 13 ways)

		Ring final circuits (measured end to end)			At least one column to be completed		Insulation resistance						RCD		AFDD	
Cct No	Designation	(r1) (Ω)	(rn) (Ω)	(r2) (Ω)	R1+R2 (Ω)	R2 (Ω)	IR Test voltage (V)	L-L (MΩ)	L-E (MΩ)	Polarity	Meas Zs (Ω)	Meas kA	RCD at IΔn (ms)	RCD Test button	AFDD Test button	Circuit vulnerable to test
1	Shower	-	-	-	0.22	-	500	>999	>999	✓	0.34	-	29.2	✓	N/A	No
2	Cooker	-	-	-	0.17	-	500	>999	>999	✓	0.29	-	48.9	✓	N/A	No
3	Spare	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
4	Downstairs Sockets	0.25	0.25	0.39	0.14	-	500	>999	>999	✓	1.12	-	48.9	✓	N/A	No
5	Upstairs Sockets	-	-	-	0.30	-	500	>999	>999	✓	0.39	-	28.8	✓	N/A	No
6	Unknown	-	-	-	-	-	500	-	>999	N/A	-	-	28.9	✓	N/A	No
7	Downstairs Lights	-	-	-	0.96	-	500	>999	>999	✓	1.08	-	28.9	✓	N/A	No
8	Upstairs Lights	-	-	-	0.83	-	500	>999	>999	✓	0.94	-	29.0	✓	N/A	No
9	Downstairs Sockets	0.21	0.21	0.36	0.11	-	500	>999	>999	✓	0.62	-	39.0	✓	N/A	No
10	Kitchen Sockets	0.82	0.83	1.37	0.35	-	500	>999	>999	✓	0.91	-	48.9	✓	N/A	No
11	Spare	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
12	Spare	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
13	Spare	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-

## ENGINEER AND TEST INSTRUMENTS

## Multifunction

101309512

## Continuity

-

## Insulation resistance

-

## EFLI Tester

-

## RCD tester

-

## Tested by (Capitals)

Luke Livingstone

## Signature



## Date

01/09/2022

Certificate produced by electroform based on the MODEL FORM from BS7671:2018+A2:2022 (18th Edition)

## ADDITIONAL BONDING INFORMATION

**Water bond details**

Water bond size

 mm<sup>2</sup>

Water bond measurement

 Ω

Water bond location

Additional notes

**Gas bond details**

Gas bond size

 mm<sup>2</sup>

Gas bond measurement

 Ω

Gas bond location

Additional notes

**Oil bond details**

Oil bond size

 mm<sup>2</sup>

Oil bond measurement

 Ω

Oil bond location

Additional notes

**Structural steel bond details**

Steel bond size

 mm<sup>2</sup>

Steel bond measurement

 Ω

Steel bond location

Additional notes

**Lightning conductor bond details**

Lightning conductor size

 mm<sup>2</sup>

Lightning conductor measurement

 Ω

Lightning conductor location(s)

Additional notes

**Other bond details**

Other bonding conductor size

 mm<sup>2</sup>

Bonding conductor measurement

 Ω

Other bonding conductor location(s)

Additional notes

# ELECTRICAL INSTALLATION CERTIFICATE GUIDANCE FOR RECIPIENTS

This CERTIFICATE is an important and valuable document which should be retained for future reference.

- This safety Certificate has been issued to confirm that the electrical installation work to which it relates has been designed, constructed, inspected and tested in accordance with BS 7671.
- You should have received a Certificate without watermarks and the company should have retained a duplicate. If you were the person ordering the work, but not the owner of the installation, you should pass this Certificate, or a full copy of it including the schedules, immediately to the owner.
- This Certificate should be retained in a safe place and be shown to any person inspecting or undertaking further work on the electrical installation in the future. If you later vacate the property, this Certificate will demonstrate to the new owner that the electrical installation complied with the requirements of BS 7671 at the time the Certificate was issued. The Construction (Design and Management) Regulations require that, for a project covered by those Regulations, a copy of this Certificate, together with schedules, is included in the project health and safety documentation.
- For safety reasons, the electrical installation will need to be inspected at appropriate intervals by a skilled person or persons, competent in such work. The maximum time interval recommended before the next inspection is stated on Page 1 under "NEXT INSPECTION".
- This Certificate is intended to be issued only for a new electrical installation or for new work associated with an alteration or an addition to an existing installation. It should not have been issued for the inspection and testing of an existing electrical installation. An "Electrical Installation Condition Report (EICR)" should have been issued for such an inspection.
- This Certificate is only valid if the Schedule of Inspections has been completed to confirm that all relevant inspections have been carried out and where accompanied by Schedule(s) of Circuit Details and Test Results.
- Where the installation includes a residual current device (RCD) it should be tested six-monthly by pressing the button marked 'T' or 'Test'. The device should switch off the supply and should then be switched on to restore the supply. If the device does not switch off the supply when the button is pressed, seek expert advice. **For safety reasons it is important this instruction is followed.**
- Where the installation includes an arc fault detection device (AFDD) having a manual test facility it should be tested six-monthly by pressing the test button. Where an AFDD has both a test button and automatic test function, manufacturers instructions should be followed with respect to test button operation.
- Where the installation includes a surge protection device (SPD) the status indicator should be checked to confirm it is in operational condition in accordance with manufacturers information. If the indication shows the device is not operational, seek expert advice. **For safety reasons it is important this instruction is followed.**
- Where the installation includes alternative or additional sources of supply, warning notices should be found at the origin or meter position or, if remote from the origin, at the consumer unit or distribution board and at all points of isolation of all sources of supply.

## CODES FOR TYPE OF WIRING

A	B	C	D	E	F	G	H	O (Other)
Thermoplastic insulated/sheathed cables	Thermoplastic cables in metallic conduit	Thermoplastic cables in non-metallic conduit	Thermoplastic cables in metallic trunking	Thermoplastic cables in non-metallic trunking	Thermoplastic / SWA cables	Thermosetting / SWA cables	MICC cables	Other cable types not listed here
FP	TR	HT	SY	YY	CY	VIR		
FP 200 - standard fire resistant cable	Tri-rated - BS 6231 high temperature - flame retardant cable	Hi Tuff - waterproof with a tough PVC sheathing for outdoor use	SY cable - flexible instrumentation cable with a galvanised steel wire braid	YY cable - flexible instrumentation cable with a galvanised steel wire braid	CY cable - flexible instrumentation cable with a galvanised steel wire braid and a PETP separator	VIR - Vulcanised Indian Rubber cable - no longer manufactured		

Certificate produced by electroform based on the MODEL FORM from BS7671:2018+A2:2022 (18th Edition)