



ELECTRICAL INSTALLATION CERTIFICATE
CERTIFICATE No: EICS-20220809151532

This is to certify that the electrical installation at the following address complies with the requirements of BS7671:2018+A2:2022 (18th Edition)

11 Jupiter House
York
YO10 3UA

The following work was carried out at the address above

Replacement of DB1. Replacement of 4x downlights in bathroom

This Certificate deems the installation to be in the following condition:

SATISFACTORY

Company issuing this Certificate

Mad About Electrics
Unit 2 Pyramid Court, Rosetta Way
York
YO26 5NB
01904787983
info@madaboutelectrics.com
CPS Enrolment No: 50 1089 000

Issued on
10/08/2022

Inspected by
Luke Livingstone

Reviewed by
Tom Sewell

Recommended re-test

**5 Years from
date of issue**

Certificate generated by electraform® 2022 | www.electraform.co.uk

DETAILS OF THE CLIENT

DETAILS OF THE INSTALLATION

David Blackwell
254 Tadcaster Road
York
North Yorkshire
YO24 1ES

☎: -
📠: -
✉: David_blackwell@hotmail.com
👤: David Blackwell

-
11 Jupiter House
York
-
YO10 3UA

☎: -
📠: -
✉: -
👤: -

EXTENT OF INSTALLATION COVERED BY THIS CERTIFICATE

Extent of the electrical installation covered by this certificate

Replacement of DB1. Replacement of 4x downlights in bathroom

Description of premises

- Residential
- Commercial
- Industrial
- Other

-

Installation is

- New
- An addition
- An alteration

DETAILS OF DEPARTURES AND PERMITTED EXCEPTIONS

Details of departures and permitted exceptions BS 7671 (Regs 120.3, 133.5, 411.3.3). Risk assessment included.

N/A

COMMENTS ON EXISTING INSTALLATION (in the case of an addition or alteration see Regulation 644.1.2)

Electrical improvement works carried following recent EICR undertaken, Cert No. 20220727113421. Installation is in good condition with no obvious defects, all circuits are now protected by RCD. Both water and gas bonding is present.

FOR DESIGN, CONSTRUCTION AND INSPECTION AND TESTING

Mad About Electrics
Unit 2 Pyramid Court, Rosetta Way
York
-
YO26 5NB

☎: 01904787983
📠: -
✉: info@madaboutelectrics.com
🌐: www.madaboutelectrics.com
Registration no: 50 1089 000

I/We, being the person(s) responsible for the design, construction and inspection and testing of the electrical installation (as indicated by my/our signatures below), particulars of which are described above, having exercised reasonable skill and care when carrying out the design, construction and inspection and testing, hereby **CERTIFY** that the work for which I have been responsible is to the best of my knowledge and belief in accordance with BS7671:2018+A2:2022 (18th Edition) as amended except for the departures, if any, detailed as follows.

Inspected and tested by

Name: Luke Livingstone
Signature: 
Position: Electrician
Date: 09/08/2022

Certificate authorised by

Name: Tom Sewell
Signature: 
Position: Electrician
Date: 10/08/2022

NEXT INSPECTION

I, recommend that this installation is further inspected and tested in

SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

Earthing arrangements		Number and type of live conductors			Nature of supply parameters				Supply Protective Device		
TN-S	<input type="checkbox"/>	AC	<input checked="" type="checkbox"/>	DC	<input type="checkbox"/>	Nominal voltage - U	N/A V	U _o	230 V	BS(EN)	LIM
TN-C-S	<input type="checkbox"/>	1-phase (2 wire)	<input checked="" type="checkbox"/>	1-phase (3 wire)	<input type="checkbox"/>	2 pole	<input type="checkbox"/>	Nominal frequency - f	50 Hz	No of supplies	1
TN-C	<input type="checkbox"/>	2-phase (3 wire)	<input type="checkbox"/>	3 pole	<input type="checkbox"/>	PFC - I _{pf}	0.61 kA	Supply polarity confirmed	<input checked="" type="checkbox"/>	Short circuit capacity (kA)	LIM
TT	<input type="checkbox"/>	3-phase (3 wire)	<input type="checkbox"/>	3-phase (4 wire)	<input type="checkbox"/>	Other	<input type="checkbox"/>	Earth loop impedance - Z _e	0.16 Ω	Maximum demand	55 A
IT	<input type="checkbox"/>									Rated current (A)	LIM

PARTICULARS OF INSTALLATION REFERRED TO IN THIS REPORT

Means of earthing	Details of installation earth electrode (where applicable)			
Distributor's facility <input checked="" type="checkbox"/>	Type: eg rod, tape	N/A	Resistance to earth	N/A Ω
Earth electrode	Location	N/A	Method of measurement	N/A

Main switch / switch fuse / circuit breaker / RCD				Earthing conductor		Main protective bonding conductors		Bonding of extraneous conductive parts			
Type BS(EN)	LIM	Voltage rating	230 V	Conductor material	Copper	Conductor material	Copper	Water	<input checked="" type="checkbox"/>	Gas	<input checked="" type="checkbox"/>
No of poles	2	Rated current - I _n	LIM A	Conductor csa (mm ²)	LIM	Conductor csa (mm ²)	10	Oil	N/A	Structural steel	N/A
Conductor material	LIM	Fuse/device rating or setting	N/A A	Continuity check	<input checked="" type="checkbox"/>	Lightning protection	N/A	Other services	N/A		
Conductor csa (mm ²)	LIM	RCD operating current, I _n	N/A mA								
RCD time delay (ms)	N/A ms	RCD operating time at IΔn	N/A ms								
						BONDING OUTCOMES		Pass <input checked="" type="checkbox"/>		Not applicable N/A	
								No access <input type="checkbox"/>			

Location of main switch

Unable to gain access

SCHEDULE OF INSPECTIONS

Item No.	Description	Outcome	Item No.	Description	Outcome
1.0	Condition of consumer's intake equipment (Visual inspection only)	<input checked="" type="checkbox"/>	8.0	Circuits (Distribution and final)	<input checked="" type="checkbox"/>
2.0	Parallel or switched alternative sources of supply	N/A	9.0	Isolation and switching	<input checked="" type="checkbox"/>
3.0	Protective measure: Automatic disconnection of supply	<input checked="" type="checkbox"/>	10.0	Current using equipment (permanently connected)	<input checked="" type="checkbox"/>
4.0	Basic protection	<input checked="" type="checkbox"/>	11.0	Identification and notices	<input checked="" type="checkbox"/>
5.0	Protective measures other than ADS	<input checked="" type="checkbox"/>	12.0	Location(s) containing a bath or shower	<input checked="" type="checkbox"/>
6.0	Additional protection	<input checked="" type="checkbox"/>	13.0	Other special installations or locations	N/A
7.0	Distribution equipment	<input checked="" type="checkbox"/>	14.0	Prosumer's low voltage electrical installation(s)	<input checked="" type="checkbox"/>

DB-1 - Hallway cupboard - (Lewden) (10 ways)

Applies in every case				Characteristics at this board			
DB name	DB-1	Supplied from	Origin	Supply polarity confirmed		<input checked="" type="checkbox"/>	
Location	Hallway cupboard	No of circuits	10	No of phases	1	Phase sequence confirmed	
SPD Details		Type T1	<input checked="" type="checkbox"/>	Type T2		Type T3	
Overcurrent protective device for the supply circuit				Measurements at this board			
BS(EN)	LIM	Rating (A)	LIM	Voltage Rating (V)	230	Zs (Ω)	0.16
						Ipf (kA)	0.61
						IΔn (ms)	N/A
				SPD Operation status confirmed			
				<input checked="" type="checkbox"/>			

CIRCUIT DETAILS

Cct No	Designation	No of points	Wiring type	Ref method	Conductors			Overcurrent devices					RCD	
					Live (mm ²)	cpc (mm ²)	Dis time (s)	BS(EN)	Rating (A)	Short circuit (kA)	Voltage Rating (V)	Max Zs (Ω)	IΔn (mA)	
1	Cooker	1	A	C	6	2.5	0.4	61009-B	32	6	230	1.37	30	
2	Sockets	7	A	C	2.5	1.5	0.4	61009-B	32	6	230	1.37	30	
3	Sockets	10	A	C	2.5	1.5	0.4	61009-B	32	6	230	1.37	30	
4	Lights and Smokes	10	A	C	1	1	0.4	61009-B	6	6	230	7.28	30	
5	Lights	8	A	C	1	1	0.4	61009-B	6	6	230	7.28	30	
6	Spare	-	-	-	-	-	-	-	-	-	-	-	-	
7	Spare	-	-	-	-	-	-	-	-	-	-	-	-	
8	Spare	-	-	-	-	-	-	-	-	-	-	-	-	
9	Spare	-	-	-	-	-	-	-	-	-	-	-	-	
10	Spare	-	-	-	-	-	-	-	-	-	-	-	-	

TEST RESULTS DB-1 - Hallway cupboard - (Lewden 10 ways)

Cct No	Designation	Ring final circuits (measured end to end)			At least one column to be completed		Insulation resistance			Polarity	Meas Zs (Ω)	Meas kA	RCD		AFDD	Circuit vulnerable to test
		(r1) (Ω)	(rn) (Ω)	(r2) (Ω)	R1+R2 (Ω)	R2 (Ω)	IR Test voltage (V)	L-L (M Ω)	L-E (M Ω)				RCD at I Δ n (ms)	RCD Test button	AFDD Test button	
1	Cooker	-	-	-	0.03	-	500	>999	>999	✓	0.22	-	29.0	✓	N/A	No
2	Sockets	0.45	0.46	0.75	0.32	-	500	>999	>999	✓	0.75	-	28.5	✓	N/A	No
3	Sockets	0.56	0.57	0.85	0.34	-	500	>999	>999	✓	0.45	-	35.4	✓	N/A	No
4	Lights and Smokes	-	-	-	0.50	-	500	>999	>999	✓	0.69	-	29.1	✓	N/A	No
5	Lights	-	-	-	0.30	-	500	>999	>999	✓	0.50	-	28.7	✓	N/A	No
6	Spare	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
7	Spare	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
8	Spare	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
9	Spare	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
10	Spare	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-

ENGINEER AND TEST INSTRUMENTS

Multifunction

101309512

Continuity

-

Insulation resistance

-

EFLI Tester

-

RCD tester

-

Tested by (Capitals)

Luke Livingstone

Signature



Date

09/08/2022

Certificate produced by electroform based on the MODEL FORM from BS7671:2018+A2:2022 (18th Edition)

ELECTRICAL INSTALLATION CERTIFICATE GUIDANCE FOR RECIPIENTS

This CERTIFICATE is an important and valuable document which should be retained for future reference.

- This safety Certificate has been issued to confirm that the electrical installation work to which it relates has been designed, constructed, inspected and tested in accordance with BS 7671.
- You should have received a Certificate without watermarks and the company should have retained a duplicate. If you were the person ordering the work, but not the owner of the installation, you should pass this Certificate, or a full copy of it including the schedules, immediately to the owner.
- This Certificate should be retained in a safe place and be shown to any person inspecting or undertaking further work on the electrical installation in the future. If you later vacate the property, this Certificate will demonstrate to the new owner that the electrical installation complied with the requirements of BS 7671 at the time the Certificate was issued. The Construction (Design and Management) Regulations require that, for a project covered by those Regulations, a copy of this Certificate, together with schedules, is included in the project health and safety documentation.
- For safety reasons, the electrical installation will need to be inspected at appropriate intervals by a skilled person or persons, competent in such work. The maximum time interval recommended before the next inspection is stated on Page 1 under "NEXT INSPECTION".
- This Certificate is intended to be issued only for a new electrical installation or for new work associated with an alteration or an addition to an existing installation. It should not have been issued for the inspection and testing of an existing electrical installation. An "Electrical Installation Condition Report (EICR)" should have been issued for such an inspection.
- This Certificate is only valid if the Schedule of Inspections has been completed to confirm that all relevant inspections have been carried out and where accompanied by Schedule(s) of Circuit Details and Test Results.
- Where the installation includes a residual current device (RCD) it should be tested six-monthly by pressing the button marked 'T' or 'Test'. The device should switch off the supply and should then be switched on to restore the supply. If the device does not switch off the supply when the button is pressed, seek expert advice. **For safety reasons it is important this instruction is followed.**
- Where the installation includes an arc fault detection device (AFDD) having a manual test facility it should be tested six-monthly by pressing the test button. Where an AFDD has both a test button and automatic test function, manufacturers instructions should be followed with respect to test button operation.
- Where the installation includes a surge protection device (SPD) the status indicator should be checked to confirm it is in operational condition in accordance with manufacturers information. If the indication shows the device is not operational, seek expert advice. **For safety reasons it is important this instruction is followed.**
- Where the installation includes alternative or additional sources of supply, warning notices should be found at the origin or meter position or, if remote from the origin, at the consumer unit or distribution board and at all points of isolation of all sources of supply.

CODES FOR TYPE OF WIRING								
A	B	C	D	E	F	G	H	O (Other)
Thermoplastic insulated/sheathed cables	Thermoplastic cables in metallic conduit	Thermoplastic cables in non-metallic conduit	Thermoplastic cables in metallic trunking	Thermoplastic cables in non-metallic trunking	Thermoplastic / SWA cables	Thermosetting / SWA cables	MICC cables	Other cable types not listed here
FP	TR	HT	SY	YY	CY	VIR		
FP 200 - standard fire resistant cable	Tri-rated - BS 6231 high temperature - flame retardant cable	Hi Tuff - waterproof with a tough PVC sheathing for outdoor use	SY cable - flexible instrumentation cable with a galvanised steel wire braid	YY cable - flexible instrumentation cable with a galvanised steel wire braid	CY cable - flexible instrumentation cable with a galvanised steel wire braid and a PETP separator	VIR - Vulcanised Indian Rubber cable - no longer manufactured		

Certificate produced by electroform based on the MODEL FORM from BS7671:2018+A2:2022 (18th Edition)