



This certificate is not valid if the serial number has been defaced or altered

27866147

EICR18.2c

# ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018+A2:2022 - Requirements for Electrical Installations

Original (to the person ordering the work)

## PART 1 : DETAILS OF THE CONTRACTOR, CLIENT AND INSTALLATION

DETAILS OF THE CONTRACTOR		DETAILS OF THE CLIENT		DETAILS OF THE INSTALLATION	
Registration No. 501766000	Branch No. 000	Contractor Reference Number (CRM) N/A	Occupier Unknown	CPRE N/A	Address 15 Vanbrugh Drive, York, North Yorkshire
Trading Title: Advanced Electrical Services York Ltd		Name: Claire Dunford	Address: 7 Doe Park, York, North Yorkshire	Postcode: YO10 9HE	Tel No: N/A
Address: York Eco Business Centre, York Amy Johnson Way, York, North Yorkshire		Postcode: YO30 4UG	Tel No: N/A		
Postcode: YO30 4AG	Tel No: 01904479485				

## PART 2 : PURPOSE OF THE REPORT

Purpose for which this report is required:  
 Scheduled report prior to property being rented to comply with the Electrical safety standard in the private rental sector (England) regulations as amended

Date(s) when inspection and testing was carried out: 02/08/2023

Records available (BS13)  Previous inspection report available (BS13)  Previous report date: N/A

## PART 3 : SUMMARY OF THE CONDITION OF THE INSTALLATION

General condition of the installation (in terms of electrical safety): The installation appears to be in acceptable condition with regards to electrical safety. Accessories in good condition. Installation erected to previous version of BS7671

Description of premises: Dwelling  Commercial  Industrial  Other (include brief description): N/A

Estimated age of electrical installation: 40 years Evidence of additions or alterations:  if yes, estimated age 10 years Overall assessment of the installation for continued use: **Satisfactory/Unsatisfactory\*\***

\*\*An unsatisfactory assessment indicates that dangerous (Code C1) and/or potentially dangerous (Code C2) conditions have been identified (listed in PART 5 of this report) and it is recommended that these are acted upon as a matter of urgency.

## PART 4 : DECLARATION

**INSPECTION AND TESTING**

I/We, being the person responsible for the inspection and testing of the electrical installation (as indicated by my/our signature below), particulars of which are described in PART 6, having exercised reasonable skill and care when carrying out the inspection and testing, hereby declare that the information in this report, including the observations (PART 5) and the attached Schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent and limitations in PART 6 of this report.

Name (capital) on behalf of the contractor identified in PART 1: MATTHEW SPEICH Signature: [Signature] Date: 02/08/2023

I/We further RECOMMEND, subject to the necessary remedial action being taken, that the installation is inspected and tested by: 02/08/2028 (date)

Give reason for recommendation: Domestic rental property

The proposed date for the next inspection should take into consideration any legislative or licensing requirements and the frequency and quality of maintenance that the installation can reasonably be expected to receive during its intended life. The period should be agreed between relevant parties.

**REVIEWED BY THE REGISTERED QUALIFIED SUPERVISOR FOR THE CONTRACTOR**

Name (capital) on behalf of the contractor identified in PART 1: MATTHEW CHIPCHASE Signature: [Signature] Date: 24/08/2023





This certificate is not valid if the serial number has been defaced or altered

27866147

EICR18.2c

# ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671:2018+A2:2022 - Requirements for Electrical Installations

## PART 6 : DETAILS AND LIMITATIONS OF THE INSPECTION AND TESTING

The inspection and testing has been carried out in accordance with BS 7671:2018, as amended to 2022 (date). Cables concealed within trunking and conduits, or cables and conduits concealed under floors, in inaccessible roof spaces and generally within the fabric of the building or underground, have not been visually inspected unless specifically agreed between the Client and the Inspector prior to inspection.

Details of the electrical installation covered by this report. All circuits within the installation have been tested and inspected.

Agreed limitations including the reasons, if any, on the inspection and testing (BSL2): No live to neutral insulation resistance tests carried out to prevent damage to connected equipment. No test or inspection has been undertaken in any building voids/roof spaces. see continuation sheet for more.

Operational limitations including the reasons: Unable to determine size and type of main supply company fuse as unit is sealed and access forbidden.

System type and earthing arrangements		Number and type of live conductors		Nature of supply parameters	
TN-C: (N/A)	TN-S: (✓)	AC 1-phase, 2 wire: (✓)	2 phase, 3 wire: (N/A)	Nominal voltage between lines, U <sub>ll</sub> : (N/A) V	(1) By enquiry
TT: (N/A)	IT: (N/A)	3-phase, 3 wire: (N/A)	3 phase, 4 wire: (N/A)	Nominal line voltage to Earth, U <sub>le</sub> : (230) V	(2) By enquiry or by measurement
Supply protective device		DC 2 wire: (N/A)	3 wire: (N/A)	Nominal frequency, f <sub>n</sub> : (50) Hz	
ES EN: (Non-verifiable)	Type: (N/A)	Confirmation of supply polarity: (✓)	Other: (N/A)	Prospective fault current, I <sub>p</sub> : (1.25) kA	
	Rated current: (N/A) A	Other sources of supply (Schedule of Test Results):	Page No: (N/A)	External earth fault loop impedance, Z <sub>s</sub> : (0.23) Ω	

## PART 7 : PARTICULARS OF INSTALLATION REFERRED TO IN THIS REPORT

Means of Earthing		Main protective conductors		Main protective bonding connections		Main switch / Switch-fuse / Circuit-breaker / RCD	
Maximum demand (kVA): (45) kVA	(state as appropriate)	Earthing conductor:		Water installation pipes: (✓)		Location: (Within consumer unit)	
Distributor's facility: (✓)		Material: Copper		Gas installation pipes: (✓)		ES EN: (60947-3)	Type: (3) Rating / setting of device: (N/A) A
Installation earth electrode(s): (N/A)		csa (16) mm <sup>2</sup> Connection/continuity verified: (✓)		Structural steel: (N/A)		No. of poles: (2)	Current rating: (100) A Voltage rating: (230) V
Earth electrode type - rods, taps, etc: (None)		Main protective bonding conductors:		Oil installation pipes: (N/A)		Where an RCD is used as the main switch	
Location: (N/A)		Material: Copper		Lightning protection: (N/A)		RCD rated residual operating current, I <sub>Δn</sub> : (N/A) mA	RCD type: (N/A)
Electrode resistance to Earth: (N/A) Ω		csa (10) mm <sup>2</sup> Connection/continuity verified: (✓)		Other (state): (N/A)		Rated line delay: (N/A) ms	Measured operating time: (N/A) ms

\*Where the installation is supplied by more than one source, the higher or highest values of prospective fault current, I<sub>p</sub>, and external earth fault loop impedance, Z<sub>s</sub>, must be recorded. All fields must be completed. Enter either, as appropriate: ✓ if acceptable condition; N/A if not applicable; LIM if a limitation exists, or Code appropriately: CODE 'EX' 'CX' 'CF' or 'TV' codes to be recorded in PART 5, with additional comments (where appropriate) on attached numbered sheets. This report is based on the model forms shown in Appendix 6 of BS 7671:2018+A2:2022. © Copyright Certsure LLP (May 2023)

Original (for the purpose of issuing the report)

# ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671:2018+A2:2017 - Requirements for Electrical Installations

**PART 9: SCHEDULE OF ITEMS INSPECTED** (enter ✓, N/A or Classification Code C1, C2, C3 or F1, as applicable)

<b>1.8 Intake equipment (visual inspection only)</b> <i>An reference against an item in section 1, other than access to live parts, should not be used to determine the overall assessment of the installation. Where inadequacies are identified, a cross should be put against the appropriate item and a comment made in Part 6 of this report.</i>		4.6 Confirmation that integral test button / switch, where present, causes RCD to trip when operated (S43.3) (C3)
1.1 Distributor / supplier intake equipment	• Accessibility of all protective bonding connections (S43.2) (✓)	4.7 Presence of diagrams, charts or schedules at or near equipment, where required (S43.5) (✓)
• Service cables (✓)	• Provision of earthing / bonding labels at all appropriate locations (S43.3) (✓)	4.8 Presence of alternative supply warning notice at or near equipment, where required (S43.6) (N/A)
• Service head (✓)	3.2 RCD - requirements satisfied (S43.7) (N/A)	4.9 Presence of test inspection recommendation label, where required (S43.7) (✓)
• Earthing arrangement (✓)	3.3 Other methods of protection	4.20 Presence of other required labelling (where specific) (S44) (N/A)
• Water tails (✓)	Where any of the methods listed below are employed, details should be provided on separate sheets	4.21 Compatibility of protective devices, bases and other components correct type and rating for signs of unacceptable thermal damage, arcing or overheating (S42, S42, S44) (✓)
• Working equipment (✓)	• Non-conducting location (R41) (N/A)	4.22 Single pole switching or protective devices in live conductors only (S23.4) (S23.5) (✓)
• Isolator, where present (N/A)	• Earth-free local equipotential bonding (R42) (N/A)	4.23 Protection against mechanical damage where cables enter equipment (S22.1) (S22.5.1) (S22.5.2) (✓)
• Where inadequacies in the intake equipment are encountered, which may result in a dangerous or potentially dangerous situation, the person ordering the work and / or dutyholder must be informed. It is strongly recommended that the person ordering the work informs the appropriate authority.	• Electrical separation (R3, R3.1) (N/A)	4.24 Protection against electromagnetic effects where cables enter ferromagnetic enclosures (S23.2) (✓)
• Double insulation (R2) (N/A)	• Reinforced insulation (R2) (N/A)	5.8 Distribution circuits
• Provisions where automatic disconnection of supply is not feasible (R3) (N/A)	4.0 Distribution equipment, including consumer units and distribution boards	5.1 Identification of conductors (S4.2) (N/A)
1.2 Consumer's isolator, where present (N/A)	4.1 Adequacy of working space / accessibility to equipment (S2.2) (S2.3) (✓)	5.2 Cables correctly supported throughout their run (S23.5.3) (S23.5.4) (N/A)
1.3 Consumer's meter tails (✓)	4.2 Security of fixing (S41.2) (✓)	5.3 Condition of insulation of live parts (R41) (N/A)
2.0 Presence of adequate arrangements for parallel or switched alternative sources	4.3 Condition of insulation of live parts (R41) (✓)	5.4 Non-sheathed cables protected by enclosure to combat, stranding or bruising (S23.6) (N/A)
2.1 Adequate arrangements where a generating set operates as a switched alternative to the public supply (S10.6) (N/A)	4.4 Adequacy security of barriers or enclosures (R42.2) (✓)	5.5 Suitability of containment systems for continued use (including flexible conduit) (S23) (N/A)
2.2 Adequate arrangements where a generating set operates in parallel with the public supply (S10.7) (N/A)	4.5 Condition of enclosures in terms of IP rating, etc. (R42) (✓)	5.6 Cables correctly terminated in enclosures (S26) (N/A)
3.0 Methods of protection	4.6 Condition of enclosure(s) in terms of fire rating, etc. (S21.2) (S21.3) (S21.4) (✓)	5.7 Confirmation that ALL conductor connections, including connections to busbars, are correctly located in terminals and are tight and secure (S25) (N/A)
3.1 Automatic disconnection of supply (ADS)	4.7 Enclosure not damaged / deteriorated so as to impair safety (R42.3) (✓)	5.8 Examination of cables for signs of unacceptable thermal or mechanical damage / deterioration (S21) (S23.6) (N/A)
• Main earthing / bonding arrangement (R43, Chap 54) (✓)	4.8 Presence and effectiveness of obstacles (R22) (✓)	5.9 Adequacy of cables for current-carrying capacity with regard to the type and nature of installation (S22) (N/A)
• Presence of distributor's earthing arrangement (S42.1.1; S42.1.2) or presence of installation earth electrode arrangement (S43.1.1) (✓)	4.9 Presence of main switch(es), listed where required (R42, R42.1.2) (R42.2) (✓)	
• Adequacy of earthing conductor size (S42.3; S43.1) (✓)	4.10 Operation of main switch(es) (functional check) (S43.1) (✓)	
• Adequacy of earthing conductor connections (S42.3.2) (✓)	4.11 Confirmation that integral test button / switch causes RCD(s) to trip when operated (functional check) (S43.3) (✓)	
• Accessibility of earthing conductor connections (S43.1.2) (✓)	4.12 RCD(s) provided for fault protection - includes RCO(s) (R44.2.04-4.4.5; 4.5.2; S31.2) (N/A)	
• Adequacy of main protective bonding conductor sizes (S44.1) (✓)	4.13 RCD(s) provided for additional protection / requirements, where required - includes RCO(s) (R43.1.1; 4.5.1) (C3)	
• Adequacy and location of main protective bonding conductor connections (S44.1.2) (✓)	4.14 Presence of RCD six-monthly test notice, where required (S43.2) (✓)	
	4.15	

Original (in the person making the work)





This certificate is not valid if the serial number has been defaced or altered

27866147

EICR18.2c

# ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671:2018+A2:2022 - Requirements for Electrical Installations

## PART 9 : SCHEDULE OF ITEMS INSPECTED (enter ✓, N/A or Classification Code C1, C2, C3 or FI, as applicable)

<p><b>72</b> Switching off for mechanical maintenance -</p> <ul style="list-style-type: none"> <li>Presence and condition of appropriate devices (464); 5323.2) (✓)</li> <li>Capable of being secured in the OFF position where not under continuous supervision (464.2) (✓)</li> <li>Correct operation verified (464.3) (✓)</li> <li>Clearly identified by position and / or durable marking (5323.2.4) (✓)</li> </ul> <p><b>73</b> Emergency switching off -</p> <ul style="list-style-type: none"> <li>Presence and condition of appropriate devices (465; 5323.3; 5324) (N/A)</li> <li>Readily accessible for operation where danger might occur (5323.3.6) (N/A)</li> <li>Correct operation verified (464.3) (N/A)</li> <li>Clearly identified by position and / or durable marking (5323.3.5; 5323.3.6; 5324.3; 5324.4) (N/A)</li> </ul> <p><b>74</b> Functional switching -</p> <ul style="list-style-type: none"> <li>Presence and condition of appropriate devices (5323.1); 5323.2) (✓)</li> <li>Correct operation verified (464.3) (✓)</li> </ul> <p><b>8.0</b> Current-using equipment (permanently connected)</p> <p><b>8.1</b> Condition of equipment in terms of IP rating, etc. (416.2; 422.3; 422.4; 522.4) (✓)</p> <p><b>8.2</b> Equipment does not constitute a fire hazard (420) (✓)</p> <p><b>8.3</b> Enclosure not damaged / deteriorated so as to impair safety (D4.1); 416.2) (✓)</p> <p><b>8.4</b> Suitability for the environment and external influences (50.2) (✓)</p>	<p><b>8.5</b> Security of fixing (D4.1) (✓)</p> <p><b>8.6</b> Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire. List number and location of luminaires inspected (separate page) (5272) (✓)</p> <p><b>8.7</b> Recessed luminaires (downlighters) -</p> <ul style="list-style-type: none"> <li>Correct type of lamps fitted (508.3.1) (N/A)</li> <li>Installed to minimise build-up of heat by use of "fire rated" fittings, insulation displacement box or similar (421.2) (N/A)</li> <li>No signs of overheating to surrounding building fabric (508.4) (N/A)</li> <li>No signs of overheating to conductors / terminations (526) (N/A)</li> </ul> <p><b>8.0</b> Special locations and installations Where special installations or locations relating to a particular Section of Part 2, an additional inspection schedule(s) should be provided on separate pages.</p> <p><b>8.1</b> Location(s) containing a bath or shower -</p> <ul style="list-style-type: none"> <li>Additional protection by RCBO having rated residual operating current not exceeding 30 mA for all low voltage (LV) circuits serving the location or passing through zones 1 and / or 2 of the location (701.61.3.3) (✓)</li> <li>Where used as a protective measure, requirements for SELV or PELV met (701.64.4.5) (N/A)</li> <li>Shower supply units complying with BS EN 60598-2-5 formerly BS 3535 (701.52.3) (N/A)</li> <li>Presence of supplementary bonding conductors, unless not required by BS 7671:2018 (701.65.2) (N/A)</li> </ul>	<ul style="list-style-type: none"> <li>Low voltage (e.g. 230 V) socket-outlets sited at least 2.5 m from zone 1 (701.52.3) (N/A)</li> <li>Suitability of equipment for external influences for installed location in terms of IP rating (701.52.2) (✓)</li> <li>Suitability of accessories and contractor etc. for a particular zone (701.52.2) (✓)</li> <li>Suitability of current-using equipment for particular position within the location (701.56) (✓)</li> </ul> <p><b>8.2</b> Other special installations or locations - (N/A)</p> <p><b>8.3</b> Prosumer's low voltage installation Where elements of a prosumer installation falling within the scope of Chapter 62 are covered by the report, additional schedules detailing the associated inspection and testing should be provided on separate pages. (N/A)</p> <p><b>Schedule of items inspected by</b> Name (sophistic): MATTHEW SPEICH Signature: [Signature] Date: 02/06/2023</p>
--	--	---

## PART 10 : SCHEDULES AND ADDITIONAL PAGES (the pages identified are an essential part of this report (see Regulation 653.2))

Schedule of Inspections	Schedule of Circuit Details and Test Results for the Installation	Additional pages, including data sheets for additional sources	Special installations or locations (indicated in item 8.2 above)	Schedules relating to Prosumer's installations (indicated in item 8.3 above)	Continuation sheets
Page No(s): (4, 5 & 6)	Page No(s): (7 & 8)	Page No(s): (11-12)	Page No(s): (None)	Page No(s): (None)	Page No(s): (None)



This certificate is not valid if the serial number has been defaced or altered

27866147

EICR18.2c

# ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671:2018+A2:2022 - Requirements for Electrical Installations

## PART 11A - SCHEDULE OF CIRCUIT DETAILS (GO TO Part 11B 'Schedule of Test Results' to enter test results for the corresponding circuit listed in this part)

Circuit number	Circuit description	Type of wiring (see Section 534.1.1)	Insulation method (BS 5717)	Number of paths served	Cable conductor (Section 534.1.1)			Max. Protection (see BS 5717)	Overcurrent protective device					RCD			
					Line	Neutral	Earth		BS 286	Type	Rating	Short circuit capacity	Residual current	BS 286	Type	Rating	Operating time, s
					(mm <sup>2</sup> )	(mm <sup>2</sup> )	(mm <sup>2</sup> )		(kA)	(kA)	(kA)	(mA)	(s)	(s)			
1	Cooker	A	C	1	6	2.5	0.4	61009	B	32	6	1.37	61009	AC	32	30	
2	Sockets	A	C	20	2.5	1.5	0.4	61009	C	20	6	1.09	61009	A	20	30	
3	Hall sockets	A	C	1	2.5	1.5	0.4	61009	C	16	6	1.37	61009	AC	16	30	
4	Lighting	A	C	1	1	1	0.4	61009	C	6	6	3.64	61009	AC	6	30	
5	Shower	A	C	1	10	4	0.4	61009	B	45	6	0.87	61009	AC	45	30	
6	Extension sockets	A	C	4	2.5	1.5	0.4	61009	B	32	6	1.37	61009	AC	32	30	
7	Extension lights	A	101	5	1.5	1	0.4	61009	B	10	6	4.37	61009	AC	10	30	
8	Spare	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Original (in the person ordering the work)

### DISTRIBUTION BOARD (DB) DETAILS (complete in every case)

DB designation: DB-01  
 Location of DB: Understairs  
 $Z_e = 0.23$  (Ω)  $I_{sc}$  at DB: 1.26 (kA)  
 Confirmation of supply polarity:  Phase sequence confirmed: (N/A)  
 SPD Details\*\* Types: T1 (N/A) T2 (N/A) T3 (N/A) R/A (N/A)  
 Status indicator checked (where functionality indicator is present): (N/A)

\*\*SPD Type.  
 Where combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both Type brackets.  
 Where T3 devices are installed on a circuit to protect sensitive equipment, enter details in 'Comments' (PART 11B).  
 (See Section 534 for further details).  
 Note that not all SPDs have visible functionality indication.

### TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

Supply to DB is from: N/A  
 Overcurrent protective device for the distribution circuit  
 BS (kA) (N/A) Type ( ) Nominal voltage (N/A) V Rating (N/A) A No. of phases (N/A)  
 Associated RCD (if any)  
 BS (kA) (N/A) RCD type (N/A) I<sub>Δn</sub> (N/A) mA No. of poles (N/A) Operating time (N/A) ms



This certificate is not valid if the serial number has been defaced or altered

27886147

EICR18.2c

# ELECTRICAL INSTALLATION CONDITION REPORT

Issued in accordance with BS 7671: 2018+A2:2022 - Requirements for Electrical Installations

## PART IIB - SCHEDULE OF TEST RESULTS (MUST reflect circuits entered into 'Schedule of Circuit Details' in Part IIA)

Circuit number	Continuity (Ω)					Insulation resistance			Polarity	RCD Type (MVA)	RCB Type (MVA)	RCD Test button	RCB Test button	Comments and additional information, where required	
	Ring final circuits only (measured end to end)			All circuits (complete of least one conductor)		Line / Line	Line / Earth	Test voltage (V)							
	Line / Line	Line / Neutral	Line / Earth	(R <sub>1</sub> + R <sub>2</sub> )	R <sub>3</sub>	(MΩ)	(MΩ)	(V)							
1	N/A	N/A	N/A	0.04	N/A	LIM	200	500	✓	0.27	33.9	✓	N/A	N/A	
2	N/A	N/A	N/A	0.56	N/A	LIM	40	500	✓	0.74	22.5	✓	N/A	N/A	
3	N/A	N/A	N/A	0.07	N/A	LIM	200	500	✓	0.30	37.1	✓	N/A	N/A	
4	N/A	N/A	N/A	1.11	N/A	LIM	50	500	✓	1.34	28.8	✓	N/A	N/A	
5	N/A	N/A	N/A	0.11	N/A	LIM	200	500	✓	0.34	28.9	✓	N/A	N/A	
6	0.50	0.50	0.81	0.35	N/A	LIM	100	500	✓	0.55	52.7	✓	N/A	N/A	
7	N/A	N/A	N/A	0.61	N/A	LIM	100	500	✓	0.84	29.8	✓	N/A	N/A	
8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Circuits/equipment vulnerable to damage when testing (where applicable): N/A

TESTED BY Name (capital): MATTHEW SPEICH

Position: Electrician

Signature: [Signature]

Date: 02/06/2023

### TEST INSTRUMENTS (ENTER SERIAL NUMBER AGAINST EACH INSTRUMENT USED)

Multi-function:	Continuity:	Insulation resistance:	Earth fault loop impedance:	Earth electrode resistance:	RCD:
N/A	N/A	N/A	N/A	N/A	N/A

\* RCD effectiveness is verified using an alternating current test at rated residual operating current (I<sub>Δn</sub>)

COIKS for type of wiring: (A) Thermoplastic insulated (plastic jacketed) cables, (B) Thermoplastic insulated (plastic jacketed) cables, (C) Thermoplastic cables in non-metallic conduit, (D) Thermoplastic cables in metal conduit, (E) Thermoplastic cables in non-metallic conduit, (F) Thermoplastic cables in metal conduit, (G) Thermoplastic cables in metal conduit, (H) Thermoplastic cables in metal conduit, (I) Thermoplastic cables in metal conduit, (J) Thermoplastic cables in metal conduit, (K) Thermoplastic cables in metal conduit, (L) Thermoplastic cables in metal conduit, (M) Thermoplastic cables in metal conduit, (N) Thermoplastic cables in metal conduit, (O) Thermoplastic cables in metal conduit, (P) Thermoplastic cables in metal conduit, (Q) Thermoplastic cables in metal conduit, (R) Thermoplastic cables in metal conduit, (S) Thermoplastic cables in metal conduit, (T) Thermoplastic cables in metal conduit, (U) Thermoplastic cables in metal conduit, (V) Thermoplastic cables in metal conduit, (W) Thermoplastic cables in metal conduit, (X) Thermoplastic cables in metal conduit, (Y) Thermoplastic cables in metal conduit, (Z) Thermoplastic cables in metal conduit.

This certificate is based on the model forms shown in Appendix 8 of BS 7671: 2018+A2:2022 © Copyright Centauru LLP (May 2023) Page 8 of 12



CONTINUATION SHEET : EIC and EICR  
Issued in accordance with BS 7671:2018+A2:2022 - Requirements for Electrical Installations

PART A : SCHEDULE OF CIRCUIT DETAILS (GO TO Part B 'Schedule of Test Results' to enter test results for the corresponding circuit listed in this part)

Circuit number	Circuit description	Type of wiring (see Section 534.2.1)	Number of conductors (BS 6843)	Number of points served	Circuit conductor (number & size)			Max. disconnection time (s) (BS 6843)	Overcurrent protective device				RCD			
					L1e (mm <sup>2</sup> )	L1N (mm <sup>2</sup> )	N (mm <sup>2</sup> )		BS (EN)	Type	Rating (kA)	Sensitivity (mA)	BS (EN)	Type	Rating (kA)	Sensitivity (mA)
	RCD main switch	N/A	N/A	N/A	N/A	N/A	0.4	N/A	N/A	N/A	N/A	N/A	61008	AC	63	30
	RCD main switch	N/A	N/A	N/A	N/A	N/A	0.4	N/A	N/A	N/A	N/A	N/A	61008	AC	63	30
1	Shower-1st floor	A	C	1	10	4	0.4	60698	B	40	6	1.09	N/A	N/A	N/A	N/A

**DISTRIBUTION BOARD (DB) DETAILS (complete in every case)**  
 DB designation: DB-02  
 Location of DB: Understairs  
 $Z_{db}$ : 0.23 (Ω)  
 $I_{sc}$  at DB: 1.26 (kA)  
 Confirmation of supply polarity: (✓) Phase sequence confirmed: (N/A)  
 SPD Details\*\* Types: T1 (N/A) T2 (N/A) T3 (N/A) N/A (N/A)  
 Status indicator checked (where functionality indicator is present): (N/A)

\*\*SPD Type.  
 Where combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both Type brackets.  
 Where T3 devices are installed on a circuit to protect sensitive equipment, enter details in 'Comments' (PART B).  
 (See Section 534 for further details).  
 Note that not all SPDs have visible functionality indication.

**TO BE COMPLETED ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION**  
 Supply to DB is from: N/A  
**Overcurrent protective device for the distribution circuit**  
 BS (EN) (N/A) Type: ( ) Nominal voltage (N/A) V Rating (N/A) kA No. of poles (N/A)  
**Associated RCD (if any)**  
 BS (EN) (N/A) RCD type (N/A)  $I_{\Delta n}$  (N/A) mA No. of poles (N/A) Operating time (N/A) ms

Original (to the person ordering the work)

**CONTINUATION SHEET : EIC and EICR**

Issued in accordance with BS 7671:2018+A2:2022 - Requirements for Electrical Installations

**PART B : SCHEDULE OF TEST RESULTS (MUST reflect circuits entered into 'Schedule of Circuit Details' in Part A)**

Circuit number	Continuity (Ω)					Insulation resistance			Polarity	RCD Sensitivity mA Type	RCD		AFDD*		Comments and additional information, where required
	Ring final circuits only (measured end to end)			Miscellaneous (complete at test time unless stated)		Line / Live	Line / Earth	Out to earth / RC			Operating time†	Test failure	AFDD test failure	AFDD test failure	
	Ω/kV	Ω/kV	Ω/kV	R <sub>1</sub> + R <sub>2</sub>	R <sub>3</sub>	MΩ	MΩ	Ω			ms	ms	ms	ms	
	Ω/kV	Ω/kV	Ω/kV	R <sub>1</sub> + R <sub>2</sub>	R <sub>3</sub>	MΩ	MΩ	Ω			ms	ms	ms	ms	
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	✓	N/A	17.1	✓	N/A	N/A	
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	✓	N/A	17.1	✓	N/A	N/A	
1	N/A	N/A	N/A	0.16	N/A	LIM	200	500	✓	0.39	17.1	✓	N/A	N/A	

Circuits/equipment vulnerable to damage when testing (where applicable): N/A

TESTED BY Name (capital): MATTHEW SPEICH

Position: Electrician

Signature: *M. Speich*

Date: 02/08/2023

**TEST INSTRUMENTS (ENTER SERIAL NUMBER AGAINST EACH INSTRUMENT USED)**

Multi-function: 1010105910	Continuity: N/A	Insulation resistance: N/A	Earth fault loop impedance: N/A	Earth electrode resistance: N/A	RCD: N/A
-------------------------------	--------------------	-------------------------------	------------------------------------	------------------------------------	-------------

\* RCD effectiveness is verified using an alternating current test at rated residual operating current (I<sub>Δn</sub>) \*\* Where installed, Note, not all AFDDs have a test function. Where a circuit contains an AFDD this should be stated in the field for that circuit in the 'Comments and additional information, where required' column.

Original (for the person submitting the work)



This certificate is not valid if the serial number has been defaced or altered

27866147

N18.2c

### GENERAL CONTINUATION SHEET

Issued in accordance with BS 7671: 2018+A2:2022 - Requirements for Electrical Installations

#### NOTES

##### Inspection limitations

Accessories such as sockets and light switches not unscrewed where decor may be damaged.  
 Fixed equipment such as cookers, or other hard wired equipment tested at point of isolation.  
 Socket-outlets or connection points behind washing-machines, dishwashers, cooker-hoods etc not inspected or tested.  
 Complex wiring that can be reasonably accessed has been visually inspected.  
 Cables incorporating integrated appliances only tested at isolation spur unit and not at socket outlet behind appliance to prevent damage to goods and floor areas where moving would be required.  
 Central heating system including wiring to thermostats and control / wiring centres not inspected - tested to isolation point only.  
 Cable values may be calculated to prevent access to exposed live parts during testing.  
 Not possible to determine whether cables are routed in prescribed cable zones due to building fabric (plaster etc)

Original (for the person ordering the work)



**THIS CONDITION REPORT IS AN IMPORTANT AND VALUABLE DOCUMENT WHICH SHOULD BE RETAINED FOR FUTURE USE**

The purpose of periodic inspection is to determine, so far as is reasonably practicable, whether an electrical installation is in a satisfactory condition for continued service. This report provides an assessment of the condition of the electrical installation identified overleaf at the time it was inspected and tested, taking into account the stated extent of the installation and the limitations of the inspection and testing.

This report has been issued in accordance with the national standard for the safety of electrical installations, BS 7671: 2018+A2:2022 - Requirements for Electrical Installations.

The report identifies any damage, deterioration, defects and/or conditions found by the inspector which may give rise to danger (see PART 5), together with any items for which improvement is recommended.

You should have received the report marked 'Original' and the contractor should retain a duplicate. If you were the person ordering this report, but not the owner or user of the installation, you should pass this report, or a full copy of it, including these notes, the schedules and additional pages (if any), immediately to the owner or user of the installation.

This report should be retained in a safe place and shown to any person inspecting or undertaking further work on the electrical installation in the future. If you later vacate the property, this report will provide the new user with an assessment of the condition of the electrical installation at the time the periodic inspection was carried out.

For safety reasons, the electrical installation should be re-inspected at appropriate intervals by a skilled person or persons, competent in such work. NICEIC® recommends that you engage the services of an NICEIC contractor for the inspection. Only an NICEIC contractor is authorised to issue this NICEIC Electrical Installation Condition Report, which has a unique serial number that is traceable to the contractor to which it was supplied by NICEIC.

The recommended date by which the next inspection should be carried out is stated in PART 4 of this report. With the exception of domestic (household) premises, there should also be a notice at or near the main switchboard or distribution board/consumer unit indicating when the next inspection of the installation is due.

This report is intended to be issued only for the purpose of reporting on the condition of an existing electrical installation and must not be issued to certify new electrical installation work including the replacement of a distribution board or consumer unit.

The report consists of at least eight numbered pages. The report is only valid if the Schedule of Items Inspected (PART 9) has been completed to confirm that all relevant inspections have been carried out and the Schedule of Circuit Details (PART 11A) and the Schedule of Test Results (PART 11B) are attached. For installations having more than one distribution board (or consumer unit) or more circuits than can be recorded in PARTS 11A & 11B, one or more additional Schedule of Circuit Details and Schedule of Test Results, should form part of the report. Additional numbered pages may have been provided to permit further relevant information relating to the installation to be recorded. The report is invalid if any of the additional pages, listed in PART 10 are missing.

Where the installation includes a residual current device (RCD) it should be tested every six months by pressing the button marked "T" or "Test". The device should switch off the supply and should then be switched on to restore the supply. If the device does not switch off the supply when the button is pressed, seek expert advice. For safety reasons it is important that this instruction is followed.

Where the installation includes an arc fault detection device (AFDD) having a manual test facility it should be tested six-monthly by pressing the test button. Where an AFDD has both a test button and automatic test function, manufacturer's instructions should be followed with respect to test button operation.

Where the installation includes a surge protection device (SPD) the status indicator should be checked to confirm it is in operational condition in accordance with manufacturer's information. If the indication shows that the device is not operational, seek expert advice.

**NOTES FOR RECIPIENT**

Where the installation can be supplied by more than one source, such as the public supply and a standby generator or microgenerator, this should be identified in PART 7 Supply Characteristics and Earthing Arrangements, and the Schedules of Circuit Details and Test Results (PART 11A & 11B) compiled accordingly.

PART 8 (Details and Limitations) should identify fully the extent of the installation covered by this report and any limitations on the inspection and testing. The inspector should have agreed these covers with the person ordering the report and with other interested parties (licensing authority, insurance company, mortgage provider and the like) before the inspection was carried out.

Operational limitations may have been encountered during the inspection such as inability to gain access to parts of the installation or to an item of equipment. The inspector should have noted any such limitations in PART 8. It should be noted that the greater the limitations applying to a report, the less its value from the safety aspect.

A declaration should have been given by the inspector in PART 4 of the report. The declaration must reflect the statement given in PART 3, which summarises the observations and recommendations made in PART 5. Where one or more observations have been made in PART 5, the Classification code given to each by the inspector indicates the degree of urgency with which remedial action needs to be taken to restore the installation to a safe working condition.

Where the inspector has indicated an observation as code C1 (danger present) the safety of those using the installation is at risk. Whenever practicable, items classified as C1 should be made safe on discovery, and it is recommended that a skilled person(s) competent in electrical installation work undertakes the necessary remedial work immediately.

Where the inspector has indicated an observation as code C2 (potentially dangerous) the safety of those using the installation may be at risk, and it is recommended that a skilled person competent in electrical installation work undertakes the necessary remedial work as a matter of urgency.

Where the inspector has indicated that an item requires further investigation (FI), the investigation should be carried out without delay to determine whether danger or potential danger exists. For further guidance on the Classification codes, please see the reverse of page 2.

Where inadequacies in the intake equipment have been observed (Item 1 of PART 9), the person ordering the inspection should inform the distributor and/or supplier as appropriate.

Should the person ordering this report have reason to believe that it does not reasonably reflect the condition of the electrical installation reported on, that person should in the first instance raise the specific concerns in writing with the contractor. If the concerns remain unresolved, the person ordering this report may make a formal complaint to NICEIC, for which purpose a complaint form is available on request.

The complaints procedure offered by NICEIC is subject to certain terms and conditions, full details of which are available upon application. NICEIC does not investigate complaints relating to the operational performance of electrical installations (such as lighting levels), or to contractual or commercial issues (such as time or costs).

For further information about electrical safety and how NICEIC can help you, visit:  
[www.niceic.com](http://www.niceic.com)

\* NICEIC is operated by Certisure LLP, a partnership between the Electrical Contractors' Association and the charity, Electrical Safety First. NICEIC maintains and publishes registers of electrical contractors that it has assessed against particular scheme requirements (including the technical standard of electrical work).