

A Details of the Installation

Client **MR & MRS PARTINGTON**

Address **8 STATION LANE,
COLMANTHORPE, YORK.**

Postcode **YO23**

Installation (If different from client)

Address **4 HESLINGTON MEWS,
YORK.**

Postcode **YO10 5BT.**

B Reason for producing this report This form to be used only for reporting on the condition of an existing installation

DATE OVERDUE.

Date(s) on which the inspection and testing were carried out **6th MARCH 23** to **6th MARCH 23**

C Details of the installation which is the subject of the report

Description of premises Domestic ☒ Commercial ☐ Industrial ☐ Other (please state) **_____**

Estimated age of the wiring system **15** years

Evidence of alterations or additions ☐ Yes ☒ No ☐ Not apparent If 'Yes', estimated **_____** years

Records of installation available (Regulation 651.1) ☒ Yes ☐ No Records held by **MR PARTINGTON.**

Date of last inspection **2nd FEB 2018** Electrical Installation Certificate No. **_____** or previous Inspection Report No. **63263.**

D Extent of imitations of inspection and testing

Agreed limitations and Operational Limitations (See Regulations 653.2)

**No lifting of floors.
No loft access
No Alterations to the fabric of the
Building.**

NONE

Agreed with (If required): **_____**

Operational limitations including the reasons (see page no **NA** of **NA** (If applicable)

The inspection and testing detailed within this report and accompanying schedules has been carried out in accordance with BS 7671:2018. It should be noted that cables concealed within the trunking and conduits, under floors, in roof spaces and generally within the fabric of the building or underground have not been inspected unless specifically agreed between the client and inspector prior to the inspection. An inspection should be made within an accessible roof space housing other electrical equipment.

E Summary of the condition of the installation

General conditions of the installation (in terms of electrical safety)

SATISFACTORY

Overall assessment of the installation in terms of its suitability for continued use

SATISFACTORY ☒ **UNSATISFACTORY*** ☐

* An UNSATISFACTORY assessment indicates that dangerous (code C1) and/or potentially dangerous (code C2) conditions have been identified.

F Recommendations

Where the overall assessment of the suitability of the installation for continued use above is stated as UNSATISFACTORY, I / we recommend that any observations classified as 'Danger present' (code C1) or 'Potentially dangerous' (code C2) are acted upon as a matter of urgency. Investigation without delay is recommended for observations identified as 'further investigation required' (code FI) Observations classified as 'Improvement recommended' (code C3) should be given due consideration. Subject to the necessary remedial action being taken, I / we recommend that the installation is further inspected and tested by **6 / 3 / 23** (date)

G Declaration

I/We, being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by my/our signatures below), particulars of which are described above, having exercised reasonable skill and care when carrying out the inspection and testing, hereby declare that the information in this report, including the observations and the attached schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent and limitations in section D of this report.

Company **PAUL BOUTON ELECTRICAL**

Membership No. **9375**

Address **6 SOUTH VIEW**

NEWTON ON OSSE

Postcode **YO30 2BX**

Inspected and tested by

Name **P. BOUTON**

Signature **P. Bouton**

Position **SOLE TRADER**

Date **6th MARCH 23**

Authorised for issue by

P. Bouton

✓

✓

✓

H Schedule(s)

☒ schedule(s) of inspection and ☒ schedule(s) of test results are attached.

The attached schedule(s) are part of this document and this report is valid only when they are attached to it.

Supply characteristics and earthing arrangements

Earthing Arrangements TN-S ☐ TN-C-S ☒ TT ☐ Other ☐ Please specify: _____

Number and Type of Live Conductors AC ☒ DC ☐ No. of phases ☐ 1 ☐ 2 ☐ 3 ☐ 4 ☐ 5 ☐ 6 ☐ 7 ☐ 8 ☐ 9 ☐ 10 ☐ 11 ☐ 12 ☐ 13 ☐ 14 ☐ 15 ☐ 16 ☐ 17 ☐ 18 ☐ 19 ☐ 20 ☐ 21 ☐ 22 ☐ 23 ☐ 24 ☐ 25 ☐ 26 ☐ 27 ☐ 28 ☐ 29 ☐ 30 ☐ 31 ☐ 32 ☐ 33 ☐ 34 ☐ 35 ☐ 36 ☐ 37 ☐ 38 ☐ 39 ☐ 40 ☐ 41 ☐ 42 ☐ 43 ☐ 44 ☐ 45 ☐ 46 ☐ 47 ☐ 48 ☐ 49 ☐ 50 ☐ 51 ☐ 52 ☐ 53 ☐ 54 ☐ 55 ☐ 56 ☐ 57 ☐ 58 ☐ 59 ☐ 60 ☐ 61 ☐ 62 ☐ 63 ☐ 64 ☐ 65 ☐ 66 ☐ 67 ☐ 68 ☐ 69 ☐ 70 ☐ 71 ☐ 72 ☐ 73 ☐ 74 ☐ 75 ☐ 76 ☐ 77 ☐ 78 ☐ 79 ☐ 80 ☐ 81 ☐ 82 ☐ 83 ☐ 84 ☐ 85 ☐ 86 ☐ 87 ☐ 88 ☐ 89 ☐ 90 ☐ 91 ☐ 92 ☐ 93 ☐ 94 ☐ 95 ☐ 96 ☐ 97 ☐ 98 ☐ 99 ☐ 100 ☐ 101 ☐ 102 ☐ 103 ☐ 104 ☐ 105 ☐ 106 ☐ 107 ☐ 108 ☐ 109 ☐ 110 ☐ 111 ☐ 112 ☐ 113 ☐ 114 ☐ 115 ☐ 116 ☐ 117 ☐ 118 ☐ 119 ☐ 120 ☐ 121 ☐ 122 ☐ 123 ☐ 124 ☐ 125 ☐ 126 ☐ 127 ☐ 128 ☐ 129 ☐ 130 ☐ 131 ☐ 132 ☐ 133 ☐ 134 ☐ 135 ☐ 136 ☐ 137 ☐ 138 ☐ 139 ☐ 140 ☐ 141 ☐ 142 ☐ 143 ☐ 144 ☐ 145 ☐ 146 ☐ 147 ☐ 148 ☐ 149 ☐ 150 ☐ 151 ☐ 152 ☐ 153 ☐ 154 ☐ 155 ☐ 156 ☐ 157 ☐ 158 ☐ 159 ☐ 160 ☐ 161 ☐ 162 ☐ 163 ☐ 164 ☐ 165 ☐ 166 ☐ 167 ☐ 168 ☐ 169 ☐ 170 ☐ 171 ☐ 172 ☐ 173 ☐ 174 ☐ 175 ☐ 176 ☐ 177 ☐ 178 ☐ 179 ☐ 180 ☐ 181 ☐ 182 ☐ 183 ☐ 184 ☐ 185 ☐ 186 ☐ 187 ☐ 188 ☐ 189 ☐ 190 ☐ 191 ☐ 192 ☐ 193 ☐ 194 ☐ 195 ☐ 196 ☐ 197 ☐ 198 ☐ 199 ☐ 200 ☐ 201 ☐ 202 ☐ 203 ☐ 204 ☐ 205 ☐ 206 ☐ 207 ☐ 208 ☐ 209 ☐ 210 ☐ 211 ☐ 212 ☐ 213 ☐ 214 ☐ 215 ☐ 216 ☐ 217 ☐ 218 ☐ 219 ☐ 220 ☐ 221 ☐ 222 ☐ 223 ☐ 224 ☐ 225 ☐ 226 ☐ 227 ☐ 228 ☐ 229 ☐ 230 ☐ 231 ☐ 232 ☐ 233 ☐ 234 ☐ 235 ☐ 236 ☐ 237 ☐ 238 ☐ 239 ☐ 240 ☐ 241 ☐ 242 ☐ 243 ☐ 244 ☐ 245 ☐ 246 ☐ 247 ☐ 248 ☐ 249 ☐ 250 ☐ 251 ☐ 252 ☐ 253 ☐ 254 ☐ 255 ☐ 256 ☐ 257 ☐ 258 ☐ 259 ☐ 260 ☐ 261 ☐ 262 ☐ 263 ☐ 264 ☐ 265 ☐ 266 ☐ 267 ☐ 268 ☐ 269 ☐ 270 ☐ 271 ☐ 272 ☐ 273 ☐ 274 ☐ 275 ☐ 276 ☐ 277 ☐ 278 ☐ 279 ☐ 280 ☐ 281 ☐ 282 ☐ 283 ☐ 284 ☐ 285 ☐ 286 ☐ 287 ☐ 288 ☐ 289 ☐ 290 ☐ 291 ☐ 292 ☐ 293 ☐ 294 ☐ 295 ☐ 296 ☐ 297 ☐ 298 ☐ 299 ☐ 300 ☐ 301 ☐ 302 ☐ 303 ☐ 304 ☐ 305 ☐ 306 ☐ 307 ☐ 308 ☐ 309 ☐ 310 ☐ 311 ☐ 312 ☐ 313 ☐ 314 ☐ 315 ☐ 316 ☐ 317 ☐ 318 ☐ 319 ☐ 320 ☐ 321 ☐ 322 ☐ 323 ☐ 324 ☐ 325 ☐ 326 ☐ 327 ☐ 328 ☐ 329 ☐ 330 ☐ 331 ☐ 332 ☐ 333 ☐ 334 ☐ 335 ☐ 336 ☐ 337 ☐ 338 ☐ 339 ☐ 340 ☐ 341 ☐ 342 ☐ 343 ☐ 344 ☐ 345 ☐ 346 ☐ 347 ☐ 348 ☐ 349 ☐ 350 ☐ 351 ☐ 352 ☐ 353 ☐ 354 ☐ 355 ☐ 356 ☐ 357 ☐ 358 ☐ 359 ☐ 360 ☐ 361 ☐ 362 ☐ 363 ☐ 364 ☐ 365 ☐ 366 ☐ 367 ☐ 368 ☐ 369 ☐ 370 ☐ 371 ☐ 372 ☐ 373 ☐ 374 ☐ 375 ☐ 376 ☐ 377 ☐ 378 ☐ 379 ☐ 380 ☐ 381 ☐ 382 ☐ 383 ☐ 384 ☐ 385 ☐ 386 ☐ 387 ☐ 388 ☐ 389 ☐ 390 ☐ 391 ☐ 392 ☐ 393 ☐ 394 ☐ 395 ☐ 396 ☐ 397 ☐ 398 ☐ 399 ☐ 400 ☐ 401 ☐ 402 ☐ 403 ☐ 404 ☐ 405 ☐ 406 ☐ 407 ☐ 408 ☐ 409 ☐ 410 ☐ 411 ☐ 412 ☐ 413 ☐ 414 ☐ 415 ☐ 416 ☐ 417 ☐ 418 ☐ 419 ☐ 420 ☐ 421 ☐ 422 ☐ 423 ☐ 424 ☐ 425 ☐ 426 ☐ 427 ☐ 428 ☐ 429 ☐ 430 ☐ 431 ☐ 432 ☐ 433 ☐ 434 ☐ 435 ☐ 436 ☐ 437 ☐ 438 ☐ 439 ☐ 440 ☐ 441 ☐ 442 ☐ 443 ☐ 444 ☐ 445 ☐ 446 ☐ 447 ☐ 448 ☐ 449 ☐ 450 ☐ 451 ☐ 452 ☐ 453 ☐ 454 ☐ 455 ☐ 456 ☐ 457 ☐ 458 ☐ 459 ☐ 460 ☐ 461 ☐ 462 ☐ 463 ☐ 464 ☐ 465 ☐ 466 ☐ 467 ☐ 468 ☐ 469 ☐ 470 ☐ 471 ☐ 472 ☐ 473 ☐ 474 ☐ 475 ☐ 476 ☐ 477 ☐ 478 ☐ 479 ☐ 480 ☐ 481 ☐ 482 ☐ 483 ☐ 484 ☐ 485 ☐ 486 ☐ 487 ☐ 488 ☐ 489 ☐ 490 ☐ 491 ☐ 492 ☐ 493 ☐ 494 ☐ 495 ☐ 496 ☐ 497 ☐ 498 ☐ 499 ☐ 500 ☐ 501 ☐ 502 ☐ 503 ☐ 504 ☐ 505 ☐ 506 ☐ 507 ☐ 508 ☐ 509 ☐ 510 ☐ 511 ☐ 512 ☐ 513 ☐ 514 ☐ 515 ☐ 516 ☐ 517 ☐ 518 ☐ 519 ☐ 520 ☐ 521 ☐ 522 ☐ 523 ☐ 524 ☐ 525 ☐ 526 ☐ 527 ☐ 528 ☐ 529 ☐ 530 ☐ 531 ☐ 532 ☐ 533 ☐ 534 ☐ 535 ☐ 536 ☐ 537 ☐ 538 ☐ 539 ☐ 540 ☐ 541 ☐ 542 ☐ 543 ☐ 544 ☐ 545 ☐ 546 ☐ 547 ☐ 548 ☐ 549 ☐ 550 ☐ 551 ☐ 552 ☐ 553 ☐ 554 ☐ 555 ☐ 556 ☐ 557 ☐ 558 ☐ 559 ☐ 560 ☐ 561 ☐ 562 ☐ 563 ☐ 564 ☐ 565 ☐ 566 ☐ 567 ☐ 568 ☐ 569 ☐ 570 ☐ 571 ☐ 572 ☐ 573 ☐ 574 ☐ 575 ☐ 576 ☐ 577 ☐ 578 ☐ 579 ☐ 580 ☐ 581 ☐ 582 ☐ 583 ☐ 584 ☐ 585 ☐ 586 ☐ 587 ☐ 588 ☐ 589 ☐ 590 ☐ 591 ☐ 592 ☐ 593 ☐ 594 ☐ 595 ☐ 596 ☐ 597 ☐ 598 ☐ 599 ☐ 600 ☐ 601 ☐ 602 ☐ 603 ☐ 604 ☐ 605 ☐ 606 ☐ 607 ☐ 608 ☐ 609 ☐ 610 ☐ 611 ☐ 612 ☐ 613 ☐ 614 ☐ 615 ☐ 616 ☐ 617 ☐ 618 ☐ 619 ☐ 620 ☐ 621 ☐ 622 ☐ 623 ☐ 624 ☐ 625 ☐ 626 ☐ 627 ☐ 628 ☐ 629 ☐ 630 ☐ 631 ☐ 632 ☐ 633 ☐ 634 ☐ 635 ☐ 636 ☐ 637 ☐ 638 ☐ 639 ☐ 640 ☐ 641 ☐ 642 ☐ 643 ☐ 644 ☐ 645 ☐ 646 ☐ 647 ☐ 648 ☐ 649 ☐ 650 ☐ 651 ☐ 652 ☐ 653 ☐ 654 ☐ 655 ☐ 656 ☐ 657 ☐ 658 ☐ 659 ☐ 660 ☐ 661 ☐ 662 ☐ 663 ☐ 664 ☐ 665 ☐ 666 ☐ 667 ☐ 668 ☐ 669 ☐ 670 ☐ 671 ☐ 672 ☐ 673 ☐ 674 ☐ 675 ☐ 676 ☐ 677 ☐ 678 ☐ 679 ☐ 680 ☐ 681 ☐ 682 ☐ 683 ☐ 684 ☐ 685 ☐ 686 ☐ 687 ☐ 688 ☐ 689 ☐ 690 ☐ 691 ☐ 692 ☐ 693 ☐ 694 ☐ 695 ☐ 696 ☐ 697 ☐ 698 ☐ 699 ☐ 700 ☐ 701 ☐ 702 ☐ 703 ☐ 704 ☐ 705 ☐ 706 ☐ 707 ☐ 708 ☐ 709 ☐ 710 ☐ 711 ☐ 712 ☐ 713 ☐ 714 ☐ 715 ☐ 716 ☐ 717 ☐ 718 ☐ 719 ☐ 720 ☐ 721 ☐ 722 ☐ 723 ☐ 724 ☐ 725 ☐ 726 ☐ 727 ☐ 728 ☐ 729 ☐ 730 ☐ 731 ☐ 732 ☐ 733 ☐ 734 ☐ 735 ☐ 736 ☐ 737 ☐ 738 ☐ 739 ☐ 740 ☐ 741 ☐ 742 ☐ 743 ☐ 744 ☐ 745 ☐ 746 ☐ 747 ☐ 748 ☐ 749 ☐ 750 ☐ 751 ☐ 752 ☐ 753 ☐ 754 ☐ 755 ☐ 756 ☐ 757 ☐ 758 ☐ 759 ☐ 760 ☐ 761 ☐ 762 ☐ 763 ☐ 764 ☐ 765 ☐ 766 ☐ 767 ☐ 768 ☐ 769 ☐ 770 ☐ 771 ☐ 772 ☐ 773 ☐ 774 ☐ 775 ☐ 776 ☐ 777 ☐ 778 ☐ 779 ☐ 780 ☐ 781 ☐ 782 ☐ 783 ☐ 784 ☐ 785 ☐ 786 ☐ 787 ☐ 788 ☐ 789 ☐ 790 ☐ 791 ☐ 792 ☐ 793 ☐ 794 ☐ 795 ☐ 796 ☐ 797 ☐ 798 ☐ 799 ☐ 800 ☐ 801 ☐ 802 ☐ 803 ☐ 804 ☐ 805 ☐ 806 ☐ 807 ☐ 808 ☐ 809 ☐ 810 ☐ 811 ☐ 812 ☐ 813 ☐ 814 ☐ 815 ☐ 816 ☐ 817 ☐ 818 ☐ 819 ☐ 820 ☐ 821 ☐ 822 ☐ 823 ☐ 824 ☐ 825 ☐ 826 ☐ 827 ☐ 828 ☐ 829 ☐ 830 ☐ 831 ☐ 832 ☐ 833 ☐ 834 ☐ 835 ☐ 836 ☐ 837 ☐ 838 ☐ 839 ☐ 840 ☐ 841 ☐ 842 ☐ 843 ☐ 844 ☐ 845 ☐ 846 ☐ 847 ☐ 848 ☐ 849 ☐ 850 ☐ 851 ☐ 852 ☐ 853 ☐ 854 ☐ 855 ☐ 856 ☐ 857 ☐ 858 ☐ 859 ☐ 860 ☐ 861 ☐ 862 ☐ 863 ☐ 864 ☐ 865 ☐ 866 ☐ 867 ☐ 868 ☐ 869 ☐ 870 ☐ 871 ☐ 872 ☐ 873 ☐ 874 ☐ 875 ☐ 876 ☐ 877 ☐ 878 ☐ 879 ☐ 880 ☐ 881 ☐ 882 ☐ 883 ☐ 884 ☐ 885 ☐ 886 ☐ 887 ☐ 888 ☐ 889 ☐ 890 ☐ 891 ☐ 892 ☐ 893 ☐ 894 ☐ 895 ☐ 896 ☐ 897 ☐ 898 ☐ 899 ☐ 900 ☐ 901 ☐ 902 ☐ 903 ☐ 904 ☐ 905 ☐ 906 ☐ 907 ☐ 908 ☐ 909 ☐ 910 ☐ 911 ☐ 912 ☐ 913 ☐ 914 ☐ 915 ☐ 916 ☐ 917 ☐ 918 ☐ 919 ☐ 920 ☐ 921 ☐ 922 ☐ 923 ☐ 924 ☐ 925 ☐ 926 ☐ 927 ☐ 928 ☐ 929 ☐ 930 ☐ 931 ☐ 932 ☐ 933 ☐ 934 ☐ 935 ☐ 936 ☐ 937 ☐ 938 ☐ 939 ☐ 940 ☐ 941 ☐ 942 ☐ 943 ☐ 944 ☐ 945 ☐ 946 ☐ 947 ☐ 948 ☐ 949 ☐ 950 ☐ 951 ☐ 952 ☐ 953 ☐ 954 ☐ 955 ☐ 956 ☐ 957 ☐ 958 ☐ 959 ☐ 960 ☐ 961 ☐ 962 ☐ 963 ☐ 964 ☐ 965 ☐ 966 ☐ 967 ☐ 968 ☐ 969 ☐ 970 ☐ 971 ☐ 972 ☐ 973 ☐ 974 ☐ 975 ☐ 976 ☐ 977 ☐ 978 ☐ 979 ☐ 980 ☐ 981 ☐ 982 ☐ 983 ☐ 984 ☐ 985 ☐ 986 ☐ 987 ☐ 988 ☐ 989 ☐ 990 ☐ 991 ☐ 992 ☐ 993 ☐ 994 ☐ 995 ☐ 996 ☐ 997 ☐ 998 ☐ 999 ☐ 1000 ☐ 1001 ☐ 1002 ☐ 1003 ☐ 1004 ☐ 1005 ☐ 1006 ☐ 1007 ☐ 1008 ☐ 1009 ☐ 1010 ☐ 1011 ☐ 1012 ☐ 1013 ☐ 1014 ☐ 1015 ☐ 1016 ☐ 1017 ☐ 1018 ☐ 1019 ☐ 1020 ☐ 1021 ☐ 1022 ☐ 1023 ☐ 1024 ☐ 1025 ☐ 1026 ☐ 1027 ☐ 1028 ☐ 1029 ☐ 1030 ☐ 1031 ☐ 1032 ☐ 1033 ☐ 1034 ☐ 1035 ☐ 1036 ☐ 1037 ☐ 1038 ☐ 1039 ☐ 1040 ☐ 1041 ☐ 1042 ☐ 1043 ☐ 1044 ☐ 1045 ☐ 1046 ☐ 1047 ☐ 1048 ☐ 1049 ☐ 1050 ☐ 1051 ☐ 1052 ☐ 1053 ☐ 1054 ☐ 1055 ☐ 1056 ☐ 1057 ☐ 1058 ☐ 1059 ☐ 1060 ☐ 1061 ☐ 1062 ☐ 1063 ☐ 1064 ☐ 1065 ☐ 1066 ☐ 1067 ☐ 1068 ☐ 1069 ☐ 1070 ☐ 1071 ☐ 1072 ☐ 1073 ☐ 1074 ☐ 1075 ☐ 1076 ☐ 1077 ☐ 1078 ☐ 1079 ☐ 1080 ☐ 1081 ☐ 1082 ☐ 1083 ☐ 1084 ☐ 1085 ☐ 1086 ☐ 1087 ☐ 1088 ☐ 1089 ☐ 1090 ☐ 1091 ☐ 1092 ☐ 1093 ☐ 1094 ☐ 1095 ☐ 1096 ☐ 1097 ☐ 1098 ☐ 1099 ☐ 1100 ☐ 1101 ☐ 1102 ☐ 1103 ☐ 1104 ☐ 1105 ☐ 1106 ☐ 1107 ☐ 1108 ☐ 1109 ☐ 1110 ☐ 1111 ☐ 1112 ☐ 1113 ☐ 1114 ☐ 1115 ☐ 1116 ☐ 1117 ☐ 1118 ☐ 1119 ☐ 1120 ☐ 1121 ☐ 1122 ☐ 1123 ☐ 1124 ☐ 1125 ☐ 1126 ☐ 1127 ☐ 1128 ☐ 1129 ☐ 1130 ☐ 1131 ☐ 1132 ☐ 1133 ☐ 1134 ☐ 1135 ☐ 1136 ☐ 1137 ☐ 1138 ☐ 1139 ☐ 1140 ☐ 1141 ☐ 1142 ☐ 1143 ☐ 1144 ☐ 1145 ☐ 1146 ☐ 1147 ☐ 1148 ☐ 1149 ☐ 1150 ☐ 1151 ☐ 1152 ☐ 1153 ☐ 1154 ☐ 1155 ☐ 1156 ☐ 1157 ☐ 1158 ☐ 1159 ☐ 1160 ☐ 1161 ☐ 1162 ☐ 1163 ☐ 1164 ☐ 1165 ☐ 1166 ☐ 1167 ☐ 1168 ☐ 1169 ☐ 1170 ☐ 1171 ☐ 1172 ☐ 1173 ☐ 1174 ☐ 1175 ☐ 1176 ☐ 1177 ☐ 1178 ☐ 1179 ☐ 1180 ☐ 1181 ☐ 1182 ☐ 1183 ☐ 1184



NAPIT Electrical Installation Condition Report

Main Intake Inspection Schedule

For Installations above 100 A

Requirements for Electrical Installations – BS 7671:2018 (IET Wiring Regulations 18th Edition)

Only for the reporting on the condition of an existing installation.

NA/EICR 09386

Page 3 of 7

Schedule of Inspections - Outcomes

Acceptable condition: ✓	Unacceptable condition: State C1 or C2	Improvement recommended: C3	Further investigation: FI	Not verified: NV	Limitation: LIM	Not applicable: NA
----------------------------	---	--------------------------------	------------------------------	---------------------	--------------------	-----------------------

(In the outcome column use the codes above. Provide additional comment where appropriate. C1/C2/C3 and FI coded items to be recorded in section K of the condition report)

Item No.	Description (Where inadequacies in intake equipment are encountered, it is recommended that the person ordering the report informs the appropriate authority)	Outcome
1.0	EXTERNAL CONDITION OF INTAKE EQUIPMENT (VISUAL INSPECTION ONLY);	
1.1	Service cable	✓
1.2	Service head	✓
1.3	Earthing arrangement	✓
1.4	Meter tails	✓
1.5	Metering equipment	✓
1.6	Isolator (where present)	✓
2.0	PRESENCE OF ADEQUATE ARRANGEMENTS FOR PARALLEL OR SWITCHED ALTERNATIVE SOURCES	
2.1	Adequate arrangements where a generating set operates as a switched alternative to the public supply (551.6)	N/A
2.2	Adequate arrangements where a generating set operates in parallel with the public supply (551.7)	N/A
3.0	AUTOMATIC DISCONNECTION OF SUPPLY	
3.1	Main earthing/bonding arrangements (411.3; Chap 54)	
3.1.1	Presence of distributor's earthing arrangement (542.1.2.1; 542.1.2.2)	✓
3.1.2	Presence of installation earth electrode arrangement (542.1.2.3)	N/A
3.1.3	Adequacy of earthing conductor size (542.3; 543.1.1)	✓
3.1.4	Adequacy of earthing conductor connections (542.3.2)	✓
3.1.5	Accessibility of earthing conductor connections (543.3.2)	✓
3.1.6	Adequacy of main protective bonding conductor sizes (544.1)	✓
3.1.7	Adequacy and location of main protective bonding conductor connections (543.3.2; 544.1.2)	✓
3.1.8	Accessibility of all protective bonding connections (543.3.2)	✓
3.1.9	Provision of earthing/bonding labels at all appropriate locations (514.13)	✓
3.2	FELV - requirements satisfied (411.7; 411.7.1)	N/A
4.0	OTHER METHODS OF PROTECTION (WHERE ANY OF THE METHODS LISTED BELOW ARE EMPLOYED DETAILS SHOULD BE PROVIDED ON SEPARATE SHEETS)	
4.1	Non-conducting location (418.1)	N/A
4.2	Earth-free local equipotential bonding (418.2)	N/A
4.3	Electrical separation (Section 413; 418.3)	N/A
4.4	Double insulation (Section 412)	N/A
4.5	Reinforced insulation (Section 412)	N/A
5.0	DISTRIBUTION EQUIPMENT	
5.1	Adequacy of working space/accessibility to equipment (132.12; 513.1)	✓
5.2	Security of fixing (134.1.1)	✓
5.3	Condition of insulation of live parts (416.1)	✓
5.4	Adequacy/security of barriers (416.2)	✓
5.5	Condition of enclosure(s) in terms of IP rating etc (416.2)	✓
5.6	Condition of enclosure(s) in terms of fire rating etc. (421.1.6; 421.1.201; 526.5)	C3
5.7	Enclosure not damaged/deteriorated so as to impair safety (651.2)	✓
5.8	Presence and effectiveness of obstacles (417.2)	✓
5.9	Presence of main switch(es), linked where required (462.1; 462.1.201; 462.2)	✓
5.10	Operation of main switch(es) (functional check) (643.10)	✓
5.11	Manual operation of circuit-breakers and RCD(s) to prove disconnection (643.10)	✓
5.12	Confirmation that integral test button/switch causes RCD(s) to trip when operated (functional check) (643.10)	✓
5.13	RCD(s) provided for fault protection – includes RCBO(s) (411.4.204; 411.5.2; 531.2)	C3
5.14	RCD(s) provided for additional protection / requirements, where required - includes RCBO(s) (411.3.3; 415.1)	C3
5.15	Presence of RCD six-monthly test notice at or near equipment, where required (514.12.2)	✓
5.16	Presence of diagrams, charts or schedules at or near equipment, where required (514.9.1)	✓
5.17	Presence of non-standard (mixed) cable colour warning notice at or near equipment, where required (514.14)	✓
5.18	Presence of alternative supply warning notice at or near equipment, where required (514.15)	✓
5.19	Presence of next inspection recommendation label (514.12.1)	✓
5.20	Presence of other required labelling (please specify) (Section 514)	✓
5.21	Compatibility of protective devices, bases and other components; correct type and rating (no signs of unacceptable thermal damage, arcing or overheating) (411.3.2; 411.4; 411.5; 411.6; Sections 432; 433)	✓
5.22	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)	✓

NAPIT Electrical Installation Condition Report

Main Intake Inspection Schedule

For Installations above 100 A

Requirements for Electrical Installations – BS 7671:2018 (IET Wiring Regulations 18th Edition)

Only for the reporting on the condition of an existing installation.

NA/EICR 09386

Page 4 of 7

Schedule of Inspections - Outcomes

Acceptable condition: ✓	Unacceptable condition: State C1 or C2	Improvement recommended: C3	Further investigation: FI	Not verified: NV	Limitation: LIM	Not applicable: NA
----------------------------	---	--------------------------------	------------------------------	---------------------	--------------------	-----------------------

(In the outcome column use the codes above. Provide additional comment where appropriate. C1/C2/C3 and FI coded items to be recorded in section K of the condition report)

Item No.	Description	Outcome
5.0	DISTRIBUTION EQUIPMENT CONT.	
5.23	Protection against mechanical damage where cables enter equipment (522.8.1; 522.8.5; 522.8.11)	N/A
5.24	Protection against electromagnetic effects where cables enter ferromagnetic enclosures (521.5.1)	N/A
6.0	DISTRIBUTION CIRCUITS	
6.1	Identification of conductors (514.3.1)	✓
6.2	Cables correctly supported throughout their run (521.10.202; 522.8.5)	N/V
6.3	Condition of insulation of live parts (416.1)	✓
6.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking. (521.10.1)	N/V
6.5	Suitability of containment systems for continued use (including flexible conduit) (Section 522)	✓
6.6	Cables correctly terminated in enclosures (Section 526)	✓
6.7	Confirmation that ALL conductor connections, including connections to busbars, are correctly located in terminals and are tight and secure (526.1)	✓
6.8	Examination of cables for signs of unacceptable thermal or mechanical damage/deterioration (421.1; 522.6)	✓
6.9	Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523)	✓
6.10	Adequacy of protective devices: type and rated current for fault protection (411.3)	✓
6.11	Presence and adequacy of circuit protective conductors (411.3.1.1; 543.1)	✓
6.12	Coordination between conductors and overload protective devices (433.1; 533.2.1)	✓
6.13	Cable installation methods/practices with regard to the type and nature of installation and external influences (Section 522)	✓
6.14	Where exposed to direct sunlight, cable of a suitable type (522.11.1)	N/A
6.15	CABLES CONCEALED UNDER FLOORS, ABOVE CEILINGS, IN WALLS/PARTITIONS LESS THAN 50 MM FROM A SURFACE, AND IN PARTITIONS CONTAINING METAL PARTS	
6.15.1	Installed in prescribed zones (see Section D. Extent and limitations) (522.6.202)	C3
6.15.2	Incorporating earthed armour or sheath, or run within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the like (see Section D. Extent and limitations) (522.6.204)	N/A
6.16	Provision of fire barriers, sealing arrangements and protection against thermal effects (Section 527)	✓
6.17	Band II cables segregated/separated from Band I cables (528.1)	N/V
6.18	Cables segregated/separated from non-electrical services (528.3)	N/V
6.19	Condition of circuit accessories (651.2)	✓
6.20	Suitability of circuit accessories for external influences (512.2)	✓
6.21	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)	✓
6.22	Adequacy of connections, including cpc's, within accessories and to fixed and stationary equipment – identify/ record numbers and locations of items inspected (Section 526)	✓
6.23	Presence, operation and correct location of appropriate devices for isolation and switching (Chapter 46; Section 537)	✓
6.24	General condition of wiring systems (651.2)	✓
6.25	Temperature rating of cable insulation (522.1.1; Table 52.1)	N/V
7.0	SCHEDULE OF TESTS (RESULTS TO BE RECORDED ON SCHEDULE(S) OF TEST RESULT)	
7.1	External earth loop impedance, Z_e	✓
7.2	Installation earth electrode R_A	N/A
7.3	Prospective fault current I_{pf}	✓
7.4	Continuity of Earthing conductors	✓
7.5	Continuity of circuit protective conductors	✓
7.6	Continuity of ring final circuit conductors	✓
7.7	Continuity of protective bonding conductors	✓
7.8	Volt drop verified	✓
7.9	Insulation Resistance between Live conductors	✓
7.10	Insulation Resistance between Live conductors and Earth	✓
7.11	Polarity (prior to energisation)	✓
7.12	Polarity (after energisation) including phase sequence	✓
7.13	Earth fault loop impedance	✓
7.14	RCD(s)/RCBO(s) including selectivity	✓
7.15	Functional testing of RCD(s)	C3
7.16	Functional testing of AFDD(s)	N/A

Inspector's Name: P. Boulton

Date: 6th MARCH 2023

Signature:

P. Boulton



NAPIT Electrical Installation Condition Report Distribution Board Inspection Schedule

For Installations above 100 A

Requirements for Electrical Installations – BS 7671:2018 (IET Wiring Regulations 18th Edition)

Only for the reporting on the condition of an existing installation.

NA/EICR 09386

Page 5 of 7

Schedule of Inspections - Outcomes

Acceptable condition: ✓	Unacceptable condition: State C1 or C2	Improvement recommended: C3	Further investigation: FI	Not verified: NV	Limitation: LIM	Not applicable: NA
----------------------------	---	--------------------------------	------------------------------	---------------------	--------------------	-----------------------

(In the outcome column use the codes above. Provide additional comment where appropriate. C1/C2/C3 and FI coded items to be recorded in section K of the condition report)

Item No.	Description	Outcome
1.0	CONSUMER UNIT/DISTRIBUTION BOARD	
1.1	Adequacy of working space / accessibility to consumer unit/distribution board (132.12; 513.1)	✓
1.2	Security of fixing (134.1.1)	✓
1.3	Condition of enclosure(s) in terms of IP rating (barriers etc.)(416.2)	✓
1.4	Condition of enclosure(s) in terms of fire rating etc (421.1.6; 421.1.201; 526.5)	C3
1.5	Enclosure not damaged/deteriorated so as to impair safety (651.2)	✓
1.5.1	Presence and effectiveness of obstacles (417.2)	✓
1.6	Presence of main switch(es), linked where required (462.1; 462.1.201; 462.2)	✓
1.7	Operation of main switch(es) (functional check) (643.10)	✓
1.8	Manual operation of circuit-breakers and RCD(s) (test button) to prove disconnection (643.10)	✓
1.9	Correct identification of circuit details and protective devices (514.8.1; 514.9.1)	✓
1.10	Presence of RCD six-monthly test notice at or near equipment, where required (514.12.2)	✓
1.11	Presence of non-standard (mixed) cable colour warning notice at or near equipment, where required (514.14)	✓
1.12	Presence of alternative supply warning notice at or near consumer unit/distribution board (514.15)	✓
1.13	Presence of other required labelling (Please specify) Section 514	✓
1.14	Compatibility of protective devices, bases and other components; correct type and rating (no signs of unacceptable thermal damage, arcing or overheating) (411.3.2; 411.4; 411.5; 411.6; Sections 432; 433)	✓
1.15	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)	✓
1.16	Protection against mechanical damage where cables enter distribution board (522.8.1; 522.8.5; 522.8.11)	✓
1.17	Protection against electromagnetic effects where cables enter distribution board (521.5.1)	✓
1.18	RCD(s) provided for fault protection – includes RCBO(s)(411.4.204; 411.5.2; 531.2)	C3
1.19	RCD(s) provided for additional protection/requirements, where required - includes RCBO(s) (411.3.3; 415.1)	C3
1.20	Confirmation of indication that SPD is functional (651.4)	C3
1.21	Confirmation that ALL conductor connections, including connections to busbars, are correctly located in terminals and are tight and secure (526.1)	✓
1.22	Adequate arrangements where a generating set operates as a switched alternative to public supply (551.6)	N/A
1.23	Adequate arrangements where a generating set operates in parallel with public supply (551.7)	N/A
2.0	FINAL CIRCUITS	
2.1	Identification of conductors (514.3.1)	✓
2.2	Cables correctly supported throughout their run (521.10.202; 522.8.5)	N/A
2.3	Condition of insulation of live parts (416.1)	✓
2.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking. (521.10.1)	N/A
2.4.1	To include the integrity of conduit and trunking systems (metallic and plastic)	✓
2.5	Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523)	✓
2.6	Coordination between conductors and overload protective devices (433.1; 533.2.1)	✓
2.7	Adequacy of protective devices: type and rated current for fault protection (411.3)	✓
2.8	Presence and adequacy of circuit protective conductors (411.3.1.1; 543.1)	✓
2.9	Wiring system(s) appropriate for the type and nature of the installation and external influences (Section 522)	✓
2.10	Concealed cables installed in prescribed zones (see Section D. Extent of limitations) (522.6.202)	N/A
2.11	Cables Concealed Under Floors, Above Ceilings Or In Walls/ Partitions, Adequately Protected Against Damage (522.3.201, 202, 203, 204)	N/A
2.12	PROVISION OF ADDITIONAL PROTECTION/REQUIREMENTS BY 30 mA RCD Note: Older installations designed prior to BS 7671:2018 may not have been provided with RCDs for additional protection.	
2.12.1	For all socket-outlets of rating 32 A or less unless exempt (411.3.3)	✓
2.12.2	For the supply of mobile equipment not exceeding 32 A rating for use outdoors (411.3.3)	✓
2.12.3	For cables concealed in walls at a depth of less than 50 mm (522.6.202; 522.6.203)	C3
2.12.4	For cables concealed in walls/partitions containing metal parts regardless of depth (522.6.203)	C3
2.12.5	Final circuits supplying luminaries within domestic (household) premises (411.3.4)	C3
2.13	Provision of fire barriers, sealing arrangements and protection against thermal effects (Section 527)	✓



NAPIT Electrical Installation Condition Report Distribution Board Inspection Schedule

For Installations above 100 A

Requirements for Electrical Installations – BS 7671:2018 (IET Wiring Regulations 18th Edition)

Only for the reporting on the condition of an existing installation.

NA/EICR 09386

Page 6 of 7

Schedule of Inspections - Outcomes

Acceptable condition:	Unacceptable condition: State	Improvement recommended:	Further investigation:	Not verified:	Limitation:	Not applicable:
✓	C1 or C2	C3	FI	NV	LIM	NA

(In the outcome column use the codes above. Provide additional comment where appropriate. C1/C2/C3 and FI coded items to be recorded in section K of the condition report)

Item No.	Description	Outcome
2.0	FINAL CIRCUITS CONT.	
2.14	Band II cables segregated/separated from Band I cables (528.1)	N/V
2.15	Cables segregated/separated from communications cabling (528.2)	N/V
2.16	Cables segregated/separated from non-electrical services (528.3)	N/V
2.17	Terminations of cables at enclosures - indicate extent of sampling in Section D of the report (Section 526)	✓
2.17.1	Connection soundly made and under no undue strain (526.6)	✓
2.17.2	No basic insulation of a conductor visible outside enclosure (526.8)	✓
2.17.3	Connections of live conductors adequately enclosed (526.5)	✓
2.17.4	Adequately connected at point of entry to enclosure (glands, bushes etc.) (522.8.5)	✓
2.18	Condition of accessories including socket-outlets, switches and joint boxes (651.2 (v))	✓
2.19	Suitability of accessories for external influences (512.2)	✓
2.20	Adequacy of working space/accessibility to equipment (132.12; 513.1)	✓
2.21	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)	✓
3.0	ISOLATION AND SWITCHING	
3.1	ISOLATOR (SECTIONS 460; 537)	
3.1.1	Presence and condition of appropriate devices (Section 462; 537.2.7)	✓
3.1.2	Acceptable location – state if local or remote from equipment in question (Section 462; 537.2.7)	✓
3.1.3	Capable of being secured in the OFF position (462.3)	✓
3.1.4	Correct operation verified (643.10)	✓
3.1.5	Clearly identified by position and/or durable marking (537.2.6)	✓
3.1.6	Warning label posted in situations where live parts cannot be isolated by the operation of a single device (514.11.1; 537.1.2)	✓
3.2	SWITCHING OFF FOR MECHANICAL MAINTENANCE (SECTION 464; 537.3.2)	
3.2.1	Presence and condition of appropriate devices (464.1; 527.3.2)	✓
3.2.2	Acceptable location – state if local or remote from equipment in question (537.3.2.4)	✓
3.2.3	Capable of being secured in the OFF position (462.3)	✓
3.2.4	Correct operation verified (643.10)	✓
3.2.5	Clearly identified by position and/or durable marking (537.3.2.4)	✓
3.3	EMERGENCY SWITCHING/STOPPING (SECTION 465; 537.3.3)	
3.3.1	Presence and condition of appropriate devices (Section 465; 537.3.3; 537.4)	N/A
3.3.2	Readily accessible for operation where danger might occur (537.3.3.6)	N/A
3.3.3	Correct operation verified (643.10)	N/A
3.3.4	Clearly identified by position and/or durable marking (537.3.3.6)	N/A
3.4	FUNCTIONAL SWITCHING (SECTION 463; 537.3.1)	
3.4.1	Presence and condition of appropriate devices (537.3.1.1; 537.3.1.2)	✓
3.4.2	Correct operation verified (537.3.1.1; 537.3.1.2)	✓
4.0	CURRENT-USING EQUIPMENT (PERMANENTLY CONNECTED)	
4.1	Condition of equipment in terms of IP rating etc (416.2)	✓
4.2	Equipment does not constitute a fire hazard (Section 421)	C3
4.3	Enclosure not damaged/deteriorated so as to impair safety (134.1.1; 416.2; 512.2)	✓
4.4	Suitability for the environment and external influences (512.2)	✓
4.5	Security of fixing (134.1.1)	✓
4.6	Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire: List number and location of luminaires inspected (separate page) (527.2)	✓
4.7	RECESSED LUMINAIRES (DOWNLIGHTERS)	
4.7.1	Correct type of lamps fitted (559.3.1)	✓
4.7.2	Installed to minimize build-up of heat by use of "fire rated" fittings, insulation displacement box or similar (421.1.2)	✓
4.7.3	No signs of overheating to surrounding building fabric (559.4.1)	✓
4.7.4	No signs of overheating to conductors/terminations (526.1)	✓
5.0	PART 7 SPECIAL INSTALLATIONS OR LOCATIONS	
5.1	If any special installations or locations are present, list the particular inspections applied.	✓

Inspector's Name: P. Boulton

Date: 6th MARCH 2023

Signature:

P. Boulton



NAPIT Electrical Installation Test Schedule

Requirements for Electrical Installations – BS 7671:2018 (IET Wiring Regulations 18th Edition)

NA/EICR 09386

Page 7 of 7

Client **MANNES PARTINGTON** Installation address **A HESINGTON MESS, YORK**

Complete in every case

Location of distribution board **KITCHEN**
Distribution board designation **HOUSE**
Number of ways **12WAYS**

Complete only if the distribution board is not connected directly to the origin of the installation

Supply to DB is from **—**
Overcurrent protective device for the distribution circuit: Type BS(EN) **—** Rating **—** A
Supply polarity confirmed **—** Phase sequence confirmed **—**

Characteristics at this distribution board

No. of poles **—**
Time Delay (if applicable) **—** ms
Zob **—** Ω
Ipf **—** kA

Postcode **YO10 5BT**

Test instrument serial number(s)

Loop imped. **05123663**
Insulation resistance **05123663**
Continuity **05123663**
RCD **05123663**

CIRCUIT DETAILS

Circuit No. and line No.	Circuit designation	Type of wiring	Ref. method	No. of points served	Circuit conductor csa		Maximum disconnection time (BS 7671)	Overcurrent protective devices				RCD operating current I _{Δn} (mA)	BS 7671 Max. permitted value Z _s Other Z _s %	Circuit impedance Ω						Insulation resistance (Record lower reading)		Polarity	Max. measured Z _s (Ω)	RCD testing		Manual test button operation																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																												
					L/N (mm ²)	CPC (mm ²)		BS EN Number	Type No.	Rating (A)	Breaking Capacity (kA)			Fig 8 check	All circuits to be completed using R ₁ , R ₂ or R ₃ , not both	Test Voltage V	L/L L/N (MΩ)	L/E N/E (MΩ)	Above 30mA I _{Δn} ms	30mA or below 5 I _{Δn} ms																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																		
r ₁	r ₂	r ₃	r ₄	r ₅	r ₆	r ₇	r ₈	r ₉	r ₁₀	r ₁₁	r ₁₂	r ₁₃	r ₁₄	r ₁₅	r ₁₆	r ₁₇	r ₁₈	r ₁₉	r ₂₀	r ₂₁	r ₂₂	r ₂₃	r ₂₄	r ₂₅	r ₂₆	r ₂₇	r ₂₈	r ₂₉	r ₃₀	r ₃₁	r ₃₂	r ₃₃	r ₃₄	r ₃₅	r ₃₆	r ₃₇	r ₃₈	r ₃₉	r ₄₀	r ₄₁	r ₄₂	r ₄₃	r ₄₄	r ₄₅	r ₄₆	r ₄₇	r ₄₈	r ₄₉	r ₅₀	r ₅₁	r ₅₂	r ₅₃	r ₅₄	r ₅₅	r ₅₆	r ₅₇	r ₅₈	r ₅₉	r ₆₀	r ₆₁	r ₆₂	r ₆₃	r ₆₄	r ₆₅	r ₆₆	r ₆₇	r ₆₈	r ₆₉	r ₇₀	r ₇₁	r ₇₂	r ₇₃	r ₇₄	r ₇₅	r ₇₆	r ₇₇	r ₇₈	r ₇₉	r ₈₀	r ₈₁	r ₈₂	r ₈₃	r ₈₄	r ₈₅	r ₈₆	r ₈₇	r ₈₈	r ₈₉	r ₉₀	r ₉₁	r ₉₂	r ₉₃	r ₉₄	r ₉₅	r ₉₆	r ₉₇	r ₉₈	r ₉₉	r ₁₀₀	r ₁₀₁	r ₁₀₂	r ₁₀₃	r ₁₀₄	r ₁₀₅	r ₁₀₆	r ₁₀₇	r ₁₀₈	r ₁₀₉	r ₁₁₀	r ₁₁₁	r ₁₁₂	r ₁₁₃	r ₁₁₄	r ₁₁₅	r ₁₁₆	r ₁₁₇	r ₁₁₈	r ₁₁₉	r ₁₂₀	r ₁₂₁	r ₁₂₂	r ₁₂₃	r ₁₂₄	r ₁₂₅	r ₁₂₆	r ₁₂₇	r ₁₂₈	r ₁₂₉	r ₁₃₀	r ₁₃₁	r ₁₃₂	r ₁₃₃	r ₁₃₄	r ₁₃₅	r ₁₃₆	r ₁₃₇	r ₁₃₈	r ₁₃₉	r ₁₄₀	r ₁₄₁	r ₁₄₂	r ₁₄₃	r ₁₄₄	r ₁₄₅	r ₁₄₆	r ₁₄₇	r ₁₄₈	r ₁₄₉	r ₁₅₀	r ₁₅₁	r ₁₅₂	r ₁₅₃	r ₁₅₄	r ₁₅₅	r ₁₅₆	r ₁₅₇	r ₁₅₈	r ₁₅₉	r ₁₆₀	r ₁₆₁	r ₁₆₂	r ₁₆₃	r ₁₆₄	r ₁₆₅	r ₁₆₆	r ₁₆₇	r ₁₆₈	r ₁₆₉	r ₁₇₀	r ₁₇₁	r ₁₇₂	r ₁₇₃	r ₁₇₄	r ₁₇₅	r ₁₇₆	r ₁₇₇	r ₁₇₈	r ₁₇₉	r ₁₈₀	r ₁₈₁	r ₁₈₂	r ₁₈₃	r ₁₈₄	r ₁₈₅	r ₁₈₆	r ₁₈₇	r ₁₈₈	r ₁₈₉	r ₁₉₀	r ₁₉₁	r ₁₉₂	r ₁₉₃	r ₁₉₄	r ₁₉₅	r ₁₉₆	r ₁₉₇	r ₁₉₈	r ₁₉₉	r ₂₀₀	r ₂₀₁	r ₂₀₂	r ₂₀₃	r ₂₀₄	r ₂₀₅	r ₂₀₆	r ₂₀₇	r ₂₀₈	r ₂₀₉	r ₂₁₀	r ₂₁₁	r ₂₁₂	r ₂₁₃	r ₂₁₄	r ₂₁₅	r ₂₁₆	r ₂₁₇	r ₂₁₈	r ₂₁₉	r ₂₂₀	r ₂₂₁	r ₂₂₂	r ₂₂₃	r ₂₂₄	r ₂₂₅	r ₂₂₆	r ₂₂₇	r ₂₂₈	r ₂₂₉	r ₂₃₀	r ₂₃₁	r ₂₃₂	r ₂₃₃	r ₂₃₄	r ₂₃₅	r ₂₃₆	r ₂₃₇	r ₂₃₈	r ₂₃₉	r ₂₄₀	r ₂₄₁	r ₂₄₂	r ₂₄₃	r ₂₄₄	r ₂₄₅	r ₂₄₆	r ₂₄₇	r ₂₄₈	r ₂₄₉	r ₂₅₀	r ₂₅₁	r ₂₅₂	r ₂₅₃	r ₂₅₄	r ₂₅₅	r ₂₅₆	r ₂₅₇	r ₂₅₈	r ₂₅₉	r ₂₆₀	r ₂₆₁	r ₂₆₂	r ₂₆₃	r ₂₆₄	r ₂₆₅	r ₂₆₆	r ₂₆₇	r ₂₆₈	r ₂₆₉	r ₂₇₀	r ₂₇₁	r ₂₇₂	r ₂₇₃	r ₂₇₄	r ₂₇₅	r ₂₇₆	r ₂₇₇	r ₂₇₈	r ₂₇₉	r ₂₈₀	r ₂₈₁	r ₂₈₂	r ₂₈₃	r ₂₈₄	r ₂₈₅	r ₂₈₆	r ₂₈₇	r ₂₈₈	r ₂₈₉	r ₂₉₀	r ₂₉₁	r ₂₉₂	r ₂₉₃	r ₂₉₄	r ₂₉₅	r ₂₉₆	r ₂₉₇	r ₂₉₈	r ₂₉₉	r ₃₀₀	r ₃₀₁	r ₃₀₂	r ₃₀₃	r ₃₀₄	r ₃₀₅	r ₃₀₆	r ₃₀₇	r ₃₀₈	r ₃₀₉	r ₃₁₀	r ₃₁₁	r ₃₁₂	r ₃₁₃	r ₃₁₄	r ₃₁₅	r ₃₁₆	r ₃₁₇	r ₃₁₈	r ₃₁₉	r ₃₂₀	r ₃₂₁	r ₃₂₂	r ₃₂₃	r ₃₂₄	r ₃₂₅	r ₃₂₆	r ₃₂₇	r ₃₂₈	r ₃₂₉	r ₃₃₀	r ₃₃₁	r ₃₃₂	r ₃₃₃	r ₃₃₄	r ₃₃₅	r ₃₃₆	r ₃₃₇	r ₃₃₈	r ₃₃₉	r ₃₄₀	r ₃₄₁	r ₃₄₂	r ₃₄₃	r ₃₄₄	r ₃₄₅	r ₃₄₆	r ₃₄₇	r ₃₄₈	r ₃₄₉	r ₃₅₀	r ₃₅₁	r ₃₅₂	r ₃₅₃	r ₃₅₄	r ₃₅₅	r ₃₅₆	r ₃₅₇	r ₃₅₈	r ₃₅₉	r ₃₆₀	r ₃₆₁	r ₃₆₂	r ₃₆₃	r ₃₆₄	r ₃₆₅	r ₃₆₆	r ₃₆₇	r ₃₆₈	r ₃₆₉	r ₃₇₀	r ₃₇₁	r ₃₇₂	r ₃₇₃	r ₃₇₄	r ₃₇₅	r ₃₇₆	r ₃₇₇	r ₃₇₈	r ₃₇₉	r ₃₈₀	r ₃₈₁	r ₃₈₂	r ₃₈₃	r ₃₈₄	r ₃₈₅	r ₃₈₆	r ₃₈₇	r ₃₈₈	r ₃₈₉	r ₃₉₀	r ₃₉₁	r ₃₉₂	r ₃₉₃	r ₃₉₄	r ₃₉₅	r ₃₉₆	r ₃₉₇	r ₃₉₈	r ₃₉₉	r ₄₀₀	r ₄₀₁	r ₄₀₂	r ₄₀₃	r ₄₀₄	r ₄₀₅	r ₄₀₆	r ₄₀₇	r ₄₀₈	r ₄₀₉	r ₄₁₀	r ₄₁₁	r ₄₁₂	r ₄₁₃	r ₄₁₄	r ₄₁₅	r ₄₁₆	r ₄₁₇	r ₄₁₈	r ₄₁₉	r ₄₂₀	r ₄₂₁	r ₄₂₂	r ₄₂₃	r ₄₂₄	r ₄₂₅	r ₄₂₆	r ₄₂₇	r ₄₂₈	r ₄₂₉	r ₄₃₀	r ₄₃₁	r ₄₃₂	r ₄₃₃	r ₄₃₄	r ₄₃₅	r ₄₃₆	r ₄₃₇	r ₄₃₈	r ₄₃₉	r ₄₄₀	r ₄₄₁	r ₄₄₂	r ₄₄₃	r ₄₄₄	r ₄₄₅	r ₄₄₆	r ₄₄₇	r ₄₄₈	r ₄₄₉	r ₄₅₀	r ₄₅₁	r ₄₅₂	r ₄₅₃	r ₄₅₄	r ₄₅₅	r ₄₅₆	r ₄₅₇	r ₄₅₈	r ₄₅₉	r ₄₆₀	r ₄₆₁	r ₄₆₂	r ₄₆₃	r ₄₆₄	r ₄₆₅	r ₄₆₆	r ₄₆₇	r ₄₆₈	r ₄₆₉	r ₄₇₀	r ₄₇₁	r ₄₇₂	r ₄₇₃	r ₄₇₄	r ₄₇₅	r ₄₇₆	r ₄₇₇	r ₄₇₈	r ₄₇₉	r ₄₈₀	r ₄₈₁	r ₄₈₂	r ₄₈₃	r ₄₈₄	r ₄₈₅	r ₄₈₆	r ₄₈₇	r ₄₈₈	r ₄₈₉	r ₄₉₀	r ₄₉₁	r ₄₉₂	r ₄₉₃	r ₄₉₄	r ₄₉₅	r ₄₉₆	r ₄₉₇	r ₄₉₈	r ₄₉₉	r ₅₀₀	r ₅₀₁	r ₅₀₂	r ₅₀₃	r ₅₀₄	r ₅₀₅	r ₅₀₆	r ₅₀₇	r ₅₀₈	r ₅₀₉	r ₅₁₀	r ₅₁₁	r ₅₁₂	r ₅₁₃	r ₅₁₄	r ₅₁₅	r ₅₁₆	r ₅₁₇	r ₅₁₈	r ₅₁₉	r ₅₂₀	r ₅₂₁	r ₅₂₂	r ₅₂₃	r ₅₂₄	r ₅₂₅	r ₅₂₆	r ₅₂₇	r ₅₂₈	r ₅₂₉	r ₅₃₀	r ₅₃₁	r ₅₃₂	r ₅₃₃	r ₅₃₄	r ₅₃₅	r ₅₃₆	r ₅₃₇	r ₅₃₈	r ₅₃₉	r ₅₄₀	r ₅₄₁	r ₅₄₂	r ₅₄₃	r ₅₄₄	r ₅₄₅	r ₅₄₆	r ₅₄₇	r ₅₄₈	r ₅₄₉	r ₅₅₀	r ₅₅₁	r ₅₅₂	r ₅₅₃	r ₅₅₄	r ₅₅₅	r ₅₅₆	r ₅₅₇	r ₅₅₈	r ₅₅₉	r ₅₆₀	r ₅₆₁	r ₅₆₂	r ₅₆₃	r ₅₆₄	r ₅₆₅	r ₅₆₆	r ₅₆₇	r ₅₆₈	r ₅₆₉	r ₅₇₀	r ₅₇₁	r ₅₇₂	r ₅₇₃	r ₅₇₄	r ₅₇₅	r ₅₇₆	r ₅₇₇	r ₅₇₈	r ₅₇₉	r ₅₈₀	r ₅₈₁	r ₅₈₂	r ₅₈₃	r ₅₈₄	r ₅₈₅	r ₅₈₆	r ₅₈₇	r ₅₈₈	r ₅₈₉	r ₅₉₀	r ₅₉₁	r ₅₉₂	r ₅₉₃	r ₅₉₄	r ₅₉₅	r ₅₉₆	r ₅₉₇	r ₅₉₈	r ₅₉₉	r ₆₀₀	r ₆₀₁	r ₆₀₂	r ₆₀₃	r ₆₀₄	r ₆₀₅	r ₆₀₆	r ₆₀₇	r ₆₀₈	r ₆₀₉	r ₆₁₀	r ₆₁₁	r ₆₁₂	r ₆₁₃	r ₆₁₄	r ₆₁₅	r ₆₁₆	r ₆₁₇	r ₆₁₈	r ₆₁₉	r ₆₂₀	r ₆₂₁	r ₆₂₂	r ₆₂₃	r ₆₂₄	r ₆₂₅	r ₆₂₆	r ₆₂₇	r ₆₂₈	r ₆₂₉	r ₆₃₀	r ₆₃₁	r ₆₃₂	r ₆₃₃	r ₆₃₄	r ₆₃₅	r ₆₃₆	r ₆₃₇	r ₆₃₈	r ₆₃₉	r ₆₄₀	r ₆₄₁	r ₆₄₂	r ₆₄₃	r ₆₄₄	r ₆₄₅	r ₆₄₆	r ₆₄₇	r ₆₄₈	r ₆₄₉	r ₆₅₀	r ₆₅₁	r ₆₅₂	r ₆₅₃	r ₆₅₄	r ₆₅₅	r ₆₅₆	r ₆₅₇	r ₆₅₈	r ₆₅₉	r ₆₆₀	r ₆₆₁	r ₆₆₂	r ₆₆₃	r ₆₆₄	r ₆₆₅	r ₆₆₆	r ₆₆₇	r ₆₆₈	r ₆₆₉	r ₆₇₀	r ₆₇₁	r ₆₇₂	r ₆₇₃	r ₆₇₄	r ₆₇₅	r ₆₇₆	r ₆₇₇	r ₆₇₈	r ₆₇₉	r ₆₈₀	r ₆₈₁	r ₆₈₂	r ₆₈₃	r ₆₈₄	r ₆₈₅	r ₆₈₆	r ₆₈₇	r ₆₈₈	r ₆₈₉	r ₆₉₀	r ₆₉₁	r ₆₉₂	r ₆₉₃	r ₆₉₄	r ₆₉₅	r ₆₉₆	r ₆₉₇	r ₆₉₈	r ₆₉₉	r ₇₀₀	r ₇₀₁	r ₇₀₂	r ₇₀₃	r ₇₀₄	r ₇₀₅	r ₇₀₆	r ₇₀₇	r ₇₀₈	r ₇₀₉	r ₇₁₀	r ₇₁₁	r ₇₁₂	r ₇₁₃	r ₇₁₄	r ₇₁₅	r ₇₁₆	r ₇₁₇	r ₇₁₈	r ₇₁₉	r ₇₂₀	r ₇₂₁	r ₇₂₂	r ₇₂₃	r ₇₂₄	r ₇₂₅	r ₇₂₆	r ₇₂₇	r ₇₂₈	r ₇₂₉	r ₇₃₀	r ₇₃₁	r ₇₃₂	r ₇₃₃	r ₇₃₄	r ₇₃₅	r ₇₃₆	r ₇₃₇	r ₇₃₈	r ₇₃₉	r ₇₄₀	r ₇₄₁	r ₇₄₂	r ₇₄₃	r ₇₄₄	r ₇₄₅	r ₇₄₆	r ₇₄₇	r ₇₄₈	r ₇₄₉	r ₇₅₀	r ₇₅₁	r ₇₅₂	r ₇₅₃	r ₇₅₄	r ₇₅₅	r ₇₅₆	r ₇₅₇	r ₇₅₈	r ₇₅₉	r ₇₆₀	r ₇₆₁	r ₇₆₂	r ₇₆₃	r ₇₆₄	r ₇₆₅	r ₇₆₆	r ₇₆₇	r ₇₆₈	r ₇₆₉	r ₇₇₀	r ₇₇₁	r ₇₇₂	r ₇₇₃	r ₇₇₄	r ₇₇₅	r ₇₇₆	r ₇₇₇	r ₇₇₈	r ₇₇₉	r ₇₈₀	r ₇₈₁	r ₇₈₂	r ₇₈₃	r ₇₈₄	r ₇₈₅	r ₇₈₆	r ₇₈₇	r ₇₈₈	r ₇₈₉	r ₇₉₀	r ₇₉₁	r ₇₉₂	r ₇₉₃	r ₇₉₄	r ₇₉₅	r ₇₉₆	r ₇₉₇	r ₇₉₈	r ₇₉₉	r ₈₀₀	r ₈₀₁	r ₈₀₂	r ₈₀₃	r ₈₀₄	r ₈₀₅	r ₈₀₆	r ₈₀₇	r ₈₀₈	r ₈₀₉	r ₈₁₀	r ₈₁₁	r ₈₁₂	r ₈₁₃	r ₈₁₄	r ₈₁₅	r ₈₁₆	r ₈₁₇	r ₈₁₈	r ₈₁₉	r ₈₂₀	r ₈₂₁	r ₈₂₂	r ₈₂₃	r ₈₂₄	r ₈₂₅	r ₈₂₆	r ₈₂₇	r ₈₂₈	r ₈₂₉	r ₈₃₀	r ₈₃₁	r ₈₃₂	r ₈₃₃	r ₈₃₄	r ₈₃₅	r ₈₃₆	r ₈₃₇	r ₈₃₈	r ₈₃₉	r ₈₄₀	r ₈₄₁	r ₈₄₂	r ₈₄₃	r ₈₄₄	r ₈₄₅	r ₈₄₆	r ₈₄₇	r ₈₄₈	r ₈₄₉	r ₈₅₀	r ₈₅₁	r ₈₅₂	r ₈₅₃	r ₈₅₄	r ₈₅₅	r ₈₅₆	r ₈₅₇	r ₈₅₈	r ₈₅₉	r ₈₆₀	r ₈₆₁	r ₈₆₂	r ₈₆₃	r ₈₆₄	r ₈₆₅	r ₈₆₆	r ₈₆₇	r ₈₆₈	r ₈₆₉	r ₈₇₀	r ₈₇₁	r ₈₇₂	r ₈₇₃	r ₈₇₄	r ₈₇₅	r ₈₇₆	r ₈₇₇	r ₈₇₈	r ₈₇₉	r ₈₈₀	r ₈₈₁	r ₈₈₂	r ₈₈₃	r ₈₈₄	r ₈₈₅	r ₈₈₆	r ₈₈₇	r ₈₈₈	r ₈₈₉	r ₈₉₀	r ₈₉₁	r ₈₉₂	r ₈₉₃	r ₈₉₄	r ₈₉₅	r ₈₉₆	r ₈₉₇	r ₈₉₈	r ₈₉₉	r ₉₀₀	r ₉₀₁	r ₉₀₂	r ₉₀₃	r ₉₀₄	r ₉₀₅	r ₉₀₆	r ₉₀₇	r ₉₀₈	r ₉₀₉	r ₉₁₀	r ₉₁₁	r ₉₁₂	r ₉₁₃	r ₉₁₄	r ₉₁₅	r ₉₁₆	r ₉₁₇	r ₉₁₈	r ₉

Details of Circuits and/or installed equipment vulnerable to damage when testing

Date(s) dead testing

6th MARCH 2023

Date(s) live testing

6th March 2023

Boiler, Portable Appliances, Fixed Appliances, LED Lamps, Electronic Equipment

See attached sheets page(s)

6 of 7

Tested by: Name (capital letters)

PAUL BOUTON

Signature

P. Boulton

Position

SOLE TRADER

Date(s)

6th MARCH 23

Wiring Types: A PVC/PVC B PVC cables in metallic conduit C PVC cables in non-metallic conduit D PVC cables in metallic trunking E PVC cables in non-metallic trunking F PVC/SWA cables G SWA/XPLE cables H Mineral insulated O Other