

# ELECTRICAL INSTALLATION CERTIFICATE

Requirements for Electrical Installations - BS 7671: 2018+A2:2022  
(IET Wiring Regulations 18th Edition)

## Guidance for recipients:

This safety Certificate has been issued to confirm that the electrical installation work to which it relates has been designed, constructed, inspected and tested in accordance with BS 7671 (the IET Wiring Regulations).

You should have received an 'original' Certificate and the person that issued the Certificate should have retained a duplicate.

If you were the person ordering this work, but not the owner of the installation, you should pass this Certificate, or a full copy of it, immediately to the owner. The original Certificate is to be retained in a safe place and be shown to any person inspecting or undertaking work on the electrical installation in the future.

If you later vacate the property, this Certificate will demonstrate to the new owner that the electrical installation complied with the requirements of BS 7671 at the time the Certificate was issued.

The Construction (Design and Management) Regulations require that, for a project covered by those Regulations, a copy of this certificate, together with schedules, is included in the project health and safety document.

For safety reasons, the electrical installation will need to be re-inspected at appropriate intervals by a skilled person or persons, competent in such work. The maximum time interval recommended before the next inspection is stated in Section 3 under "NEXT INSPECTION".

This Certificate is intended to be issued only for a new electrical installation or for new work associated with an addition or alteration to an existing installation. It should not have been issued for the inspection and testing of an existing electrical installation. An "Electrical Installation Condition Report" should be issued for such an inspection.

This Certificate is only valid if the Schedule of Inspections has been completed to confirm that all relevant inspections have been carried out and where accompanied by Schedule(s) of Circuit Details and Test Results.

Where the installation includes a residual current device (RCD) it should be tested six-monthly by pressing the button marked 'T' or 'Test'. The device should switch off the supply and should then be switched on to restore the supply. If the device does not switch off the supply when the button is pressed, seek expert advice. For safety reasons it is important that this instruction is followed.

Where the installation includes an arc fault detection device (AFDD) having a manual test facility it should be tested six-monthly by pressing the test button. Where an AFDD has both a test button and automatic test function, manufacturer's instructions shall be followed with respect to test button operation.

Where the installation includes a surge protective device (SPD) the status indicator should be checked to confirm it is in operational condition in accordance with manufacturer's information. If the indication shows that the device is not operational, seek expert advice. For safety reasons it is important that this instruction is followed.

Where the installation includes alternative or additional sources of supply, warning notices should be found at the origin or meter position or, if remote from the origin, at the consumer unit or distribution board and at all points of isolation of all sources of supply.

**ELECTRICAL INSTALLATION CERTIFICATE**  
**[BS 7671: 2018+A2:2022 as amended]**

FT/EIC 673500001195

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



**Client Details**

|          |                              |              |                           |
|----------|------------------------------|--------------|---------------------------|
| Client   | Richard and Hannah Gabbitass | Installation | Empty Property            |
| Address  | 144 Shipton Road<br>YORK     | Address      | 17 Deramore Drive<br>YORK |
| Postcode | YO30 5RU                     | Postcode     | YO10 5HW                  |

**Details of the Installation**

Description of premises Domestic  Commercial  Industrial  Date of original installation

Installation is New  Addition  Alteration  Records Available Yes  No  RCD Risk assessment attached

Description of the installation  
Full rewire of all circuits, incorporating all lighting, power and smoke detection.

Extent of the installation covered by this certificate  
All circuits covered by this certificate

Details of departures from BS 7671 (regulations 120.3, 133.1.3 and 133.5)

Details of permitted exception. (regulation 411.3.3) where applicable a suitable risk assessment(s) must be attached to this certificate

**Declaration for Design, Construction, Inspection and Testing (for sole person responsibility)**

I being the person responsible for design, construction, inspection and the test of the electrical installation (as indicated by my signature below), particulars of which are described in Section 2, having exercised reasonable skill and care when carrying out the design, construction, inspection and test hereby CERTIFY that the design, construction, inspection and test for which i have been responsible is to the best of my knowledge and belief in accordance with BS 7671:2018, amended to  except for the departures, if any, listed below. The extent of liability of the signatory or the signatories is limited to work described in Section 2 as subject of this certificate.

For the DESIGN / CONSTRUCTION / INSPECTION & TEST of the installation:

|                  |   |                       |   |            |                      |
|------------------|---|-----------------------|---|------------|----------------------|
| Company          | <input type="text" value="JB Electrical Services"/>   | Position              | <input type="text" value="Owner"/>      |            |                      |
| Inspector Name   | <input type="text" value="Terence John Berry"/>   | Date                  | <input type="text" value="12/10/2022"/> |            |                      |
| Address          | <input type="text" value="31 Main Street&lt;br/&gt;Stamford Bridge, North Yorkshire&lt;br/&gt;YO41 1AD"/> | Scheme No.            | <input type="text" value="25729"/>      | Branch No. | <input type="text"/> |
| Reviewed By      | <input type="text" value="Terence John Berry"/>   | Signature             | <input type="text" value="JB"/>         |            |                      |
| Reviewed By Date | <input type="text" value="12/10/2022"/>   | Reviewed By Signature | <input type="text" value="JB"/>         |            |                      |

Next inspection I the designer recommend that this installation is further inspected after an interval of not more than  years

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations  
 BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



**Supply Characteristics and Earthing Arrangements**

Earthing Arrangements TN-S  TN-C-S  TT  Other  If Other please specify

Number & Type of live conductors AC  DC  No. of phases  No. of wires

**Nature of Supply Parameters (Note: <sup>(1)</sup> by enquiry, <sup>(2)</sup> by enquiry or by measurement)**

Nominal voltage, U/U<sub>0</sub> <sup>(1)</sup>  v Nominal frequency, f<sup>(1)</sup>  Hz Confirmation of polarity

Prospective fault current, I<sub>pf</sub> <sup>(2)</sup>  kA External loop impedance, Z<sub>e</sub> <sup>(2)</sup>  Ω

Supply Protective Device BS (EN)  Type  Rated Current  A

No. of Additional Supplies

**Particulars of Installation at the Origin**

**Details of installation Earth Electrode** (where applicable) Type (e.g. rod(s), tape etc)  Distributors facility  Installation Earth Electrode

Location  Electrode resistance to earth  Ω Maximum Demand (load)  Amps  KVA

| Main Protective Conductors   | Material | csa | (✓) or Value  | (✓) or Value  |
|------------------------------|----------|-----|---|---|
| Earthing Conductor           | Copper   | 16  | mm <sup>2</sup> Continuity Verified <input checked="" type="checkbox"/> | Ω Connection Verified <input checked="" type="checkbox"/> |
| Protective Bonding Conductor | Copper   | 10  | mm <sup>2</sup> Continuity Verified <input checked="" type="checkbox"/> | Ω Connection Verified <input checked="" type="checkbox"/> |

| Main Supply Conductor | Material | csa | (connection / continuity) (✓) or Value | (✓) or Value |
|-----------------------|----------|-----|--|--------------|
|                       | Copper   | 25  | mm <sup>2</sup>                        |              |

**Main Switch** Location

**Water installation**  Ω **To structural steel**  Ω

**Gas installation pipes**  Ω **To lightning protection**  Ω

**Oil installation pipes**  Ω **Other**  Ω

**Fuse/device rating or setting**  A Voltage rating  V BS(EN)  No. of Poles  Current Rating  A

**If RCD main switch:** Rated residual operating current I<sub>Δn</sub>  mA Rated time delay  ms Measured operating trip time

**Comments on existing installation** (in case of addition or alteration see section 644.1.2) use continuation sheet if needed

(For additions or alterations) cables concealed within trunking and conduits, or cables or conduits concealed under floors, in roof spaces and generally within the fabric of the building or underground may not have been inspected.

**Schedule of Inspection - Outcomes**

| Indicates an inspection has been carried out and the result is satisfactory |   | Indicates the inspection is not applicable to a particular item |      |   |     |
|---|---|---|------|---|-----|
| ✓   |   | N/A   |      |   |     |
| 1.0   | Condition of consumer;s intake equipment (visual inspection only) | ✓   | 8.0  | Circuits (Distribution and Final)                 | ✓   |
| 2.0   | Parallel or switched alternative sources of supply                | N/A   | 9.0  | Isolation and switching                           | ✓   |
| 3.0   | Protective measure: Automatic Disconnection of Supply (ADS)       | ✓   | 10.0 | Current-using equipment (permanently connected)   | ✓   |
| 4.0   | Basic Protection  | ✓   | 11.0 | Identification and notices                        | ✓   |
| 5.0   | Protective measure other than ADS                                 | ✓   | 12.0 | Location(s) containing a bath or shower           | ✓   |
| 6.0   | Additional protection   | ✓   | 13.0 | Other special installations or locations          | N/A |
| 7.0   | Distribution equipment  | ✓   | 14.0 | Prosumer's low voltage electrical installation(s) | N/A |

**SCHEDULES:** This certificate is only valid when (enter quantities of schedules attached)  schedules of circuit details and test results are attached

Inspector's Name:  Signature:

Date:





**ELECTRICAL INSTALLATION CERTIFICATE - Circuit Details**

FT/EIC 673500001195

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



|                        |                              |                             |   |
|------------------------|------------------------------|-----------------------------|---|
| <b>Client Name</b>     | Richard and Hannah Gabbitass | <b>Installation Address</b> | Empty Property, 17 Deramore Drive, YORK |
| <b>Client Address</b>  | 144 Shipton Road<br>YORK     | <b>Postcode</b>             | YO10 5HW                                |
| <b>Client Postcode</b> | YO30 5RU                     |                             |   |

|  |  |   |  |
|--|--|---|--|
| <b>Distribution board details - Complete in every case</b><br>SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3† <input type="checkbox"/> N/A <input type="checkbox"/><br>Location <input type="text" value="Hallway"/><br>Designation <input type="text" value="DB 2"/><br>No. of ways <input type="text" value="12"/> |  | <b>Complete only if the distribution board is not connected directly to the origin of the installation</b><br>Overcurrent protective device for the distribution circuit: Supply to distribution board is from <input type="text" value="Sub Mains(DB 1, 1/S)"/><br>No. of phases <input type="text" value="1"/> BS(EN) <input type="text"/> Type <input type="text"/> Rating <input type="text"/> A<br>Nominal voltage <input type="text"/> V RCD BS(EN) <input type="text" value="N/A"/> Type <input type="text"/> Rating <input type="text" value="N/A"/> IΔn mA |  |
|--|--|---|--|

**SCHEDULE OF CIRCUIT DETAILS**

| Circuit No. and Line | Circuit designation   | Type of wiring | Ref. method †: | No. of points served | Circuit conductors csa (mm²) |     | Maximum disconnection time (BS 7671) (S) | Overcurrent protective devices |          |            | Breaking capacity (KA) | BS 7671 Max. permitted Zs<br>Other §<br>80%<br>(Ω) | RCD          |          |          |            |
|----------------------|-----------------------|----------------|----------------|----------------------|------------------------------|-----|--|--------------------------------|----------|------------|------------------------|--|--------------|----------|----------|------------|
|                      |                       |                |                |                      | L / N                        | CPC |  | BS EN Number                   | Type No. | Rating (A) |                        |  | BS EN Number | Type No. | IΔn (mA) | Rating (A) |
| 1/S                  | Oven                  | A              | B              | 1                    | 6                            | 2.5 | 0.4                                      | 60898 MCB                      | B        | 32         | 6                      | 1.09   | 61008        | A        | 30       | 100        |
| 2/S                  | Hob 1                 | A              | B              | 1                    | 6                            | 2.5 | 0.4                                      | 60898 MCB                      | B        | 32         | 6                      | 1.09   | 61008        | A        | 30       | 100        |
| 3/S                  | Sockets First Floor   | A              | B              | 21                   | 2.5                          | 1.5 | 0.4                                      | 60898 MCB                      | B        | 32         | 6                      | 1.09   | 61008        | A        | 30       | 100        |
| 4/S                  | Sockets Ground Floor  | A              | B              | 5                    | 2.5                          | 1.5 | 0.4                                      | 60898 MCB                      | B        | 20         | 6                      | 1.75   | 61008        | A        | 30       | 100        |
| 5/S                  | Lighting Ground Floor | A              | B              | 21                   | 1                            | 1   | 0.4                                      | 60898 MCB                      | B        | 6          | 6                      | 5.82   | 61008        | A        | 30       | 100        |
| 6/S                  | Smoke Alarm           | A              | B              | 14                   | 1                            | 1   | 0.4                                      | 60898 MCB                      | B        | 6          | 6                      | 5.82   | 61008        | A        | 30       | 100        |
| 7/S                  | Hob 2                 | A              | B              | 1                    | 6                            | 2.5 | 0.4                                      | 60898 MCB                      | B        | 32         | 6                      | 1.09   | 61008        | A        | 30       | 100        |
| 8/S                  | Sockets Kitchen       | A              | B              | 16                   | 2.5                          | 1.5 | 0.4                                      | 60898 MCB                      | B        | 32         | 6                      | 1.09   | 61008        | A        | 30       | 100        |
| 9/S                  | Garage Sockets/Alarm  | A              | B              | 3                    | 2.5                          | 1.5 | 0.4                                      | 60898 MCB                      | B        | 20         | 6                      | 1.75   | 61008        | A        | 30       | 100        |
| 10/S                 | TV Booster/Router     | A              | B              | 2                    | 2.5                          | 1.5 | 0.4                                      | 60898 MCB                      | B        | 16         | 6                      | 2.18   | 61008        | A        | 30       | 100        |
| 11/S                 | Lighting First Floor  | A              | B              | 16                   | 1                            | 1   | 0.4                                      | 60898 MCB                      | B        | 6          | 6                      | 5.82   | 61008        | A        | 30       | 100        |
| 12/S                 | SPARE                 |                |                |                      |                              |     |  |                                |          |            |                        |  |              |          |          |            |

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 ‡: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CERTIFICATE - Test Results**

FT/EIC 6735000001195

for Domestic and Similar Premises up to 100 A

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



|                       |                             |                        |                             |   |          |
|-----------------------|-----------------------------|------------------------|-----------------------------|---|----------|
| <b>Client Name</b>    | Richard and Hannah Gabbitas |                        | <b>Installation Address</b> | Empty Property, 17 Deramore Drive, YORK |          |
| <b>Client Address</b> | 144 Shipton Road<br>YORK    | <b>Client Postcode</b> | YO30 5RU                    | <b>Installation Postcode</b>            | YO10 5HW |

**Distribution board details - Complete in every case**

Location:  Designation:

No. of ways:   Supply polarity confirmed  Phase sequence confirmed

No. of phases:  SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**

Associated RCD (if any): BS (EN)

Z<sub>db</sub>:  Ω Operating at IΔn  ms

I<sub>pr</sub>:  kA No. of poles:  Time delay (if applicable):

**TEST RESULTS**

| Circuit No. and Line | Circuit impedance Ω      |      |      |            |                |               | Insulation resistance (Record lower reading) |         |          | Polarity | Max. Measured Z <sub>s</sub> (Ω) | RCD testing<br>All RCDs IΔn ms | Manual test button operation |         |
|----------------------|--------------------------|------|------|------------|----------------|---------------|--|---------|----------|----------|----------------------------------|--------------------------------|------------------------------|---------|
|                      | Ring final circuits only |      |      | R1R2 or R2 | Test voltage V | L/L, L/N M(Ω) | L/E, N/E M(Ω)                                | RCD (✓) | AFDD (✓) |          |                                  |                                |                              |         |
|                      | r1                       | m    | r2   |            |                |               |  |         |          |          |                                  |                                | F <sub>100</sub> check (✓)   | R1 + R2 |
| 1/S                  | N/A                      | N/A  | N/A  | N/A        | 0.40           |               | 250  | >200    | >200     | ✓        | 0.51                             | 134                            | ✓                            | N/A     |
| 2/S                  | N/A                      | N/A  | N/A  | N/A        | 0.36           |               | 250  | >200    | >200     | ✓        | 0.48                             | 134                            | ✓                            | N/A     |
| 3/S                  | 0.61                     | 0.62 | 0.86 | ✓          | 0.37           |               | 250  | >200    | >200     | ✓        | 0.73                             | 134                            | ✓                            | N/A     |
| 4/S                  | 0.59                     | 0.58 | 0.81 | ✓          | 0.35           |               | 250  | >200    | >200     | ✓        | 0.94                             | 134                            | ✓                            | N/A     |
| 5/S                  | N/A                      | N/A  | N/A  | N/A        | 1.72           |               | 250  | >200    | >200     | ✓        | 2.01                             | 134                            | ✓                            | N/A     |
| 6/S                  | N/A                      | N/A  | N/A  | N/A        | 1.62           |               | 250  | >200    | >200     | ✓        | 1.91                             | 134                            | ✓                            | N/A     |
| 7/S                  | 0.58                     | 0.58 | 0.82 | ✓          | 0.33           |               | 250  | >200    | >200     | ✓        | 0.60                             | 139.8                          | ✓                            | N/A     |
| 8/S                  | N/A                      | N/A  | N/A  | N/A        | 0.24           |               | 250  | >200    | >200     | ✓        | 0.77                             | 139.8                          | ✓                            | N/A     |
| 9/S                  | N/A                      | N/A  | N/A  | N/A        | 0.19           |               | 250  | >200    | >200     | ✓        | 0.35                             | 139.8                          | ✓                            | N/A     |
| 10/S                 | N/A                      | N/A  | N/A  | N/A        | 1.44           |               | 250  | >200    | >200     | ✓        | 0.32                             | 139.8                          | ✓                            | N/A     |
| 11/S                 | N/A                      | N/A  | N/A  | N/A        |                |               | 250  | >200    | >200     | ✓        | 1.61                             | 139.8                          | ✓                            | N/A     |
| 12/S                 | N/A                      | N/A  | N/A  | N/A        |                |               |  |         |          | N/A      |                                  |                                | N/A                          | N/A     |

Details of circuits and/or installed equipment vulnerable to damage when testing

Date(s) dead testing:  To

Date(s) live testing:  To

Test instrument serial number(s)

Loop impedance:  Insulation resistance:  Continuity:  RCD:  E/Electrode:

Tested by: Name (capital letters)  Signature:

Position:  Date: