



NAPIT Electrical Installation Condition Report

Requirements for Electrical Installations -
BS 7671:2008 incorporating Amendment No.3, 2015
[IET Wiring Regulations 17th Edition]

NA/ 10027
EICR Page 1 of 6

A Details of the installation

Client MR LANARACK	Installation (If different from client)
Address STATION HOUSE SANDWAST LANE CHURCH FENTON	Address 76 ELDON STREET YORK
Postcode LS24 9QT	Postcode YO31 7NE

B Reason for producing this report *This form to be used only for reporting on the condition of an existing installation.*

REQUEST OF CLIENT

Date(s) on which the inspection and testing were carried out **17 02 20** to **17 02 20**

C Details of the installation which is the subject of this report

Description of premises Domestic Commercial Industrial Other (please state)

Estimated age of the wiring system **8** years

Evidence of alterations or addition Yes No Not apparent If 'Yes', estimated years

Records of installation available Yes No Records held by **CLIENT**

Date of last inspection **Aug 2017** Electrical Installation Certificate No. or previous Inspection Report No. **0444550**

D Extent and limitations of inspection and testing

Extent of electrical installation covered by this report:
80% of Accessories VISUALLY INSPECTED
40% " REMOVED TESTED + INSPECTED NO PAT CARRIED OUT

Agreed limitations (See Regulations 634.2) Agreed with: **CLIENT**

Operational limitations including the reasons (see page no of) **-**

The inspection and testing detailed within this report and accompanying schedule has been carried out in accordance with BS 7671: 2008 (IET Wiring Regulations), amended to **2018** (date) It should be noted that cables concealed within the trunkings and conduits, under floors, in roof spaces and generally within the fabric of the building or underground have **not** been inspected unless specifically agreed between the client and inspector prior to the inspection. An inspection should be made within an accessible roof space housing other electrical equipment.

E Summary of the condition of the installation

General conditions of the Installation (in terms of safety)

SATISFACTORY

Overall assessment of the installation in terms of its suitability for continued use **SATISFACTORY** **UNSATISFACTORY***

* An UNSATISFACTORY assessment indicates that dangerous (code C1) and/or potentially dangerous (code C2) conditions have been identified

F Recommendations

Where the overall assessment of the suitability of the installation for continued use above is stated as UNSATISFACTORY, I / we recommend that any observations classified as 'Danger present' (code C1) or 'Potentially dangerous' (code C2) are acted upon as a matter of urgency. Investigation without delay is recommended for observations identified as 'further investigation required' (code FI) Observations classified as 'Improvement recommended' (code C3) should be given due consideration. Subject to the necessary remedial action being taken, I / we recommend that the installation is further inspected and tested by **17 FEB 2025** (date)

G Declaration

I/We, being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by my/our signatures below), particulars of which are described above, having exercised reasonable skill and care when carrying out the inspection and testing, hereby declare that the information in this report, including the observations and the attached schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent and limitations in section D of this report.

Company SELECTRICS	Inspected and tested by	Authorised for issue by
Membership No. 8954	Name: J R NICKSON	
Address 6 ASKHAM LANE YORK	Signature:	
Postcode YO24 3AA	Position: BUSINESS PARTNER	
	Date: 17 FEB 2020	

H Schedule(s)

3 schedule(s) of inspection and **1** schedule(s) of test results are attached.

The attached schedule(s) are part of this document and this report is valid only when they are attached to it.

© Copyright NAPIT January 2015



NAPIT Electrical Installation Condition Report

Requirements for Electrical Installations -
BS 7671:2008 incorporating Amendment No.3, 2015
[IET Wiring Regulations 17th Edition]

NA/
EICR

10027
Page 2 of 6

Supply characteristics and earthing arrangements Tick boxes and enter details, as appropriate

Earthing Arrangements TN-S TN-C-S TT Other Please specify:

Number & type of live conductors a.c. d.c. No. of phases 1 No. of wires 2

Nature of Supply Parameters (Note: (') by enquiry, (") by enquiry or by measurement)

Nominal voltage, U/U₀(') 230 v Nominal frequency, f(') 50 Hz Confirmation of supply polarity

Prospective fault current, I_{pf} (") 1.49 kA External loop impedance, Z_e (") 0.28 Ω

Supply Protective Device BS(EN) 136 Type II Nominal Current Rating LIM A

Other Sources of Supply (as detailed in attached schedule)

Particulars of installation referred to in this report Tick boxes and enter details, as appropriate

Means of Earthing Distributor's facility Installation earth electrode

Details of Installation earth electrode (where applicable) Type (e.g. rod(s), tape etc)

Location Electrode resistance to earth Ω

Main Protective Conductors Material Csa (mm²) Verified (connection / continuity)..

Main Earthing Conductor Copper 16 To water installation pipes To structural steel

Protective Bonding Conductor Copper 10 To gas installation pipes To lightning protection

Main Supply Conductor(s) Copper 25 To oil installation pipes Other

Main Switch / Switch-Fuse / Circuit Breaker / RCD

Location Front Entrance BS (EN) 60947/3 No. of Poles 2

Current rating 100 A Fuse/device rating or setting - A Voltage rating 230 V

If RCD main switch: Rated residual operating current I_{Δn} = - mA Rated time delay - ms (at I_{Δn})

Measured operating time at I_{Δn} = - ms

Observations

Referring to the attached schedule of inspection and test results, and subject to the limitations at Section D.

No remedial work required The following observations are made

Explanation of codes

C1. Danger present. Risk of injury. Immediate remedial action required.

C2. Potentially dangerous. Urgent remedial action required.

C3. Improvement recommended.

FI. Further investigation required without delay

Item No.	Observations	Code
1	HOLE AT CEILING LEVEL TO MAINS BOARD	C3
2	CONSUMER UNIT NOT AMENDMENT 3 FIRE RATED	C3
3	HOB UNDER COPBOARD	C3
4	FIRE ALARM REQUIRES ISOLATION POINT	C3

One of the above codes, as appropriate, has been allocated to each of the observations made above and/or any attached observation sheets to indicate to the person(s) responsible for the installation the degree of urgency for remedial action.

Note: For additional report pages use the continuation report form with the relevant serial number and page numbers detailed on each page.

C1 Immediate remedial work required for items

C2 Urgent remedial work required for items

C3 Improvement(s) recommended for items

FI Further investigation required without delay

1 2 3 4



Condition Report Inspection Schedule

for Domestic and Similar Premises with up to 100A Supply

Note: This form is suitable for many types of smaller installation not exclusively domestic.

Requirements for Electrical Installations – BS 7671:2008 incorporating

Amendment No.3, 2015 [IET Wiring Regulations 17th Edition]

Only for the reporting on the condition of an existing installation.

NA/

EICR

10027

Page 3 of 6



Schedule of Inspections

Outcomes

Acceptable condition: ✓	Unacceptable condition: State C1 or C2	Improvement recommended: C3	Further investigation FI	Not verified: NV	Limitation: Lim	Not applicable N/A
----------------------------	---	--------------------------------	-----------------------------	---------------------	--------------------	-----------------------

(In the Outcome column use the codes above. Provide additional comment where appropriate. C1/C2/C3 and FI coded items to be recorded in section K of the condition report)

Item No.	Description	Outcome
1.0	DISTRIBUTOR'S / SUPPLY INTAKE EQUIPMENT	
1.1	Condition of service cable	✓
1.2	Condition of service head	✓
1.3	Condition of distributor's earthing arrangement	✓
1.4	Condition of meter tails - Distributor / Consumer	✓
1.5	Condition of metering equipment	✓
1.6	Condition of isolator (where present)	NA
2.0	Presence of adequate arrangements for – other sources such as microgenerators [551.6; 551.7]	
3.0	EARTHING / BONDING ARRANGEMENTS (411 3; Chap 54)	
3.1	Presence and condition of distributor's earthing arrangement [542.1.2.1; 542.1.2.2]	✓
3.2	Presence and condition of earth electrode connection where applicable [542.1.2.3]	NA
3.3	Provision of earthing / bonding labels at all appropriate locations [514.13.1]	✓
3.4	Confirmation of earthing conductor size [542.3; 543.1.1]	✓
3.5	Accessibility and condition of earthing conductor at MET [543.3.2]	✓
3.6	Confirmation of main protective bonding conductor sizes [544.1]	✓
3.7	Condition and accessibility of main protective bonding conductor connections [543.3.2; 544.1.2]	✓
3.8	Accessibility and condition of all other protective bonding connections [543.3.2]	✓
4.0	CONSUMER UNIT(S) / DISTRIBUTION BOARD(S)	
4.1	Adequacy of working space / accessibility to consumer unit / distribution board [132.12; 513.1]	✓
4.2	Security of fixing [134.1.1]	✓
4.3	Condition of enclosure[s] in terms of IP rating etc [416.2]	✓
4.4	Condition of enclosure[s] in terms of fire rating etc [421.1.201; 526.5]	C3
4.5	Enclosure not damaged/deteriorated so as to impair safety (621.2 [iii])	✓
4.6	Presence of linked main switch [as required by 537.1.4]	✓
4.7	Operation of main switch [functional check] [612.13.2]	✓
4.8	Manual operation of circuit-breakers and RCDs to prove disconnection [612.13.2]	✓
4.9	Correct identification of circuit details and protective devices [514.8.1; 514.9.1]	✓
4.10	Presence of RCD quarterly test notice at or near consumer unit / distribution board [514.12.2]	✓
4.11	Presence of non-standard (mixed) cable colour warning notice at or near consumer unit/distribution board [514.14]	✓
4.12	Presence of alternative supply warning notice at or near consumer unit / distribution board [514.15]	NA
4.13	Presence of other required labelling [Please specify] [Section 514]	
4.14	Examination of protective device[s] and base[s]; correct type and rating [no signs of unacceptable thermal damage, arcing and overheating] [421.1.3]	✓
4.15	Single-pole switching or protective devices in line conductors only [132.14.1; 530.3.2]	✓
4.16	Protection against mechanical damage where cables enter consumer unit / distribution board [522.8.1; 522.8.11]	✓
4.17	Protection against electromagnetic effects where cables enter consumer unit/distribution board/enclosures [521.5.1]	✓
4.18	RCD[s] provided for fault protection – includes RCBO[s] [411.4.9; 411.5.2; 531.2]	✓
4.19	RCD(s) provided for additional protection-includes RCBOs [411.3.3 ; 415.1]	✓
4.20	Confirmation of indication that SPD is functional [534.2.8]	NA
4.21	Confirmation that ALL conductor connections, including busbars, are correctly located in terminals secure/tight [526.1]	✓
4.22	Adequate arrangements where a generating set operates as a switched alternative to the public supply [551.6]	NA



Condition Report Inspection Schedule

for Domestic and Similar Premises with up to 100A Supply

Note: This form is suitable for many types of smaller installation not exclusively domestic.

Requirements for Electrical Installations – BS 7671:2008 incorporating

Amendment No.3, 2015 [IET Wiring Regulations 17th Edition]

Only for the reporting on the condition of an existing installation.

NA/
EICR 10027
Page 4 of 6

Schedule of Inspections

Outcomes

Acceptable condition: ✓	Unacceptable condition: State C1 or C2	Improvement recommended: C3	Further investigation FI	Not verified: NV	Limitation: Lim	Not applicable: N/A
----------------------------	---	--------------------------------	-----------------------------	---------------------	--------------------	------------------------

(In the Outcome column use the codes above. Provide additional comment where appropriate. C1/C2/C3 and FI coded items to be recorded in section K of the condition report)

Item No.	Description	Outcome
4.23	Adequate arrangements where a generating set operates in parallel with the public supply [551.7]	✓
5.0	FINAL CIRCUITS	
5.1	Identification of conductors [514.3.1]	✓
5.2	Cables correctly supported throughout their run [522.8.5]	Lim
5.3	Condition of insulation of live parts [416.1]	✓
5.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking [521.10.1] To include the integrity of conduit and trunking systems [metallic and plastic]	✓
5.5	Adequacy of cables for current-carrying capacity with regard for the type and nature of the installation [Section 523]	✓
5.6	Co-ordination between conductors and overload protective devices [433.1; 533.2.1]	✓
5.7	Adequacy of protective devices; type and rated current for fault protection [411.3]	✓
5.8	Presence and adequacy of circuit protective conductors [411.3.1.1; 543.1]	✓
5.9	Wiring system(s) appropriate for the type and nature of the installation and external influences [Section 522.5]	✓
5.10	Concealed cables installed in prescribed zones (see extent and limitations) [522.6.202]	Lim
5.11	Cables concealed under floors, above ceilings or in walls / partitions, adequately protected against damage see section D. Extent and limitations] [522.6.204]	Lim
5.12	Provision of additional protection by RCD not exceeding 30mA	
5.12.1	for all sockets-outlets of rating 20A or less, unless exempt [411.3.3]	✓
5.12.2	for supply to mobile equipment not exceeding 32A rating for use outdoors [411.3.3]	✓
5.12.3	for cables concealed in walls / partitions at a depth of less than 50mm [522.6.202; 522.6.203]	✓
5.12.4	for cables concealed in walls / partitions containing metal parts regardless of depth [522.6.203]	✓
5.13	Provision of fire barriers, sealing arrangements and protection against thermal effects [Section 527]	✓
5.14	Cables segregated / separated from Band I cables [528.1]	✓
5.15	Cables segregated / separated from communications cabling [528.2]	✓
5.16	Cables segregated/separated from non-electrical services [528.3]	✓
5.17	Termination of cables at enclosures – indicate extent of sampling in Section D of the report [Section 526]	
5.17.1	Connections soundly made and under no undue strain [526.6]	✓
5.17.2	No basic insulation of a conductor visible outside enclosure [526.8]	✓
5.17.3	Connections of live conductors adequately enclosed [526.5]	✓
5.17.4	Adequately connected at point of entry to enclosure [glands, bushes etc...] [522.8.5]	✓
5.18	Condition of accessories including socket-outlets, switches and joint boxes (621.2 [iii])	✓
5.19	Suitability of accessories for external influences [512.2]	✓
5.20	Adequacy of working space / accessibility to equipment [132.12; 513.1]	✓
5.21	Single-pole switching or protective device in line conductors only [132.14.1; 530.3.2]	✓

Inspector's Name **J B NICKSON**
Date **17 FEB 2020**

Signature



Condition Report Inspection Schedule

for Domestic and Similar Premises with up to 100A Supply

Note: This form is suitable for many types of smaller installation not exclusively domestic.

Requirements for Electrical Installations – BS 7671:2008 incorporating
Amendment No.3, 2015 [IET Wiring Regulations 17th Edition]
Only for the reporting on the condition of an existing installation.

NA/
EICR

10027
Page 5 of 6

Schedule of Inspections

Outcomes

Acceptable condition: ✓	Unacceptable condition: <i>State</i> C1 or C2	Improvement recommended: C3	Further investigation FI	Not verified: NV	Limitation: Lim	Not applicable: N/A
----------------------------	--	--------------------------------	-----------------------------	---------------------	--------------------	------------------------

(In the Outcome column use the codes above. Provide additional comment where appropriate. C1/C2/C3 and FI coded items to be recorded in section K of the condition report)

Item No.	Description	Outcome
6.0	LOCATION(S) CONTAINING A BATH OR SHOWER	
6.1	Additional protection for all low voltage [LV] circuits by RCD not exceeding 30 mA [701.411.3.3]	✓
6.2	Where used as a protective measure, requirements for SELV or PELV met [701.414.4.5]	✓
6.3	Shaver sockets comply with BS EN 61558-2-5 formerly BS 3535 [701.512.3]	NA
6.4	Presence of supplementary bonding conductors, unless not required by BS 7671:2008 [701.415.2]	NA
6.5	Low voltage (e.g. 230 volt) socket-outlets sited at least 3m from zone 1 [701.512.3]	NA
6.6	Suitability of equipment for external influences for installed location in terms of IP rating [701.512.2]	✓
6.7	Suitability of accessories and control gear etc for a particular zone [701.512.3]	✓
6.8	Suitability of current-using equipment for particular position within the location [701.55]	✓
7.0	OTHER SPECIAL INSTALLATIONS OR LOCATIONS	
7.1	List all other special installations or locations present, if any. [Record the results of particular inspections applied separately]	

Schedule of Tests

Results to be recorded on Schedule of Test Results

- ✓ External earth loop impedance, Ze
- NA Installation earth electrode
- ✓ Prospective fault current Ipf
- ✓ Continuity of Earth Conductors
- ✓ Continuity of Circuit Protective Conductors
- ✓ Continuity of ring final conductors
- ✓ Continuity of Protective Bonding Conductors
- ✓ Volt drop verified

- ✓ Insulation Resistance between Live conductors
- ✓ Insulation Resistance between Live conductors & Earth
- ✓ Polarity (prior to energisation)
- ✓ Polarity (after energisation) including phase sequence
- ✓ Earth fault loop impedance
- ✓ RCDs / RCBOs including discrimination
- ✓ Functional testing of devices

(insert ✓ or N/A)

Inspector's Name J B Jackson
Date 17 FEB 2020

Signature



NAPIT Electrical Test Schedule

Requirements for Electrical Installations - BS 7671:2008 incorporating Amendment No.3 2015 (IET Wiring Regulations 17th Edition)

EICR

10027
Page 6 of 6

Client: **Mr Laverack** Installation address: **76 ELDON STREET** Postcode: **YO31 7NE**

Complete in every case
Location of distribution board: **FRONT ENTRANCE**
Distribution board designation: **POWER TO PROPERTY**
Number of ways: _____

Supply to distribution board is from: **N/A**
Overcurrent protective device for the distribution circuit: Type BS(EN): **N/A** Rating: **N/A** A Phase sequence confirmed: _____
Supply polarity confirmed: _____

Overcurrent protective devices: V: **N/A** Z_{db}: **N/A** Ω: _____ Operating times of: **N/A** ms
Type BS(EN): **N/A** Rating: **N/A** A Phase sequence confirmed: _____
Supply polarity confirmed: _____

Characteristics at this distribution board
Associated RCD (if any): BS (EN): **N/A**
RCD No of Poles: **N/A**
I_{Δn}: **N/A** ms
I_{Δn}: **N/A** ms

Test instrument serial number(s): **737108**
Earth fault loop imped. _____
Insulation resistance _____
Continuity _____
RCD _____

Circuit No. and line No.	Circuit designation	CIRCUIT DETAILS				TEST RESULTS											
		Type of wiring	Ref. method	No. of points served	Circuit conductors	Maximum disconnection time (BS:7671)	Overcurrent protective devices	RCD operating current I _{Δn} (mA)	BS7671 Max. and other values Ω	Ring final circuits only (measured end to end)	Circuit impedance Ω	All circuits to be completed using R1, R2, or R2, not both	Insulation resistance (Record lower reading)	Polarity	Maximum measured Z _s (Ω)	RCD testing	
					Live (mm ²) CPC (mm ²)	(S)	BS EN Number Type No. Rating (A)	(mA)	Ω	r ₁ r _n r ₂	(✓) (✓) (✓)	Live/Live (MΩ) Live/Earth (MΩ)	(✓) (✓)	(Ω)	at I _{Δn} ms at 5 I _{Δn} ms	(✓) (✓)	
1	FIRE ALARM	1 B	1 B	1	1.5 0.75	60898	B 10	6	3.49	—	0.07	>999	>999	0.37	—	—	✓
2	SPARE	1 B	1 B	17	1.0 0.75	60878	B 6	6	30582	—	1.01	200+	200+	1.40	325	15.8	✓
3	UP LIGHTS REAR	1 B	1 B	4	1.0 0.75	4	B 6	6	30582	—	0.61	180+	180+	1.02	33	15.4	✓
4	ATTIC LIGHTS	1 B	1 B	1	2.5 1.5	4	B 16	6	30218	—	0.41	700+	700+	0.45	32.5	15.4	✓
5	WATER HEATER 1st + GROUND	1 B	1 B	17	2.5 1.5	4	B 32	6	30	0.76 0.80	0.43	200+	200+	1.10	32.4	15.4	✓
6	SOCKETS FRONT	1 B	1 B	2	4.0 2.5	4	B 32	6	30	—	0.58	>999	>999	0.98	32.5	15.4	✓
7	COOKER	1 B	1 B	13	1.0 0.75	4	B 6	6	30582	—	0.84	170+	170+	1.11	41.8	21.2	✓
8	LIGHTS	1 B	1 B	6	1.0 0.75	4	B 6	6	30582	—	0.71	140+	140+	0.94	41.4	21.5	✓
9	LIGHTS 1st + GROUND FRONT	1 B	1 B	14	2.5 1.5	4	B 32	6	30	0.92 0.91	0.48	70+	70+	1.00	41.8	21.5	✓
10	SOCKETS KITCHEN/BORER	1 B	1 B	9	2.5 1.5	4	B 32	6	30	0.54 0.54	0.61	900+	900+	0.94	42.0	21.2	✓
11	SOCKETS ATTIC	1 B	1 B	1	6.0 2.5	4	B 40	6	30	—	0.29	900+	900+	0.31	41.4	21.2	✓
12	SHOWER	1 B	1 B	1	6.0 2.5	4	B 40	6	30	—	0.29	900+	900+	0.31	41.4	21.2	✓

Details of circuits and/or installed equipment vulnerable to damage when testing

Fire Alarm - Boller - Nelson's

Wiring Types 1= PVC/PVC 2= Single Insulated in Conduit or Trunking 3= Mineral Insulated 4= SWA/XPLE 5= FP200 6= Other =

Tested by: Name (capital letters) **J B NICKSON**

Position **Business Partner**

Date(s) **17 Feb 2020**

Signature

See attached sheets page(s) of