Landlord Home Owner Gas Safety Record

This inspection is for gas safety purposes only to comply with the Gas Safety (Installation and Use) Regulations. Flues have been inspected and checked for satisfactory evacuation of products of combustion. A detailed internal inspection of the flue integrity, construction and the lining has NOT been carried out.



Registered business				Job address				ndlord	l/agent		Certificate info	Certificate information		
Gas safe ID 546792 HP Plumbing & Heating Ltd Bhp Rievaulx House 1 St Marys Court York North Yorkshire YO24 1AH +44 1904 750222				10 Stanley Street York North Yorks YO31 8NW			12, Rip No	Mr Don Lamb 12,Clotherholme road, Ripon North Yorks HG42DA			Date 01/02/2023 Number 2156 Next inspection due 01/02/2024			
No	Location Appliance type Make/		Make/mo	model		Flue type	Landlo applia		Appliance insp?	Combustion analyser reading	Operating pressu or heat input	re Safety devic correct oper		
1	Toilet Combination boil		ion boiler	iler Ideal/Instinct 24			RS	5 Yes		Yes	Na	Na	Yes	
Νο	Ventilation prov satisfactory	ision	Visual cond termination			Flue performance checks	A	ppliance	A	ppliance afe to use	Approved CO alarm fitted?	Is CO alarm in date?	Testing of CO al satisfactory	arm
1	Yes Y		Yes		Pass	Ye	Yes		es	Yes	Yes	Yes		
No	No Defect(s) identified I			Remedial action taken					Warning/Advice notice issued					1 Yes
											Gas tightness test satisfactory?			
										Emergency control valve accessible?				
										Protective equipotential bonding satisfactory?			Yes	
Engl	Engineer information Received by											Audible carbon monoxide alarm fitted? Yes		
Engineer Information Engineer name: Luke Hodges Gas safe card ID: Signature:				Received by information Name: Received by: No person present Signature:						Boiler serviced all ok Gas tightness test pass all ok				

Analyser readings	App 1	App 2	Арр З	App 4
Working pressure (at meter)	Na mbar			
Working appliance pressure	19.00 mbar			
Co parts per million	71			
Percentage co2	8.3			
Percentage oxygen	4.0			
Co/Co2 ratio	0.0008			
Gross flue gas temperature	Na			
Gas rate (if applicable)	3.0			