

Landlord Home Owner Gas Safety Record



This inspection is for gas safety purposes only to comply with the Gas Safety (Installation and Use) Regulations. Flues have been inspected and checked for satisfactory evacuation of products of combustion. A detailed internal inspection of the flue integrity, construction and the lining has NOT been carried out.

Registered business		Job address		Landlord/agent			Certificate information		
Gas safe ID 546792 HP Plumbing & Heating Ltd Bhp Rievaulx House 1 St Marys Court York North Yorkshire YO24 1AH +44 1904 750222		16 Granville Terrace York YO10 3DY		N/A			Date 24/10/2023 Number 2579 Next inspection due 24/10/2024		
No	Location	Appliance type	Make/model	Flue type	Landlords appliance	Appliance insp?	Combustion analyser reading	Operating pressure or heat input	Safety device(s) correct operation
1	Kitchen	Combination boiler	Sime/EcoMfort plus 30 HE	RS	Yes	Yes	Ok	31.5KW	Yes
No	Ventilation provision satisfactory	Visual condition of the flue & termination satisfactory	Flue performance checks	Appliance serviced	Appliance safe to use	Approved CO alarm fitted?	Is CO alarm in date?	Testing of CO alarm satisfactory	
1	Yes	Yes	Pass	Yes	Yes	Yes	Yes	N/A	
No	Defect(s) identified	Remedial action taken	Warning/Advice notice issued	Number of appliances tested 1					
				Gas installation pipework (visual inspection) satisfactory? Yes					
				Gas tightness test satisfactory? Yes					
				Emergency control valve accessible? Yes					
				Protective equipotential bonding satisfactory? Yes					
				Audible carbon monoxide alarm fitted? Yes					
Engineer information			Received by information			Comments			
Engineer name: Daniel Mason Gas safe card ID: Signature:			Name: Received by: No person present Signature:			Slight leak on the boiler manifold above there heat exchanger			