

LANDLORD/HOME OWNER GAS SAFETY RECORD

This inspection is for gas safety purposes only in accordance with the current edition of the Gas Safety (Installation and Use) Regulations. Flues were inspected visually and checked for satisfactory evacuation of products of combustion. A detailed internal inspection of the flue integrity, construction and lining has not been carried out.

GAS INSTALLER: (Trading Title) COLIN ROBERTSON
Name: C. ROBERTSON
Gas Safe Register No: 1576644
Address: 19. LEIGHTON CROSS
Gas Installer Ref. No.: A.B.
Post code: HAUCU 6FE YORK
Date of Issue: 18/01/24
Tel: 07710448500
Engineers Name: (print) C. ROBERTSON

TENANT/HOME OWNER DETAILS

Tenant/Home Owner* Name: ST. FRANCIS PARISH
Property Address: ST. FRANCIS PARISH YORK
Post Code: YO1 1JL
Tel: _____
Tenant/Home Owner* present during inspection YES NO

LANDLORD/AGENT DETAILS (if applicable)

Landlord/Agent* Name: ARMAN BENNETT LETTINGS
Address: 58. GUY GATE YORK
Post Code: YO1 1JL
Tel: 011611
Landlord/Agent* present during inspection YES NO

APPLIANCE DETAILS				INSPECTION DETAILS				FLUE TEST				RESULTS							
LOCATION	MAKE	MODEL	TYPE	Flue Type e.g. CF or RS	Operating Pressure Mbar	Heat Input Kw	Safety Device Correct Operation Yes/No	Ventilation Adequate Yes/No	CO Alarm fitted Yes/No	CO Alarm tested Pass/Fail	Flue Flow Test Pass/Fail	Spillage Test Pass/Fail	Termination Satisfactory Yes/No	Visual Condition Pass/Fail	Combustion Performance CO2 Ratio / CO2 CO	Appliance Safe To Use Yes/No	Landlord's Appliance Yes/No	Inspected Yes/No	
1	FRANK	C30	HE	R.S	20	1	YES	YES	YES	PASS	N/A	N/A	YES	PASS	0.0001	YES	YES	YES	
2	FRANK	C30	HE	R.S	19	1	YES	YES	YES	PASS	N/A	N/A	YES	PASS	0.0001	YES	YES	YES	
3																			
4																			
5																			

DETAILS OF ANY FAULTS		REMEDIAL ACTION TAKEN		DETAILS OF WORK CARRIED OUT		LABEL & WARNING NOTICE ISSUED	
1	2	3	4	5	Yes	No	Yes/No

Outcome of gas installation pipework visual inspection? Pass / Fail / NA
Outcome of gas supply pipework visual inspection? Pass / Fail / NA
Is the Emergency Control Valve access satisfactory? Pass / Fail / NA
Outcome of gas tightness test? Pass / Fail / NA
Is the Protective Equipotential bonding satisfactory? Pass / Fail / NA

This Safety Record is issued by Gas Installer: (SIGNED) _____
 Received on behalf of Landlord / Home Owner: (SIGNED) _____
 Tenant/Landlord/Agent/Home Owner* _____
Number of appliances tested: 2
Date: 18/1/24

ATTENTION
 Next safety check due by: 24/01/25