

HOME OWNER SAFETY RECORD

This is for gas safety purposes only in accordance with the current the Gas Safety (Installation and Use) Regulations. Flues were inspected and checked for satisfactory evacuation of products of combustion. A detailed internal inspection of the flue integrity, construction and lining has not been carried out.

TENANT/HOME OWNER DETAILS

Tenant/Home Owner* Name: _____
 Property Address: 48 Grosvenor Terrace York
 Post Code: _____
 Tenant/Home Owner* present during inspection: YES/NO

LANDLORD/AGENT DETAILS (if applicable)

Landlord/Agent* Name: ADAM BRINKETT LETTING
 Address: 58 GUYGATE YORK
 Post Code: _____
 Landlord/Agent* present during inspection: YES/NO

GAS INSTALLER: (Trading Title) CARIN ROBERTSON
 Name: C. ROBERTSON Gas Safe Register No: 157664
 Address: 19 LEIGHTON CROFT Gas Installer Ref. No: A.B.
RAWcliffe, York Date of Issue: 17/1/24
 Post code: YO30 5ZG Time of Issue: _____
 Tel: 07710448500 Engineers Name: (print) C. ROBERTSON

APPLIANCE DETAILS				INSPECTION DETAILS				FLUE TEST				RESULTS						
LOCATION	MAKE	MODEL	TYPE	Operating Pressure Mbar	Heat Input Kw	Safety Device Correct Operation Yes/No	Ventilation Adequate Yes/No	CO Alarm fitted Yes/No	CO Alarm tested Pass/Fail	Flue Flow Test Pass/Fail	Spillage Test Pass/Fail	Termination Satisfactory Yes/No	Visual Condition Pass/Fail	Combustion Performance Reading CO: CO2 Ratio / CO2 CO	Appliance Safe To Use Yes/No	Landlord's Appliance Yes/No	Inspected Yes/No	
1	KITCHEN	ECOTEC	HE	19.5	19.5	YES	Y/A	YES	PASS	N/A	N/A	Y/A	PASS	9.99/9.51	YES	YES	YES	
2																		
3																		
4																		
5																		

DETAILS OF ANY FAULTS		REMEDIAL ACTION TAKEN		DETAILS OF WORK CARRIED OUT		LABEL & WARNING NOTICE ISSUED	
1	2	3	4	5	1	2	3

Outcome of gas installation pipework visual inspection? Pass / Fail / NA
 Outcome of gas supply pipework visual inspection? Pass / Fail / NA
 Is the Emergency Control Valve access satisfactory? Pass / Fail / NA
 Outcome of gas tightness test? 1.5ml in 2mins
 Is the Protective Equipotential bonding satisfactory? Pass / Fail / NA

This Safety Record is issued by Gas Installer: (SIGNED) _____
 Received on behalf of Landlord / Home Owner: (SIGNED) _____
 Tenant/Landlord/Agent/Home Owner* _____
 Number of appliances tested: 1
 Date: 17/1/24

ATTENTION
 Next safety check due by: 18/01/25