

LANDLORD/HOME OWNER GAS SAFETY RECORD

This inspection is for gas safety purposes only in accordance with the current edition of the Gas Safety (Installation and Use) Regulations. Flues were inspected visually and checked for satisfactory evacuation of products of combustion. A detailed internal inspection of the flue integrity, construction and lining has not been carried out.

GAS INSTALLER: (Trading Title) Coun. Robertson
 Name: C. Robertson Gas Safe Register No: 157664
 Address: 19 Leighton Crags Gas Installer Ref. No.: A.A.
 Post code: RA6 2LH Date of Issue: 21/2/24
 Tel: 07710448500 Engineers Name: (print) C. Robertson

TENANT/HOME OWNER DETAILS

Tenant/Home Owner* Name: _____
 Property Address: 10 James Street
 Post Code: _____
 Tenant/Home Owner* present during inspection: _____ YES/NO

LANDLORD/AGENT DETAILS (if applicable)

Landlord/Agent* Name: ARMY BARRACKS LETTING
 Address: 58 GUYBATE YORK
 Post Code: _____
 Landlord/Agent* present during inspection: _____ YES/NO

APPLIANCE DETAILS			INSPECTION DETAILS				FLUE TEST			RESULTS									
LOCATION	MAKE	MODEL	TYPE	Flue Type e.g. CF or RS	Operating Pressure Mbar	Heat Input Kw	Safety Device Correct Operation Yes/No	Ventilation Adequate Yes/No	CO Alarm fitted Yes/No	CO Alarm tested Pass/Fail	Flue Flow Test Pass/Fail	Spillage Test Pass/Fail	Termination Satisfactory Yes/No	Visual Condition Pass/Fail	Combustion Performance Reading CO ₂ / CO ₂ CO	Appliance Safe To Use Yes/No	Landlord's Appliance Yes/No	Inspected Yes/No	
1	LIVING ROOM	DAVID BROWN	HE	RS 20	16.5	12.5	Yes	Yes	Yes	Pass	Pass	Pass	Yes	Pass	8.9% CO ₂ / 0.1% CO	Yes	Yes	Yes	
2																			
3																			
4																			
5																			

DETAILS OF ANY FAULTS		REMEDIAL ACTION TAKEN		DETAILS OF WORK CARRIED OUT		LABEL & WARNING NOTICE ISSUED	
1	2	1	2	1	2	Yes	NO

Outcome of gas installation pipework visual inspection? Pass / Fail / NA
 Outcome of gas supply pipework visual inspection? Pass / Fail / NA
 Is the Emergency Control Valve access satisfactory? Pass / Fail / NA
 Outcome of gas tightness test? 1.7506 Pa @ 150mm
 Is the Protective Equipotential bonding satisfactory? Pass / Fail / NA

This Safety Record is issued by Gas Installer: (SIGNED) _____
 Received on behalf of Landlord / Home Owner: (SIGNED) _____
 Tenant/Landlord/Agent/Home Owner* _____
 Number of appliances tested: ONE
 Date: 21/2/24

ATTENTION
 Next safety check due by: 22/2/24