Safe Simtec Plumbing And Heating

Landlord Gas Safety Record

Cert. No. 326

Safety Inspection and reporting carried out in accordance with the Gas Safety (Installation and Use) Regulations and the Gas Industry Unsafe Situations Procedure.

Company / I	Job Address							Customer / Landlord												
Engineer	neer Deklan Simpson					Name							Name Corrina							
Company	Simtec Plumbing And Heating					Address 2								MBE Limited						
Address	27					Bu	Bull Lane						;	villa farm wigginton road York						
	Stray road					Yo	York													
	York													York						
					Post Code	1010 3211														
Post Code	1031 0112					Tel. No						Post Code YO32 2RH								
Tel No. 07415903753												Tel. No								
Gas Safe Reg 3916101																				
ID Card No.	D Card No. 3916101																			
Appliance Details Inspection Details																				
Location			Make	Mode	I	Flue Type	Landlord's Appliance Inspected		Operating Pressure	Heat Input (kW/h)	High Combustio			Safety device(s)		Visual condition of flue and	Flue	Appliance	Appliance safe	
							Appliance		(mbar)		Reading Reading Ratio CO CO2 Ratio CC ppm % ppr		CO2 operation satisfactor	Provision satisfactory	termination satisfactory	Performance test	Serviced	ed to use		
1	Boile	er	Ideal	Logic Max C	ombi C35	NA	Yes	Yes	20.1	35	0.0011 145				Yes	Yes	Pass	Yes	Yes	
2 Kitcher	n Hok)	Unknown	Uknov	wn	NA	Yes	No	NA	7	na na	na na	na na	Yes	Yes	Yes	Pass	Yes	Yes	
3																				
4																				
5																				
6																				
Defects / Identified							Labels and Warning Notice Issued				CO Alarm(s)				Smoke	Smoke Alarm(s)				
1										NA			() () .							
2										NA		CO Ala	rm(s) fitt	tea	NA	Smoke /	Alarm(s) fitt	ea	NA	
4	3								CO Alarm(s) tested			Smoke	Smoke Alarm(s) tested							
5	·											and Satisfactory			and Satisfactory					
6																				
Emergency Co	ntrol Accessible NA	Gas '	Tightness Satisfactory NA		Comn	nents														
Gas Installation	n Pipework Visual Ir	nspection	Satisfactory NA																	
Equipotenti	al Bonding NA																			
Water quality/l	evel of inhibitor ac	ceptable	NA																	
NEXT INSPEC	NEXT INSPECTION DUE ON OR 14-Mar-2025																			
BEFORE																				
Signatures																				
Issued by:	Signed		1		eceived S y:	Signed						Date	:	14-M	ar-2024					
Print Name	rint Name																			