

Landlord Gas Safety Record

Cert. No. 12926

Safety Inspection and reporting carried out in accordance with the Gas Safety (Installation and Use) Regulations 1998 section 26(9) and the Gas Industry Unsafe Situations Procedure.

Company / Ii	Company / Installer						Job Address							Customer / Landlord								
Engineer	Anthony Stannard				Name Unknown						Name				les							
Company	Nortons	s Heating	Address 140								any ess											
Address	ddress Suite 4a Heritage House					Fifth Avenue								4								
	Osbaldwick					Yo	York							Hill Garth								
	York													York								
					Post Code YO31 0UW									North Yorkshire								
Post Code	st Code YO19 5UW				Tel. No Unknown								Code	YO41 5BP								
Tel No.	01904411040												lo									
Gas Safe Reg	199682																					
	542472																					
Appliance Details Inspection Details																						
Location	n Appliance Type		Make	Model		Flue Type	Landlord's Appliance	Appliance Inspected	Operating Pressure (mbar)	Heat Input (kW/h)	High Combust Reading Ratio CO ppm		Reading cio CO CO ppm %	Safety device(s) correct operation	Ventilation Provision satisfactory	Visual condition of flue and termination satisfactory	Flue Performance test	Appliance Serviced	Appliance safe to use			
1 Lounge	e	Fire	Unknown	Unkno	own	OF	Yes	Visual	NA	NA		NA N	A NA N		NA	NA	NA	NA	NA			
	Hallway Boiler		Worcester Bosch	Greenstar 25i ErP		RS	Yes	Yes	18.2	25	.0007 69				Yes	Yes	Pass	Yes	Yes			
3	_																					
4																						
5																						
6																						
Defects / Ide	Defects / Identified Labels and Warning Notice Issued														CO Alarm(s) Optional Checks							
									N/A			CO Alarm(s) fitted Yes					Smoke Alarm(s) fitted Yes					
2		Previously isolated from the supply							NA No			, 55										
3								.10			CO Alarm(s) tested			Smoke Alarm(s) tested			Pass					
4										and Satisfactory			and Satisfactory			1 455						
5														Water o		مداماناهم						
6																	Water quality/level of inhibitor acceptable Yes					
Emergency Cor	Emergency Control Accessible Yes Gas Tightness Satisfactory Yes Comments																					
Gas Installation Pipework Visual Inspection Satisfactory Yes																						
Equipotential Bonding Yes																						
NEXT INSPECTION DUE BEFORE 26-Jul-2026																						
C'																						
Signatures Issued by:	Signed Received Signed Date 24-Jul-2025 by:																					
Print Name		Anthony Stanna	ird	P	Print Name																	