Landlord Gas Safety Record

This inspection is for gas safety purposes only in accordance with the Gas Safety (I & U) Regulations. Flues were inspected visually and checked for satisfactory evacuation of products of combustion. A detailed internal inspection of the Flue integrity, construction and lining has not been carried out.

Landlords Inspection Service

Aylestone Road Leicester Leicestershire LE27QH

Landlord/Agent Details

Mrs Lutyens-humfrey & Mr N humfrey 84,Southdown Road London

SW208PX

Property details

41EASTFIELD CRES YORK YO105HZ



Appliance details					Inspection details									
	Location	Туре	Make	Model	Flue type	Operating value (see key below)	device	Ventilation satisfactory	Flue performance		Visual condition			Indicate
									Flue flow test	Spillage test	of flue and termination satisfactory	safe*	Requested to test**	YES if unable to test**
1	Shower room	СНВ	Biasi UK Limited	GARDA PLUS HE	Room Sealed	28.98k	Yes	Yes	N/A	N/A	Yes	Yes	Yes	
2	bathroom	СНВ	Worcester Heat	Greenstar 4000	Room Sealed	28.98k	Yes	Yes	N/A	N/A	Yes	Yes	Yes	
3														
4														
5														

	Details of any defects we found	What we've done	Labelled and warning notice given	Gas installation tightness test and visual inspection of pipework
1				inspection of pipework
2				Door
3				Pass
4				Next safety inspection
5				due on 23rd July 2026

This safety record has our engineer's electronic signature: Antony Bulmer 3994458

Date: 17th July 2025

Job Number: 1704840400

Number of appliances tested: 2

It is a legal requirement that this record is kept for at least two years

Key for Operating Value

m = Operating Pressure in Millibars (mbars) k = Gas Rates in kilowatts (kW)

c = Combustion Ratio CO/CO 2 ('c' will only be displayed where neither 'm' nor 'k' could be recorded i.e. an unmetered gas supply).

*If N/A is selected, it means we've done a visual check that showed no obvious defects. We recommend all gas appliances are serviced once a year to make sure they're safe. Please ask your engineer about this or book an appointment at britishgas.co.uk

**If Requested to test is NO or Unable to test is YES, please take a look at the back of this certificate



Your Landlord Gas Safety Record is over the page

- This is an important document
- You should take a few moments now to read it
- You may need to refer to this certificate in the future
- Please file it somewhere safe and keep for a minimum of 2 years

Important safety information for landlords

To help you to better understand your landlord gas safety record (also known as a landlord certificate or a CP12) we would like to draw your attention to the following key sections:

Appliance Safe

If there is a "NO" in this section please look at the "Details of any defects we found" and "What we've done" sections overleaf. If you are unsure of any comment please contact the landlords team who will be happy to help you.

Indicate YES if Unable to test

If a "YES" has been entered in the column titled "Indicate YES if unable to test," then the landlord/agent must obtain additional evidence from any person undertaking subsequent work on the appliance, that the appliance is operating safely.

If we couldn't test appliances

You'll need to get written evidence, and must keep it with this record from anyone that checks and/or carries out any work on it to say it's working safely.

Requested to test

If a "NO" has been entered in the column "Requested to Test" and this relates to a gas appliance at the premise that does not belong to the current tenant then it may be a breach of the gas safety regulation to rent the property without all gas appliances being

checked. The only exception to this is if the appliance has been installed by a gas safe registered engineer and is still under the first year warranty.

NCS or NTCS Not to current standards
AR At Risk. This means that the appliance or
installation has one or more recognised faults, and
could constitute a danger to life or the property if
you or anyone else continues to use it. The
appliance/installation has been turned off and you
shouldn't use it until work has been carried out to
correct the faults identified. It may be an offence to
use a gas appliance or installation knowing it is a
risk.

ID Immediately Dangerous. This means that your appliance or installation presents an **immediate** danger to life if you carry on using it or if it's left connected to your gas supply. It's been turned off and should be disconnected for your safety and those around you. Using the isolated installation or equipment before it's been repaired is extremely dangerous. Please do not use it. It is an offence to use a gas appliance or installation knowing it is dangerous.

Here are some common abbreviations

AECV Additional Emergency Control Valve

ASD Atmospheric Sensing Device ECV Emergency Control Valve

FSD Flame Supervision Device (also known FFD)

NGES National Gas Emergency Service
PEB Protective Equipotential Bonding

PRV Pressure Relief Valve

Key to Appliance Type Abbreviations

AGA Aga

BBC Back Boiler Circulator

BBF Back Boiler Fire

CGE Electric / Gas Cooker CHB Central Heating Boiler

CIR Circulator
CKR Gas Cooker

FRB Back Boiler Fire FRC Back Circulator Fire

FRE Gas Fire GRL Grill

HGE Electric/Gas Hob

HOB Hob

INS Gas Meter, Pipes & Emergency Control Valve

MWH Multipoint Water Heater

OVN Gas Oven

SLC Split Level Cooker

SWH Single Point Water Heater

TDG Gas Tumble Dryer WAC Warm Air Circulator

WAL Wall Heater WAU Warm Air Unit

WAW Warm Air Unit and Water Heater

WH Water Heater

