Landlord Gas Safety Record

Cert. No. 669

Simtec Plumbing And Heating

Safety Inspection and reporting carried out in accordance with the Gas Safety (Installation and Use) Regulations 1998 section 26(9) and the Gas Industry Unsafe Situations Procedure.

Company / Installer

Engineer	Deklan Simpson
Company	Simtec Plumbing And Heating
Address	Simtec Heating.The Raylor Centre
	James Street
	York
Post Code	YO103DW
Tel No.	01904412109
Gas Safe Reg	3916101
ID Card No.	3916101

Job Address

Name	
Address	24
	Nicholas Street
	York
Post Code	YO10 3EQ
Tel. No	

Customer / Landlord

Name	
Company	Adam Bennetts
Address	58
	Gillygate
	York
Post Code	YO31 7eq
Tel. No	01904611611

Appliance Details / Inspection Details

	Location	Appliance Type	Make	Model	Flue Type	Landlord's Appliance	Appliance Inspected	Operating Pressure (mbar)	Heat Input (kW/h)	High Combustion Reading			Low Combustion Reading			Safety device(s) correct operation	Ventilation Provision satisfactory	Visual condition of flue and termination satisfactory	Flue Performance test	Appliance Serviced	Appliance safe to use
										Ratio	CO ppm	CO2 %	Ratio	CO ppm	CO2 %						
1	Ktichen	Boiler	Vokera	Excel 25	RS	No	Yes	19.8	30	0.0005	76	7.3	Na	Na	Na	Yes	Yes	Yes	Pass	NA	Yes
2	Kitchen	Hob	Lamona	Unknown	RS	Yes	Yes	NA	NA	Na	Na	Na	Na	Na	Na	Yes	Yes	NA	NA	NA	Yes
3																					
4																					
5																					
6																					

Defects / Identified

		Labels and Warning Notice Issued
1		NA
2		NA
3		
4		
5		
6		

CO Alarm(s)

CO Alarm(s) fitted	Yes
CO Alarm(s) tested and Satisfactory	Pass

Emergency Control Accessible Yes Gas Tightness Satisfactory Yes

Gas Installation Pipework Visual Inspection Satisfactory Yes

Equipotential Bonding Yes

NEXT INSPECTION DUE BEFORE 26-Jan-2027

Comments

Signatures

Issued by: Signed

Print Name Deklan Simpson

Received by: Signed

Print Name

Date 26-Jan-2026