



Simtec Plumbing And Heating

Landlord Gas Safety Record

Safety Inspection and reporting carried out in accordance with the Gas Safety (Installation and Use) Regulations 1998 section 26(9) and the Gas Industry Unsafe Situations Procedure.

Cert. No. 905

Company / Installer		Job Address		Customer / Landlord	
Engineer	Deklan Simpson	Name		Name	
Company	Simtec Plumbing And Heating	Address	54	Company	Adam Bennetts
Address	Simtec Heating.The Raylor Centre		Scarcroft Hill	Address	58
	James Street		York		Gillygate
	York				York
Post Code	YO103DW	Post Code	YO24 1DE	Post Code	YO31 7eq
Tel No.	01904412109	Tel. No		Tel. No	01904611611
Gas Safe Reg	3916101				
ID Card No.	3916101				

Appliance Details						Inspection Details															
	Location	Appliance Type	Make	Model	Flue Type	Landlord's Appliance	Appliance Inspected	Operating Pressure (mbar)	Heat Input (kW/h)	High Combustion Reading			Low Combustion Reading			Safety device(s) correct operation	Ventilation Provision satisfactory	Visual condition of flue and termination satisfactory	Flue Performance test	Appliance Serviced	Appliance safe to use
										Ratio	CO ppm	CO2 %	Ratio	CO ppm	CO2 %						
1	Kitchen	Boiler	Ideal	Vogue Max Combi 40	RS	Yes	Yes	20.3	40	NA	NA	NA	NA	NA	NA	Yes	Yes	Yes	Pass	NA	Yes
2																					
3																					
4																					
5																					
6																					

Defects / Identified										Labels and Warning Notice Issued						CO Alarm(s)	
1										NA						CO Alarm(s) fitted Yes CO Alarm(s) tested and Satisfactory Pass	
2																	
3																	
4																	
5																	
6																	

Emergency Control Accessible Yes Gas Tightness Satisfactory Yes	Comments
Gas Installation Pipework Visual Inspection Satisfactory Yes	
Equipotential Bonding Yes	

Signatures			
Issued by:	Signed	Received Signed by:	Date
			28-Jul-2026
Print Name	Deklan Simpson	Print Name	NEXT INSPECTION DUE BEFORE 28-Jul-2027