

LANDLORD/HOME OWNER GAS SAFETY RECORD

This inspection is for gas safety purposes only in accordance with the current edition of the Gas Safety (Installation and Use) Regulations. Flues were inspected visually and checked for satisfactory evacuation of products of combustion. A detailed internal inspection of the flue integrity, construction and lining has not been carried out.

GAS INSTALLER: (Trading Title) <i>COLIN ROBERTSON</i>		
Name:	<i>C. ROBERTSON</i>	Gas Safe Register No: <i>157664</i>
Address:	<i>19 LEIGHTON CROFT</i>	Gas Installer Ref. No: <i>A.B.</i>
	<i>YORK</i>	Date of Issue: <i>2/9/25</i>
Post code:	<i>YO30 5ZG</i>	Time of Issue:
Tel:	<i>07710448500</i>	Engineers Name: (print) <i>C. ROBERTSON</i>

TENANT/HOME OWNER DETAILS

Tenant/Home Owner* Name:	
Property Address:	<i>3 FEVERHAM CRESCENT</i>
	<i>YORK</i>
Post Code	Tel:
Tenant/Home Owner* present during inspection YES/NO	

LANDLORD/AGENT DETAILS (if applicable)

Landlord/Agent* Name: <i>ADAM BENNETT LETTING</i>	
Address:	<i>58 GILL/GATIE</i>
	<i>YORK</i>
Post Code	Tel: <i>611811</i>
Landlord/Agent* present during inspection YES/NO	

APPLIANCE DETAILS					INSPECTION DETAILS							FLUE TEST					RESULTS		
LOCATION	MAKE	MODEL	TYPE	Flue Type e.g. CF or RS	Operating Pressure Mbar	Heat Input Kw	Safety Device Correct Operation Yes/No	Ventilation Adequate Yes/No	CO Alarm fitted Yes/No	CO Alarm tested Pass/Fail	Flue Flow Test Pass/Fail	Spillage Test Pass/Fail	Termination Satisfactory Yes/No	Visual Condition Pass/Fail	Combustion Performance Reading CO ₁ / CO ₂ CO ₂ Ratio / CO ₂ CO	Appliance Safe To Use Yes/No	Landlord's Appliance Yes/No	Inspected Yes/No	
1. Boiler Room	Boiler	330	He	R.S	18	—	Yes	Yes	Yes	Pass	Pass	Pass	Yes	Pass	8.8/15.8	Yes	Yes	Yes	
2																			
3																			
4																			
5																			
DETAILS OF ANY FAULTS					REMEDIAL ACTION TAKEN							DETAILS OF WORK CARRIED OUT					LABEL & WARNING NOTICE ISSUED		
1	Boiler showing signs				1	of age. Advise boiler change												Yes	NO
2					2														
3					3														
4					4														
5					5														

Outcome of gas installation pipework visual inspection?	Pass / Fail / NA
Outcome of gas supply pipework visual inspection?	Pass / Fail / NA
Is the Emergency Control Valve access satisfactory?	Pass / Fail / NA
Outcome of gas tightness test?	Pass / Fail / NA
Is the Protective Equipotential bonding satisfactory?	Pass / Fail / NA

This Safety Record is issued by Gas Installer: (SIGNED) *[Signature]*

Received on behalf of Landlord / Home Owner: (SIGNED)

Tenant/Landlord/Agent/Home Owner*

Number of appliances tested: *ONE*

Date: *2/9/25*

ATTENTION

Next safety
check due by:

2/9/26

To re-order quote code 663010-NUM

Copies: White - Landlord/Agent/Home Owner

Green - Registered Gas Installer

Pink - Tenant

* delete as applicable

2388791

ARCTIC
HAYES